



## **NORTH COAST RESOURCE PARTNERSHIP**

### **2018/19 IRWM Project Application**

---

The North Coast Resource Partnership (NCRP) 2018/19 Project Application Instructions and additional information can be found at the NCRP 2018/19 Project Solicitation webpage (<https://northcoastresourcepartnership.org/proposition-1-irwm-round-1-implementation-funding-solicitation/>). Please fill out grey text boxes and select all the check boxes that apply to the project. Application responses should be clear, brief and succinct.

**Project Applications will be accepted until 5:00 pm, March 8, 2019 March 15, 2019.** It is important to save the application file with a distinct file name that references the project name. When the application is complete, please email to [kgledhill@westcoastwatershed.com](mailto:kgledhill@westcoastwatershed.com)

**If you have questions, need additional information or proposal development assistance please contact:**

- Katherine Gledhill at [kgledhill@westcoastwatershed.com](mailto:kgledhill@westcoastwatershed.com) or 707.795.1235
- Tribal Projects: Sherri Norris, NCRP Tribal Coordinator at [sherri@cieaweb.org](mailto:sherri@cieaweb.org) or 510.848.2043

**Project Name:** Improving Willits Water Supply Reliability and Drought Resiliency with Groundwater and Conjunctive Use

#### **A. ORGANIZATION INFORMATION**

- 1. Organization Name: City of Willits**
- 2. Contact Name/Title**  
Name: Jim Robbins  
Title: Community Development Specialist  
Email: [jrobbins@cityofwillits.org](mailto:jrobbins@cityofwillits.org)  
Phone Number (include area code): 707-459-7155
- 3. Organization Address (City, County, State, Zip Code):**  
111 E. Commercial Street - Willits, CA 95490 - Mendocino County

**4. Organization Type**

- ☒ Public agency  
☐ Non-profit organization  
☐ Public utility  
☐ Federally recognized Indian Tribe  
☐ California State Indian Tribe listed on the Native American Heritage Commission's California Tribal Consultation List  
☐ Mutual water company  
☐ Other:

**5. Authorized Representative** (if different from the contact name)

Name: Stephanie Garrabrant-Sierra

Title: City Manager

Email: sgsierra@cityofwillits.org

Phone Number (include area code): 707-459-4601

**6. Has the organization implemented similar projects in the past?** ☒ yes ☐ no

Briefly describe these previous projects.

The Emergency Water Line Project (2014-15): Installed a production well (the Elias Replacement Well), built a groundwater treatment plant, and installed 8000' of new 8" C900 water pipe.

Long 20 Test Well Project: Installed an 8" test well 2500' south of the Elias Replacement Well. The City is considering converting this well into a regular use production well.

**7. List all projects the organization is submitting to the North Coast Resource Partnership for the 2018/19 Project Solicitation in order of priority.**

1 Project: "Improving Willits Water Supply Reliability and Drought Resiliency with Groundwater and Conjunctive Use"

**8. Organization Information Notes:**

The City of Willits is a severely disadvantaged community in Mendocino County.

---

**B. ELIGIBILITY**

**1. North Coast Resource Partnership and North Coast IRWM Objectives**

**GOAL 1: INTRAREGIONAL COOPERATION & ADAPTIVE MANAGEMENT**

☒ Objective 1 - Respect local autonomy and local knowledge in Plan and project development and implementation

☐ Objective 2 - Provide an ongoing framework for inclusive, efficient intraregional cooperation and effective, accountable NCIRWMP project implementation

☐ Objective 3 - Integrate Traditional Ecological Knowledge in collaboration with Tribes to incorporate these practices into North Coast Projects and Plans

**GOAL 2: ECONOMIC VITALITY**

☒ Objective 4 - Ensure that economically disadvantaged communities are supported and that project implementation enhances the economic vitality of disadvantaged communities by improving built and natural infrastructure systems and promoting adequate housing

☐ Objective 5 - Conserve and improve the economic benefits of North Coast Region working landscapes and natural areas

**GOAL 3: ECOSYSTEM CONSERVATION AND ENHANCEMENT**

☐ Objective 6 – Conserve, enhance, and restore watersheds and aquatic ecosystems, including functions, habitats, and elements that support biological diversity

☐ Objective 7 - Enhance salmonid populations by conserving, enhancing, and restoring required habitats and watershed processes

**GOAL 4: BENEFICIAL USES OF WATER**

☒ Objective 8 - Ensure water supply reliability and quality for municipal, domestic, agricultural, Tribal, and recreational uses while minimizing impacts to sensitive resources

☒ Objective 9 - Improve drinking water quality and water related infrastructure to protect public health, with a focus on economically disadvantaged communities

☐ Objective 10 - Protect groundwater resources from over-drafting and contamination

**GOAL 5: CLIMATE ADAPTATION & ENERGY INDEPENDENCE**

☒ Objective 11 - Address climate change effects, impacts, vulnerabilities, and strategies for local and regional sectors to improve air and water quality and promote public health

☒ Objective 12 - Promote local energy independence, water/ energy use efficiency, GHG emission reduction, and jobs creation

**GOAL 6: PUBLIC SAFETY**

☐ Objective 13 - Improve flood protection and reduce flood risk in support of public safety

**2. Does the project have a minimum 15-year useful life?**

☒ yes ☐ no

If no, explain how it is consistent with Government Code 16727.

**3. Other Eligibility Requirements and Documentation**

**CALIFORNIA GROUNDWATER MANAGEMENT SUSTAINABILITY COMPLIANCE**

a) Does the project that directly affect groundwater levels or quality?

☒ yes ☐ no

b) If Yes, will the organization be able to provide compliance documentation outlined in the instructions, to include in the NCRP Regional Project Application should the project be selected as a Priority Project?

☒ yes ☐ no

**CASGEM COMPLIANCE**

a) Does the project overlie a medium or high groundwater basin as prioritized by DWR?

☐ yes ☒ no

b) If Yes, list the groundwater basin and CASGEM priority:

c) If Yes, please specify the name of the organization that is the designated monitoring entity:

- d) If there is no monitoring entity, please indicate whether the project is wholly located in an economically disadvantaged community.  
☒ yes      ☐ no

#### URBAN WATER MANAGEMENT PLAN

- a) Is the organization required to file an Urban Water Management Plan (UWMP)?  
☐ yes      ☒ no
- b) If Yes, list the date the UWMP was approved by DWR:
- c) Is the UWMP in compliance with AB 1420 requirements?  
☐ yes      ☐ no
- d) Does the urban water supplier meet the water meter requirements of CWC 525?  
☐ yes      ☐ no
- c) If Yes, will the organization be able to provide compliance documentation outlined in the instructions, to include in the NCRP Regional Project Application should the project be selected as a Priority Project?  
☐ yes      ☐ no

#### AGRICULTURAL WATER MANAGEMENT PLAN

- a) Is the organization – or any organization that will receive funding from the project – required to file an Agricultural Water Management Plan (AWMP)?  
☐ yes      ☒ no
- b) If Yes, list date the AWMP was approved by DWR:
- c) Does the agricultural water supplier(s) meet the requirements in CWC Part 2.55 Division 6?  
☐ yes      ☐ no

#### SURFACE WATER DIVERSION REPORTS

- a) Is the organization required to file surface water diversion reports per the requirements in CWC Part 5.1 Division 2?  
☒ yes      ☐ no
- d) If Yes, will the organization be able to provide SWRCB verification documentation outlined in the instructions, to include in the NCRP Regional Project Application should the project be selected as a Priority Project?  
☒ yes      ☐ no

#### STORM WATER MANAGEMENT PLAN

- a) Is the project a stormwater and/or dry weather runoff capture project?  
☐ yes      ☒ no
- b) If yes, does the project benefit a Disadvantaged Community with a population of 20,000 or less?  
☐ yes      ☐ no
- e) If No, will the organization be able to provide documentation that the project is included in a Stormwater Resource Plan that has been incorporated into the North Coast IRWM Plan, should the project be selected as a Priority Project?  
☐ yes      ☒ no



## C. GENERAL PROJECT INFORMATION

### 1. Project Name: Improving Willits Water Supply Reliability and Drought Resiliency with Groundwater and Conjunctive Use

### 2. Eligible Project Type under 2018/19 IRWM Grant Solicitation

- ☐ Water reuse and recycling for non-potable reuse and direct and indirect potable reuse
- ☐ Water-use efficiency and water conservation
- ☐ Local and regional surface and underground water storage, including groundwater aquifer cleanup or recharge projects
- ☐ Regional water conveyance facilities that improve integration of separate water systems
- ☒ Watershed protection, restoration, and management projects, including projects that reduce the risk of wildfire or improve water supply reliability
- ☐ Stormwater resource management projects to reduce, manage, treat, or capture rainwater or stormwater
- ☐ Stormwater resource management projects that provide multiple benefits such as water quality, water supply, flood control, or open space
- ☐ Decision support tools that evaluate the benefits and costs of multi-benefit stormwater projects
- ☐ Stormwater resource management projects to implement a stormwater resource plan
- ☒ Conjunctive use of surface and groundwater storage facilities
- ☐ Decision support tools to model regional water management strategies to account for climate change and other changes in regional demand and supply projections
- ☐ Improvement of water quality, including drinking water treatment and distribution, groundwater and aquifer remediation, matching water quality to water use, wastewater treatment, water pollution prevention, and management of urban and agricultural runoff
- ☐ Regional projects or programs as defined by the IRWM Planning Act (Water Code §10537)
- ☐ Other:

### 3. Project Abstract

Today, the Willits water system lacks the groundwater capacity to provide for the needs of the communities if surface water again becomes untenable. The proposed project seeks to expand both groundwater capacity, increasing system resiliency, and conjunctive use, increasing flexibility. This flexibility would increase options for managing water quality, aquifers, watersheds, and critical habitats. Secure water also represents an economic benefit for a severely disadvantaged community.

### 4. Project Description

The Willits water system serves approximately 5,500 people in the City of Willits and adjacent communities, providing an average 890 thousand gallons per day (kgpd), with peak flows up to 1,400 kgpd in summer. Until recently, all drinking water flowed from Morris Reservoir. In 2014, the continuing drought led to a water crisis in Willits, restrictions on water use, and emergency funds. As a result, the Elias well system was developed, which now supplies and treats supplementary groundwater. Currently, that system can produce a maximum of 490 kgpd. However, the Elias system is inadequate to meet the community's needs in the event of severe or protracted drought, or if the surface water system or its single pipeline were damaged, especially if such events occur in summer months.

The proposed project would expand the initial groundwater capacity, allow for increased conjunctive use, and ensure a reliable water supply sufficient to meet community needs if surface water again becomes untenable. Specifically, the project would replace a 30 hp pump in the primary "Elias Replacement" well

with a 70 hp pump, increasing capacity to 1,140 kgpd. A prior study showed that well and aquifer capable of sustaining 1,150 kgpd with adequate safety factors. The 30 hp pump and controls would then be installed in the secondary "Long 20" well. Both pumps would require upgraded power supplies. Increased flows also require upgrading a 3650 ft section of 6" sch 40 PVC pipe connecting the wells to the treatment plant. Finally, we would perform pilot tests to confirm the arsenic detected in the secondary Long 20 well would be adequately removed by the treatment plant prior to integrating that source. The treatment plant was designed with excess capacity.

Increasing groundwater capacity creates system resilience and the flexibility to manage sources based on real-time considerations. The people of Willits see this effort as crucial and it has broad support in the City Council. Water security represents an economic benefit in an area almost entirely classified as severely disadvantaged. The area has experienced recent droughts, and climate change predictions suggest such conditions will only become more common.

## **5. Specific Project Goals/Objectives**

Goal 1: Improve reliability of potable water supplies for the City of Willits and surrounding communities.

Goal 1 Objective: Increase capacity to provide potable water from groundwater sources, providing local self-reliance during dry periods, expected to become more common with climate change effects.

Goal 1 Objective: Develop groundwater sources sufficient to provide potable water in the event of catastrophic failure of the surface water system.

Goal 1 Objective:

Goal 1 Objective:

Goal 2: Increase flexibility in potable water source selection.

Goal 2 Objective: Increase conjunctive use of existing storage, preventing water quality issues resulting from low reservoir levels and providing options in the event of water quality issues from either source.

Goal 2 Objective: Allow for source-selection decision-making which considers economic concerns, energy efficiency, downstream flows and watersheds, salmonid populations, and aquifer health.

Goal 2 Objective:

Goal 2 Objective:

Goal 3: Support the City of Willits and surrounding communities.

Goal 3 Objective: Provide reliable water quality and water quantities required for development in an almost entirely severely economically disadvantaged area.

Goal 3 Objective:

Goal 3 Objective:

Additional Goals & Objectives (List)

## **6. Describe how the project addresses the North Coast Resource Partnership and North Coast IRWM Plan Goals and Objectives selected.**

Additional groundwater capacity provides both increased reliability of water supply and flexibility to avoid and respond to water quality issues, addressing NCRP's "ensure water supply reliability and quality" objective. That resulting flexibility also allows decision-making that supports healthy downstream surface-water flows, watersheds, salmonid habitat, and aquifers, addressing NCRP objectives "improve watersheds & salmonid populations" and "protect groundwater resources." As it provides reliability for communities almost entirely classified as SDAC, it addresses the objective "Support disadvantaged communities" within NCRP's "economic vitality" goal. Finally, this project helps

the communities adapt to dry periods, likely to be increasingly common as consequences of climate change, addressing the NCRP goal of “climate adaptation & energy independence.”

**7. Describe the need for the project.**

Today, the Willits water supply faces numerous threats. Severe or protracted drought, like that experienced in 2014 and prior years, could reduce Morris Reservoir levels such that it cannot serve as an adequate source. Additionally, water is transported from the reservoir to the city via a single pipeline; there would be little recourse in the event of catastrophic failure. Further, reduced levels in the reservoir have led to increased temperatures, causing biological growth and water quality issues. Indeed, such organics overwhelmed the system following the 2014 drought, leading to violations for TTHM. Currently, the well can provide supplementary groundwater, but only a fraction of typical needs. Thus, water quantities and qualities remain vulnerable to extreme events or failures. The proposed project would build on the initial development of the existing improvement, creating a system that offers resilient and reliable supply of high-quality drinking water.

**8. List the impaired water bodies (303d listing) that the project benefits:**

N/A

**9. Will this project mitigate an existing or potential Cease and Desist Order or other regulatory compliance enforcement action?** ☐ yes ☒ no

If so, please describe?

**10. Describe the population served by this project.**

This project serves roughly 5,500 people in the City of Willits and surrounding communities. The vast majority of this population (>95%) resides within severely economically disadvantaged communities (SDAC), as identified via the NCRP mapping data tool. The SDAC area includes census block groups with median HH incomes between \$35,094 and \$18,261 based on the DWR's DAC mapping tool. Less than 5% of the population lives outside this region, but within economically disadvantaged communities (DAC).

**11. Does the project provide direct water-related benefits to a project area comprised of Disadvantaged Communities or Economically Distressed Communities?**

- ☐ Entirely
- ☒ Partially
- ☐ No

**List the Disadvantaged Community(s) (DAC)**

Less than 5%: Neighborhoods near Bray & Commercial (E of Willits), Locust Street (S of Willits), and Hill & Center Valley Rd (E of Willits).

**12. Does the project provide direct water-related benefits to a project area comprised of Severely Disadvantaged Communities (SDAC)?**

- ☒ Entirely
- ☒ Partially
- ☐ No

**List the Severely Disadvantaged Community(s)**

Over 95%: City of Willits, Simerson (unincorporated, N of Willits); Upp (unincorporated, N of Willits); Fair Oaks (unincorporated, S of Willits); Meadowbrook (neighborhood, S of Willits).

**13. Does the project provide direct water-related benefits to a Tribe or Tribes?**

- ☒ Entirely
- ☐ Partially
- ☐ No

**List the Tribal Community(s)**

Sherwood Valley Band of Pomo Indians, tribal lands adjacent to the City of Willits

If yes, please provide evidence of support from each Tribe listed as receiving these benefits.

**14. If the project provides benefits to a DAC, EDA or Tribe, explain the water-related need of the DAC, EDA or Tribe and how the project will address the described need.**

All of the City of Willits is a severely disadvantaged community. The City water system also serves the Sherwood Valley Rancheria. The City of Willits, Rancheria, and other adjoining areas have similar needs for water that will be enhanced and made more secure by this project. As the project area includes only DAC and Tribal communities, all needs (C.7.) and benefits (F.2., F.6.) refer to communities so classified.

**15. Does the project address and/or adapt to the effects of climate change? Does the project address the climate change vulnerabilities in the North Coast region?** ☒ yes ☐ no

If yes, please explain.

The North Coast Regional Climate Adaptation Report describes the forecast for drought as the most concerning of regional climate impacts. This project would add resiliency to a system known to be vulnerable to such droughts, representing an adaptation to expected trends.

Additionally, the Elias well system represents a more energy-efficient source of water, as the higher water quality requires fewer treatment steps and as the geographically closer source requires less energy for transport.

**16. Describe how the project contributes to regional water self-reliance.**

In 2014, the City of Willits required outside assistance from the State of CA in response to emergency conditions. This project aims to build resilience in the water system such that response to similar scenarios could be handled locally.

**17. Describe how the project benefits salmonids, other endangered/threatened species and sensitive habitats.**

Morris Reservoir, the current source for Willits surface water, empties into Davis Creek, which feeds Outlet Creek in the Eel River watershed. Davis Creek is classified as a critical habitat for both Chinook salmon and steelhead, based on the NCRP's mapping data tool. Expanding groundwater and conjunctive use for the city allows additional flexibility in managing the reservoir output during dry months, including consideration of requisite flows for salmonid species.

**18. Describe local and/or political support for this project.**

Given the recent 2014 water emergency, there is broad local public support for projects that improve resilience and reliability of the local water supply. Additionally, this and similar projects have been discussed at numerous City Council meetings and Water and Wastewater Committee meetings. Current and past City Councils have strongly supported the development of groundwater because they recognize how vulnerable the City is to dry periods or pipeline failures.

**19. List all collaborating partners and agencies and nature of collaboration.**

To date, the city has not created partnerships for this project outside of the fact that the City provides water to the Sherwood Valley Rancheria, including their small casino and café on tribal land.

- 20. Is this project part or a phase of a larger project?** ☒ yes ☐ no  
**Are there similar efforts being made by other groups?** ☐ yes ☒ no

**If so, please describe?**

This project represents an informal second phase of the response to the 2014 water emergency. The improvements undertaken since the emergency have allowed the communities to get by. This phase would complete the effort, creating a conjunctive use system providing a resilient water supply with the flexibility to consider watersheds, aquifers, habitats, energy, and economic considerations.

- 21. Describe the kind of notification, outreach and collaboration that has been done with the County(ies) and/or Tribes within the proposed project impact area, including the source and receiving watersheds, if applicable.**

The City of Willits has worked with the County to secure a permit for the well. The city provides water and wastewater services to the Sherwood Valley Band of Pomo Indians.

- 22. Describe how the project provides a benefit that meets at least one of the Statewide Priorities as defined in the 2018 IRWM Grant Program Guidelines and Tribal priorities as defined by the NCRP?**

By completing a groundwater system capable of meeting the needs of these communities, this project will create a more resilient drinking water system, addressing the Statewide Priority to “provide safe water for all communities.” By adding flexibility, it will allow decision-making that considers economic, watershed, ecosystem, and aquifer health, meeting the Statewide Priority to “ensure that there is a sustainability aspect to the project.” Together, the added resiliency and flexibility address the Statewide Priority to “manage and prepare for dry periods.”

- 23. Project Information Notes:**

---

## **D. PROJECT LOCATION**

- 1. Describe the location of the project**

Geographical Information

**All project-related land parcels are owned by the City of Willits and are adjacent to or near the city limits to the north and north-east in the Little Lake Valley.**

- 2. Site Address (if relevant):**

- 3. Does the applicant have legal access rights, easements, or other access capabilities to the property to implement the project?**

☒ Yes If yes, please describe

☐ No If No, please provide a clear and concise narrative with a schedule, to obtain necessary access.

☐ NA If NA, please describe why physical access to a property is not needed.

The City of Willits owns all of the property at and surrounding the project site, has full access rights, and has full easements that are or might be necessary to implement and complete this project.

4. Project Location Notes:

E. PROJECT TASKS, BUDGET AND SCHEDULE

1. Projected Project Start Date: 1/1/20

Anticipated Project End Date: 12/31/21

2. Will CEQA be completed within 6 months of Final Award?

☒ Yes State Clearinghouse Number: TBD

☐ NA, Project is exempt from CEQA

☐ NA, Not a Project under CEQA

☐ NA, Project benefits entirely to DAC, EDA or Tribe, or is a Tribal local sponsor. [Projects providing a water-related benefit entirely to DACs, EDAs, or Tribes, or projects implemented by Tribes are exempt from this requirement].

☐ No

3. Please complete the CEQA Information Table below

Indicate which CEQA steps are currently complete and for those that are not complete, provide the estimated date for completion.

| CEQA STEP  | COMPLETE? (y/n) | ESTIMATED DATE TO COMPLETE |
|--|-----------------|----------------------------|
| Initial Study  | N               | 1/30/20                    |
| Notice & invitation to consult sent to Tribes per AB52 | N               | 1/30/20                    |
| Notice of Preparation                                  | N               | 1/30/20                    |
| Draft EIR/MND/ND                                       | N               | 2/15/20                    |
| Public Review  | N               | 3/15/20                    |
| Final EIR/MND/ND                                       | N               | 3/30/20                    |
| Adoption of Final EIR/MND/ND                           | N               | 4/30/20                    |
| Notice of Determination                                | N               | 4/30/20                    |
| N/A - not a CEQA Project                               | N               |                            |

If additional explanation or justification of the timeline is needed or why the project does not require CEQA, please describe.

4. Will all permits necessary to begin construction be acquired within 6 months of Final Award?

☒ Yes

☐ NA, Project benefits entirely to DAC, EDA, Tribe, or is a Tribal local sponsor

☐ No

## 5. PERMIT ACQUISITION PLAN

| Type of Permit    | Permitting Agency            | Date Acquired or Anticipated |
|-------------------|------------------------------|------------------------------|
| 404 Certification | U.S. Army Corps of Engineers | 4/30/20                      |
| 401 Certification | Regional Water Board         | 4/30/20                      |
|                   |                              |                              |
|                   |                              |                              |
|                   |                              |                              |
|                   |                              |                              |

**For permits not acquired: describe actions taken to date and issues that may delay acquisition of permit.**

Although not anticipated to delay the acquisition of permits, the completion of a Wetland Delineation at the project site in tandem with the preparation of permit applications is recommended.

### 6. Describe the financial need for the project.

The City of Willits is a severely disadvantaged community that has significant need, but little capacity, to finance medium and large scale public works projects to address the water needs of the community with existing fund sources.

### 7. Is the project budget scalable? ☐ yes ☒ no

**Describe how a scaled budget would impact the overall project.**

From a budget standpoint, upgrading the pipeline from the wells to water treatment constitutes the largest single component, and there is no practical way to scale this element. That said, the project could likely be implemented in two phases. In the first phase, the pipeline would be upgraded to increase transfer capacity from the wells to the groundwater treatment plant. In the second phase, the wells would be upgraded to increase pumping capacity and arsenic pilot tests would be performed.

### 8. Describe the basis for the costs used to derive the project budget according to each budget category.

For cost estimates, this project relied heavily on the professional experience of the City's engineer. Specifically, estimates for the pipeline replacement were made based on a similar project in Round Valley, where final costs for installation of a 6" main were ~\$140/ft. Costs for the 70 hp pump and pilot testing for arsenic removal were based on preliminary quotes. Most labor costs are based in prevailing wage, but there is a premium for specialized equipment given the City's remote location.

### 9. Provide a narrative on cost considerations including alternative project costs.

Considered alternatives included integrating water from the Park well, currently used for agriculture, but much higher arsenic levels necessitated additional treatment capital projects in excess of \$350k (compare with \$150k for the new pump). Increasing reservoir capacity was also considered but proved expensive and offered fewer benefits. Drilling of additional wells and alternative screening were both considered to reduce Long 20 arsenic levels but proved costlier than pilot testing.

### 10. List the sources of non-state matching funds, amounts and indicate their status.

N/A

**11. List the sources and amount of state matching funds.**

N/A

**12. Cost Share Waiver Requested (DAC or EDA)?** ☒ yes ☐ no

Cost Share Waiver Justification: Describe what percentage of the proposed project area encompasses a DAC/EDA, how the community meets the definition of a DAC/EDA, and the water-related need of the DAC/EDA that the project addresses. In order to receive a cost share waiver, the applicant must demonstrate that the project will provide benefits that address a water-related need of a DAC/EDA.

The proposed project serves the City of Willits and surrounding communities. The vast majority of the service area falls within severely economically disadvantaged communities (SDAC), as identified in both the NCRP and DWR DAC mapping tools. This SDAC area includes census block groups with median HH incomes between \$35,094 and \$18,261 based on the DWR's DAC mapping tool. The remaining area, less than 5%, lies outside SDAC block groups but within economically disadvantaged communities (DAC).

Currently, surface water from Morris reservoir is the only source capable of meeting the community's needs. The system is vulnerable to drought, as experienced in 2014, as well as failure of the surface water source, treatment, or single pipeline. The proposed project would develop groundwater capacity to meet the community's need, providing both reliability and the flexibility to optimize water quality, energy use, watershed and aquifer health, and critical habitat impacts.

**13. Major Tasks, Schedule and Budget for NCRP 2018 IRWM Project Solicitation**

Please complete MS Excel table available at <https://northcoastresourcepartnership.org/proposition-1-irwm-round-1-implementation-funding-solicitation/>; see instructions for submitting the required excel document with the application materials.

**14. Project Tasks, Budget and Schedule Notes:**

---

**F. PROJECT BENEFITS & JUSTIFICATION**

**1. Does the proposed project provide physical benefits to multiple IRWM regions or funding area(s)?**

☐ yes ☒ no

If Yes, provide a description of the impacts to the various regions.

**2. Provide a narrative for project justification. Include any other information that supports the justification for this project, including how the project can achieve the claimed level of benefits. List any studies, plans, designs or engineering reports completed for the project. Please see the instructions for more information about submitting these documents with the final application.**

The City of Willits is classified as a severely disadvantaged community. In response to the extreme drought conditions of 2013-2014, the City completed an emergency project constructing a new water treatment plant and over 8000' of new water line to connect two existing wells to the distribution system. This initial phase of developing groundwater infrastructure set up the framework for creating a



full system of redundancy. In 2017, non-emergency use of this groundwater supply was approved; however, the current infrastructure is only able to supply 490,000 gallons per day, approximately 43% of the amount needed to supply peak demand.

The surface water pipeline represents an additional vulnerability. Currently, the City's primary water supply travels 2.5 miles via a single 16" transmission line. In the event that the transmission line is compromised, the City would be solely reliant on groundwater. Completing the development of a secondary source of water that can supply the community's needs independent of surface water is critically important to the City's water security.

Improving water supply reliability is the primary purpose of this project; however, the added benefits of conjunctive use are numerous, including improved water quality, reduced operations and maintenance costs, greater operational flexibility, increased energy efficiency, reduced demands on staff time related to reporting and operations, as well as potentially increased water releases to Davis Creek, a critical salmonid habitat.

The City has received complaints regarding taste and odor during the summer months when reservoir water temperature rises and algae blooms. In contrast, groundwater developed to date produces colder, higher quality water, void of organics that occur in surface water and cause these issues. Blending groundwater with surface water would improve the overall water quality and temperature delivered to the consumers. Staff will have the ability to operate the Water Treatment Plant in conjunction with the Groundwater Treatment Plant to manage water quality, as well as reservoir levels.

The Groundwater Treatment Plant (GWTP) also requires less energy to operate than the surface Water Treatment Plant (WTP). As minimal treatment is required for this groundwater, the GWTP is simple in design, which makes it comparatively cost effective and energy efficient to run. Further, the Division of Drinking Water requires only minimal reporting and testing for groundwater, when compared with surface water.

Finally, a secondary supply of water creates operational flexibility to provide water if a critical system component for either supply needs to go offline for maintenance. Overall, use of groundwater as a supplement or replacement to surface water realizes the full investment into groundwater infrastructure to date. It provides the best quality water at a reduced operational cost with a negligible environmental impact.

- 3. Does the project address a contaminant listed in AB 1249 (nitrate, arsenic, perchlorate, or hexavalent chromium)?** ☒ yes ☐ no

If yes, provide a description of how the project helps address the contamination.

The primary Elias Replacement well has negligible levels of arsenic (As), but the secondary Long 20 well water has levels above the maximum contaminant level (MCL). We believe the current groundwater treatment system can remove As adequately, but this has not been independently tested. The project includes pilot testing to confirm that the existing treatment plant will reduce As levels below MCLs, a prerequisite to integrating that source into the drinking water system.

- 4. Does the project provide safe, clean, affordable, and accessible water adequate for human consumption, cooking, and sanitary purposes consistent with AB 685?** ☒ yes ☐ no

If Yes, please describe.

This project further develops alternative groundwater supplies for integration into the City of Willits drinking water system. Water from the primary Elias Replacement well has been used previously and

has adequate treatment methods in place. Water from the secondary Long 20 well has been tested for various analytes, showing elevated iron, manganese, and arsenic. As part of the proposed effort, in-place treatment methods will be tested to ensure safety before the source is integrated.

5. Does the project employ new or innovative technologies or practices, including decision support tools that support the integration of multiple jurisdictions, including, but not limited to, water supply, flood control, land use, and sanitation? ☒ yes ☐ no

If Yes, please describe.

Once complete, this project will allow for flexibility in source selection for the system's drinking water. We have identified a recently-developed model which could help forecast demand and support decision-making to balance considerations around water quality, energy efficiency, watershed and habitat health, and aquifer management.

6. For each of the Potential Benefits that the project claims complete the following table to describe an estimate of the benefits expected to result from the proposed project. [See the NCRP Project Application Instructions, Potential Project Benefits Worksheet and background information to help complete the table. The NCRP Project Application, Attachment B includes additional guidance, source materials and examples from North Coast projects.]

#### PROJECT BENEFITS TABLE

| Potential Benefits Description                                     | Physical Amt of Benefit | Physical Units | Est. Economic Value per year    | Economic Units |
|--|-------------------------|----------------|---------------------------------|----------------|
| <b>Water Supply</b>  |                         |                |                                 |                |
| 1. Increased Instream Flow   | 70                      | acre-ft        | \$8,400                         | \$/acre-ft/yr  |
| 2. Change in Timing and Volume of Instream Flows/ Fish Improvement |                         |                | not monetized                   |                |
| 3. Increased Water Supply Reliability                              | 2400                    | # households   | \$777,600                       | \$/yr          |
| 4. Water supply purchases  | 4) 503                  | 4) acre-ft     | 4) 140,840                      | 4) \$/acre-ft  |
| 5. Avoided Water Supply Projects                                   | 5) 1                    | 5) facility    | 5) \$750,000                    | 5) \$/facility |
| 6. Avoided Electric Costs  | 6) 36,000               | 6) kwh         | 6) \$5,000                      | 6) \$/yr       |
| 7. Avoided Water Shortage Costs                                    | 7) 15000 sq. ft.        | 7) sq. ft.     | 7) \$15,000                     | 7) \$/yr       |
| <b>Water Quality</b>   |                         |                |                                 |                |
| 8. Additional Water Quality Projects Avoided                       |                         |                | Monetized above in #5 \$750,000 | \$/facility    |
| 9. Chemical Treatment Reduction                                    |                         |                | \$27,500                        | \$/yr          |
|  |                         |                |                                 |                |
|  |                         |                |                                 |                |
| <b>Other Ecosystem Service Benefits</b>                            |                         |                |                                 |                |
|  |                         |                |                                 |                |
|  |                         |                |                                 |                |
| <b>Other Benefits</b>  |                         |                |                                 |                |
| 10. Increased Water Supply for Wildfire Fighting Use               |                         |                | 10) not monetized               | 10) none       |

| Potential Benefits Description                  | Physical Amt of Benefit | Physical Units | Est. Economic Value per year | Economic Units    |
|---|-------------------------|----------------|------------------------------|-------------------|
| 11. Decreased O&M Costs at Main Reservoir Plant |                         |                |                              | 11. 7,000 \$/year |
| 12. Improved water quality                      |                         |                | Not monetized                |                   |
|   |                         |                |                              |                   |

## 7. Project Justification & Technical Basis Notes:

The following notes correlate with the Project Benefits Table in F.6. above and provide assumptions for the calculations.

1. Increased Instream Flow - Voluntary 10% increase of water released to Davis Creek based on 2017 creek flows
2. Change in Timing and Volume of Instream Flow/Fish Improvement - Increased flows could have added benefit to Salmon and Steelhead populations
3. Increased Water Supply Reliability - Approximate number of households (Barakat & Chamberlin, 1994), assuming consumers would be willing to pay \$27 per month to avoid severe water rationing if an emergency cut off surface water supply.
4. Water supply purchases - High value based on shipping costs, no canals ways or pipes for water transfer, assume 1/2 water will need to be trucked in and other from Park Well or other well source
5. Avoided Water Supply Projects - Park Well may be improved to provide additional water supply if needed.
6. Avoided Electric Costs - Scaled reduction in energy costs. Approximate reservoir water plant yearly costs minus current groundwater plant costs scaled up by a factor of 1.8. Scale factor is current use ~350 gpm to ~624 gpm, assuming \$0.14 per kwh
7. Avoided Water Shortage Costs - Having reliable water from parks and recreation areas will prevent them from having to be replaced
8. Additional Water Quality Projects - Utilizing the Park Well would require treatment of arsenic
9. Chemical Treatment Reduction - Assumed 50% reduction in chemical needs other than copper sulfate
10. Increased Water Supply for wildfire Fighting Use - Having groundwater wells for domestic use means having more water for fore fighting use
11. Decrease O&M Costs at main reservoir plant - 10% reduction in maintenance due to minimized use at reservoir water plant, less wear on pumps
12. Improved water quality for the community is not monetized.

Total calculation for the project benefit in dollars per year, not including the Park Well improvement avoided cost = \$981,340

## Major Tasks, Schedule and Budget for North Coast Resource Partnership 2018/19 IRWM Project Solicitation

Project Name: Improving Willits Water Supply Reliability and Drought Resiliency with Groundwater and Conjunctive Use  
 Organization Name: City of Willits

| Task #   | Major Tasks  | Task Description   | Major Deliverables  | Current Stage of Completion | IRWM Task Budget | Non-State Match | Total Task Budget | Start Date | Completion Date |
|----------|--|--|---|-----------------------------|------------------|-----------------|-------------------|------------|-----------------|
| <b>A</b> | <b>Category (a): Direct Project Administration</b>                           |  |   |                             |                  |                 |                   |            |                 |
| 1        | Administration   | In cooperation with the County of Humboldt sign a sub-grantee agreement for work to be completed on this project. Develop invoices with support documentation. Provide audited financial statements and other deliverables as required | Invoices, audited financial statements and other deliverables as required | 0%                          | \$1,600.00       | \$0.00          | \$1,600.00        |            |                 |
| 2        | Monitoring Plan  | Develop Monitoring Plan to include goals and measurable objectives   | Final Monitoring Plan   | 0%                          | \$3,000.00       | \$0.00          | \$3,000.00        |            |                 |
| 3        | Labor Compliance Program   | Execute service agreement with Labor Compliance Program company  | Submission of Labor Compliance Program                                    | 0%                          | \$9,500.00       | \$0.00          | \$9,500.00        |            |                 |
| 4        | Reporting  | Develop monthly reports describing work completed, challenges, and strategies for reaching remaining project objectives. Develop Final Report  | Quarterly and Final Reports   | 0%                          | \$2,000.00       | \$0.00          | \$2,000.00        |            |                 |
| <b>B</b> | <b>Category (b): Land Purchase/Easement</b>                                  |  |   |                             |                  |                 |                   |            |                 |
| 1        |  |  |   | 0%                          | \$0.00           | \$0.00          | \$0.00            |            |                 |
| <b>C</b> | <b>Category (c): Planning/Design/Engineering/Environmental Documentation</b> |  |   |                             |                  |                 |                   |            |                 |
| 1        | Design / Plans   | Perform preliminary calculations for pipeline requirements, power requirements   | Preliminary power requirements  | 40%                         | \$2,400.00       | \$0.00          | \$2,400.00        | 1/1/20     | 1/7/20          |
| 2        | Design / Plans   | Develop preliminary plans for pipeline replacement and connection to Long 20 well  | Preliminary design plans  | 20%                         | \$2,000.00       | \$0.00          | \$2,000.00        | 1/8/19     |                 |
| 3        | Design / Plans   | Develop 90% plans for pipeline replacement and connection to Long 20 well  | 90% design plans  |                             | \$16,000.00      | \$0.00          | \$16,000.00       | 1/15/20    | 1/31/20         |
| 4        | Environmental Documentation: CEQA *  |  |   | 0%                          | \$10,000.00      | \$0.00          | \$10,000.00       | 1/1/20     | 4/30/20         |
| 5        | Permit Development:  | Obtain Regional Water Board: 401 Certification   | Regional Water Board 401 Certification                                    | 0%                          | \$1,600.00       | \$0.00          | \$1,600.00        | 2/1/20     | 5/31/20         |
| 6        | Permit Development:  | Obtain US Army Corps of Engineers: 404 Certification   | US Army Corps of Engineers 404 Certification                              | 0%                          | \$1,600.00       | \$0.00          | \$1,600.00        | 2/1/20     | 5/31/20         |
| 7        |  | Obtain PG&E service for Long 20 well and upgrade for Elias Replacement well  |   | 0%                          | \$35,000.00      | \$0.00          | \$35,000.00       | 2/1/20     | 6/30/20         |
| 8        | Design / Plans   | Perform final calculations for pipeline requirements   | Final expected water flows, power requirements                            | 0%                          | \$900.00         | \$0.00          | \$900.00          | 4/1/20     | 4/15/20         |
| 9        | Design / Plans   | Develop final plans for pipeline replacement and connection to Long 20 well  | Final design plans  | 0%                          | \$6,000.00       | \$0.00          | \$6,000.00        | 5/16/20    | 5/31/20         |
| 10       | Design / Plans   | Prepare bid packages for installation of pump, etc. for Elias Replacement well, moving Elias Replacement well pump, etc. to Long 20 well, replacement of 6" pipeline   |   | 0%                          | \$5,000.00       | \$0.00          | \$5,000.00        | 4/1/20     | 5/31/20         |
|          |  |  |   |                             |                  |                 |                   |            |                 |
| <b>D</b> | <b>Category (d): Construction/Implementation</b>                             |  |   |                             |                  |                 |                   |            |                 |
| 1        | Construction/Implementation Contracting                                      |  |   | 0%                          | \$3,200.00       | \$0.00          | \$3,200.00        | 5/1/20     | 5/30/20         |
| 2        | Mobilization and Site Preparation  |  |   | 0%                          | \$81,800.00      | \$0.00          | \$81,800.00       | 6/1/20     | 6/1/20          |
| 3        | Project Construction/Implementation:   | Install new pump in Elias Replacement well, with VFD and controls  |   | 0%                          | \$150,000.00     | \$0.00          | \$150,000.00      | 7/1/20     | 9/30/20         |

**Project Name:** Improving Willits Water Supply Reliability and Drought Resiliency with Groundwater and Conjunctive Use  
**Organization Name:** City of Willits

| Task #   | Major Tasks                                    | Task Description   | Major Deliverables   | Current Stage of Completion | IRWM Task Budget      | Non-State Match | Total Task Budget     | Start Date | Completion Date |
|--|--|--|--|-----------------------------|-----------------------|-----------------|-----------------------|------------|-----------------|
| 4  | Project Construction/Implementation:           | Move Elias Replacement well pump, VFD, controls and install in the Long 20 well. (removal, re-installation, security fencing, electrical and other miscellaneous ancillary facilities)   |  | 0%                          | \$120,000.00          | \$0.00          | \$120,000.00          | 8/1/20     | 9/30/20         |
| 5  | Project Construction/Implementation:           | Install 8" replacement pipe from the Elias Replacement well to the junction with existing 8" pipeline. (Assuming 8" C900 PVC at \$150/ft installed * 3650 ft)  |  | 0%                          | \$548,000.00          | \$0.00          | \$548,000.00          | 7/1/20     | 9/30/20         |
| 6  | Project Construction/Implementation:           | Install PG&E service connection at Long 20 test well, and upgrade connection at Elias Replacement well.  |  | 0%                          | \$50,000.00           | \$0.00          | \$50,000.00           | 7/1/20     | 8/31/20         |
| 7  | Pilot Testing                                  | Conduct pilot tests to determine the current groundwater treatments plant's capacity to remove arsenic from the Long 20 well.  |  |                             | \$8,000.00            |                 | \$8,000.00            | 4/1/21     | 6/1/21          |
| 8  | Project Signage                                |  |  | 0%                          | \$500.00              | \$0.00          | \$500.00              | 6/1/20     | 6/30/20         |
| 9  | Project Close Out, Inspection & Demobilization | Inspect project components and establish that work is complete. Verify that all project components have been installed and are functioning as specified will be conducted as part of construction inspection and project closeout. Conduct project completion photo monitoring. Prepare record drawings. | As-Built and Record Drawings; Project completion site photos   | 0%                          | \$4,140.00            | \$0.00          | \$4,140.00            | 6/30/21    | 12/31/21        |
| 10   | Project Performance Monitoring                 | The performance of the project will be monitored in accordance to the Monitoring Plan using the following measurement tools and methods:   | The project objectives will be monitored in accordance with the Monitoring Plan using project milestones and target dates. Data will be incorporated in Quarterly and Final Reports. | 0%                          | \$4,080.00            | \$0.00          | \$4,080.00            | 6/1/20     | 11/30/21        |
| 11   | Construction Administration                    | Complete tasks necessary to administer construction contract. Keep daily records of construction activities, inspection, and progress. Conduct project construction photo-monitoring.  | Construction Management Logs; Completed construction administration tasks documented in monthly progress reports   | 0%                          | \$35,992.00           | \$0.00          | \$35,992.00           | 5/1/20     | 12/31/21        |
| <b>Total North Coast Resource Partnership 2018/19 IRWM Grant Request</b>   |  |  |  |                             | <b>\$1,102,312.00</b> | <b>\$0.00</b>   | <b>\$1,102,312.00</b> |            |                 |
| <b>Is Requested Budget scalable by 25%? If yes, indicate scaled totals; if no delete budget amount provided.</b> |  |  |  |                             |                       |                 |                       |            |                 |
| <b>Is Requested Budget scalable by 50%? If yes, indicate scaled totals; if no delete budget amount provided.</b> |  |  |  |                             |                       |                 |                       |            |                 |

# **WATER SUPPLY PLANNING STUDY**

**Prepared For  
City of Willits**

**February 2006**



Consulting Engineers

706-04-04-02

# TABLE OF CONTENTS

|  |             |
|--|-------------|
| <b>EXECUTIVE SUMMARY.....</b>  | <b>ES-1</b> |
| <b>1. INTRODUCTION.....</b>  | <b>1-1</b>  |
| <b>2. WATER DEMANDS .....</b>  | <b>2-1</b>  |
| HISTORICAL WATER PRODUCTION .....                                    | 2-1         |
| CURRENT WATER DEMANDS .....  | 2-3         |
| Significant Water Users .....  | 2-4         |
| CURRENT LAND USE .....   | 2-7         |
| POPULATION.....  | 2-8         |
| UNIT WATER DEMANDS .....   | 2-10        |
| Population Based Water Demand .....                                  | 2-13        |
| Land Use Based Water Demand .....                                    | 2-13        |
| PROJECTED WATER DEMANDS .....  | 2-13        |
| Population Based Demand Projections .....                            | 2-13        |
| Land Use Based Demand Projections .....                              | 2-16        |
| Comparison of Population and Land Use Based Demand Projections ..... | 2-16        |
| DEMAND MANAGEMENT MEASURES .....                                     | 2-19        |
| SUMMARY AND RESULTS OF DEMAND MANAGEMENT .....                       | 2-25        |
| MONTHLY WATER SUPPLY REQUIREMENTS.....                               | 2-25        |
| <b>3. EXISTING WATER SUPPLY CAPACITY .....</b>                       | <b>3-1</b>  |
| WATER SUPPLY SIMULATIONS .....                                       | 3-1         |
| HYDROLOGY UPDATE.....  | 3-6         |
| <b>4. SUPPLEMENTAL SUPPLY REQUIREMENTS .....</b>                     | <b>4-1</b>  |
| <b>5. SUPPLEMENTAL SUPPLY ALTERNATIVES.....</b>                      | <b>5-1</b>  |
| ADDITIONAL SURFACE WATER SUPPLY .....                                | 5-1         |
| Raising or Replacing Morris Dam .....                                | 5-1         |
| Increasing Height of Morris Dam Flashboards .....                    | 5-2         |
| Dredging Morris Reservoir .....                                      | 5-2         |
| Building another Dam.....  | 5-3         |
| Gaining Access to Wente Lake .....                                   | 5-4         |
| NEIGHBORING WATER SYSTEM INTERCONNECTION .....                       | 5-6         |
| RECYCLED WATER SUPPLY .....  | 5-6         |
| GROUNDWATER SUPPLY .....   | 5-7         |
| Little Lake Valley Groundwater Basin .....                           | 5-7         |
| Park Well.....   | 5-8         |
| Groundwater Quality.....   | 5-8         |
| Proposed Groundwater Supply .....                                    | 5-10        |
| COMPARISON OF ALTERNATIVES .....                                     | 5-13        |

## 6. CONCLUSIONS AND RECOMMENDATIONS..... 6-1

### APPENDIX A. Detailed Model Description

### APPENDIX B. Development of Hydrology

### APPENDIX C. Model Validation

### APPENDIX D. Detailed Model Results

### APPENDIX E. Cost Estimates

## List of Tables

|   |      |
|---|------|
| Table ES-1. Supplemental Water Supply Requirements .....                  | ES-2 |
| Table 2-1. Historical Peaking Factors .....                               | 2-3  |
| Table 2-2. Top Water Users .....  | 2-7  |
| Table 2-3. Top 10 Percent of Water Customers.....                         | 2-7  |
| Table 2-4. Land Use Summary .....   | 2-8  |
| Table 2-5. Historical and Projected Population .....                      | 2-10 |
| Table 2-6. Projected Build-Out Population.....                            | 2-11 |
| Table 2-7. Historical Per Capita Unit Water Demands.....                  | 2-14 |
| Table 2-8. Land Use Water Demand Factors.....                             | 2-15 |
| Table 2-9. Population Based Demand Projections.....                       | 2-16 |
| Table 2-10. Land Use Based Demand Projections.....                        | 2-17 |
| Table 2-11. Current and Projected Customer Water Demands.....             | 2-19 |
| Table 2-12. Water Savings via Plumbing Retrofits .....                    | 2-20 |
| Table 2-13. Current Average Monthly Customer Water Demands .....          | 2-26 |
| Table 2-14. Current Water Supply Requirements.....                        | 2-27 |
| Table 2-15. Projected 2025 Water Supply Requirements.....                 | 2-27 |
| Table 4-1. Comparison of Water Demands and Existing Supply .....          | 4-1  |
| Table 4-2. Effects of Enforcing Ordinance 95-4.....                       | 4-2  |
| Table 4-3. Deficit Reductions by Enforcing Ordinance 95-4 .....           | 4-3  |
| Table 4-4. Supplemental Source Capacity Requirements.....                 | 4-4  |
| Table 4-5. Supplemental Production Capacity Requirements .....            | 4-4  |
| Table 4-6. Supplemental Source and Production Capacity Requirements ..... | 4-5  |
| Table 5-1. Park Well Water Quality .....                                  | 5-9  |
| Table 5-2. Comparison of Water Supply Alternatives.....                   | 5-14 |



|  |     |
|--|-----|
| Table 6-1. Supplemental Water Supply Requirements .....              | 6-1 |
| Table E-1. Estimated Cost of Expanding Morris Reservoir .....        | E-1 |
| Table E-2. Estimated Cost of Supplemental Surface Water Supply ..... | E-2 |
| Table E-3. Estimated Cost of Groundwater Supply – Phase 1 .....      | E-3 |
| Table E-4. Estimated Cost of Groundwater Supply – Phase 2 .....      | E-4 |
| Table E-5. Estimated Cost of Groundwater Supply – Phase 3 .....      | E-4 |

## List of Figures

|   |      |
|---|------|
| Figure 2-1. Historical Flow Measurements.....   | 2-2  |
| Figure 2-2. Monthly Water Demands .....   | 2-5  |
| Figure 2-3. Annual Water Demands .....  | 2-6  |
| Figure 2-4. Land Use Diagram.....   | 2-9  |
| Figure 2-5. Historical and Projected Populations .....  | 2-12 |
| Figure 2-6. Land Use Based Water Demand Projections .....   | 2-18 |
| Figure 3-1. Watershed and Reservoirs .....  | 3-2  |
| Figure 3-2. Annual Delivery and Deficit with Current Demands .....  | 3-3  |
| Figure 3-3. Annual Delivery and Deficit with Projected 2025 Demands .....   | 3-4  |
| Figure 3-4. Probability of Delivery.....  | 3-4  |
| Figure 3-5. End-of-Month Storage and Deficit with Current Demands .....   | 3-5  |
| Figure 3-6. End-of-Month Storage and Deficit with Projected 2025 Demands .....  | 3-5  |
| Figure 3-7. Annual Delivery and Shortage with Projected 2025 Demands:<br>Regression with City Measurements .....      | 3-7  |
| Figure 3-8. End-of-Month Storage and Shortage with Projected 2025 Demands:<br>Regression with City Measurements ..... | 3-7  |
| Figure 3-9. Probability of Delivery.....  | 3-8  |
| Figure 5-1. Proposed Water Supply Contingency Plan .....  | 5-5  |
| Figure 5-2. Groundwater Supply Project – Phase 1 Conceptual Vicinity Map .....  | 5-12 |

# EXECUTIVE SUMMARY

The City of Willits (City) owns and operates the public water system and supplies potable water to residential, commercial, industrial and institutional customers within and outside the City limits. While the current City population is just over 5,000, potable water is supplied by the City to a total population of about 6,500. The existing water supply is surface water from the Davis Creek watershed, impounded by the Centennial and Morris Dams, and treated in a filtration plant.

The City retained the engineering consultant team of West Yost & Associates and MBK Engineers to analyze the City water demands and existing water supply capacity and to determine any need for a supplemental water supply. The commissioned Water Supply Planning Study included the following scope of study:

- Determination of current water demands
- Projection of future water demands
- Analysis of existing water supply capacity
- Determination of supplemental supply requirements
- Evaluation of supplemental supply alternatives
- Conclusions and recommendations

Population and land use methodologies were used to project the 2025 and build-out water demands for the City. The land use methodology was considered more accurate, and the land use based demand projections were used as a basis of planning for the remainder of the study. Demand management measures were determined to have significant potential to reduce water demands in the future, and estimates of demand reductions with implementation of these measures were incorporated into the projected 2025 water supply requirements.

Hydrological analysis and modeling of the Morris/Centennial Reservoir system revealed a current worst-case water supply deficit of 650 acre-feet per year (AF/year) and a projected 2025 worst-case deficit of 1,300 AF/year in critically dry years. Enforcement of Ordinance 95-4 during critically dry years would reduce but not eliminate the worst-case deficits. The supplemental water supply requirements are summarized in Table ES-1 in terms of million gallons per day (mgd).

The supplemental water supply alternatives for the City include:

- Additional surface water supply
- Neighboring water system interconnection
- Recycled water supply
- Groundwater supply

**Table ES-1. Supplemental Water Supply Requirements**

|                                | Without Enforcement<br>of Ordinance 95-4 | With Enforcement of<br>Ordinance 95-4<br>Stage I | With Enforcement of<br>Ordinance 95-4<br>Stage II |
|--------------------------------|--|--|---|
| Current Demands, mgd           | 0.9                                      | 0.8  | 0.6   |
| Projected 2025<br>Demands, mgd | 1.8                                      | 1.5  | 1.3   |

Several of the alternatives were deemed inadequate to satisfy the City's need for a supplemental water supply or were otherwise not feasible. The three feasible alternatives are: 1) expanding the capacity of Morris Reservoir, 2) building another dam elsewhere in the Little Lake Valley to expand the surface water supply, and 3) implementing a groundwater supply. The capital cost estimate for a supplemental or expanded surface water supply is \$18 to \$20 million while the capital cost estimate for a groundwater supply is \$7.0 million. In addition to the cost and other advantages of the groundwater supply alternative, it is feasible to implement the groundwater supply in phases to minimize the initial effect on rates. The principal downside of the groundwater supply alternative is that the long-term annual yield of the Little Lake Valley groundwater basin may limit the groundwater supply potential to accommodate City water system growth beyond 2025.

As a result of this Water Supply Planning Study, it is recommended that the City:

- Designate a Water Conservation Coordinator to develop, launch and manage a City water conservation program and oversee the implementation of demand management measures, as described in this report.
- Continue aggressively detecting and repairing leaks in the water distribution system and maintaining or replacing meters to reduce the unaccounted for water demand to 12 percent of the customer water demand.
- Determine whether to develop enough supplemental water supply capacity to avoid enforcement of Ordinance 95-4 in critically dry years.
- Continue to operate the lower outlet(s) of Morris Reservoir as necessary to scour the immediate bottom area and minimize future sedimentation, and work with the County to promote erosion control in the upper Davis Creek watershed.
- Pursue the use of Wente Lake as part of a water supply contingency plan, as described in this report.
- Provide treated wastewater to local area farmers to offset the agricultural demand for groundwater and increase the groundwater supply availability to the City.
- Incorporate the water supply needs of any future annexation into the capacity of a supplemental water supply project(s).
- Continue discussions with Brooktrails to determine the feasibility and potential advantages of participating in an expansion of the Brooktrails water supply capacity.

- Develop a groundwater supply as described in this report.
- Plan to expand Morris Reservoir and the surface water treatment plant in the future if annexations and growth projections require a greater water supply capacity than the existing surface water supply and proposed groundwater supply can support.

Implementation of the first phase of the groundwater supply project, as described in this report and depicted in Figure 5-2, will entail:

1. Evaluating environmental impacts, preparing necessary environmental documentation, and soliciting public comments for CEQA compliance.
2. Consulting with Department of Health Services (DHS), investigating potentially contaminating activities that might affect water quality, and adjusting proposed well locations and screening intervals as necessary.
3. Initiating detailed design of wells, pipelines and groundwater treatment plant, and securing easements as necessary.
4. Drilling wells, conducting pumping tests, collecting water quality data, and incorporating test results and water quality data into detailed design.
5. Finalizing design and amending domestic water supply permit from DHS.
6. Advertising project, evaluating and awarding construction contract, and administering contract through completion.
7. Commissioning facilities and training operators as regards groundwater supply operations and maintenance requirements.

The preliminary description of the groundwater supply project, found in this report, will serve as a rational foundation to pursue CEQA compliance and proceed into design.



# 1. INTRODUCTION

The City of Willits (City) is located in Mendocino County, about 140 miles north of San Francisco along Highway 101. The City owns and operates the public water system and supplies potable water to residential, commercial, industrial and institutional customers within and outside the City limits. While the current City population is just over 5,000, potable water is supplied by the City to a total population of about 6,500. Population growth is anticipated to increase the demand for potable water.

The primary source of supply is surface water from the Davis Creek watershed, impounded by the Centennial and Morris Dams and treated in a filtration plant that was built in the late 1980s. Raw water from Morris Reservoir is pumped into the filtration plant, and filtered water is delivered by gravity into a clearwell. Potable water from the clearwell is delivered by gravity through a transmission main into the City water distribution system, which comprises eight pressure zones at various elevations and includes four storage reservoirs.

The existing water supply and treatment system is not adequate to meet the City water system demands under all demand and hydrologic conditions. The Centennial and Morris Reservoirs periodically draw down to very low levels, and the distribution system storage capacity is frequently drafted to meet maximum day demands. In contrast, an adequate and reliable water supply system would have adequate capacity to meet average and maximum day demands under all anticipated demand and hydrologic conditions.

The City retained the engineering consultant team of West Yost & Associates and MBK Engineers to address the water supply needs. The commissioned Water Supply Planning Study included the following scope of study:

- Determination of current water demands
- Projection of future water demands
- Analysis of existing water supply capacity
- Determination of supplemental water supply requirements
- Evaluation of supplemental water supply alternatives
- Conclusions and recommendations

The purpose of this report is to document the analysis, findings and recommendations of the Water Supply Planning Study.

## 2. WATER DEMANDS

An analysis of the current water demands and a projection of the future water demands is a necessary first step in determining the water supply requirements for the City. Therefore, a metered water use and land use database was developed to characterize water uses inside and outside the City limits. The resultant database was analyzed to develop unit water demands for each customer classification and projections of future demands in 2025 and at build-out. The build-out projection integrated the City's updated General Plan for the remaining undeveloped areas. The water demand analysis and findings are documented in this section.

The City provided the following data for the water demand analysis:

- Annual water production and maximum day demand for 1994-2002
- Monthly customer metering data for August 2002-July 2004
- Monthly data from the production, system and customer meters for 1983-2003
- City of Willits 2003-2008 Housing Element
- Willits General Plan, Vision 2020, Adopted August 12, 1992
- City of Willits Zoning Map adopted January 1988 and corresponding electronic file dated September 4, 2003
- Aerial photograph of the City dated July 12, 1993


### HISTORICAL WATER PRODUCTION

Annual metering data from the production (raw water), system (finished water), and customer (total sales) meters are summarized in Figure 2-1. The production meter measures the flow of raw water entering the water treatment plant from the pump station at Morris Dam. The finished water meter measures the flow downstream of the finished water storage tank (i.e., clearwell) at the plant. Total sales are determined by the customer meter readings taken at the service connections within the water distribution system inside and outside the City limits.

The finished water production volume is normally less than the raw water volume because some of the raw water is used to flush the clarifiers, and some of the finished water is used to backwash the filters, operate the chemical systems, and supply potable water for housekeeping and sanitary purposes within the plant. Total sales are typically lower than the finished water flow due to distribution system leakage and other components of unaccounted for (UAF) water demand. However, the recorded finished water flow was greater than the recorded raw water flow in three of the fourteen years, as presented in Figure 2-1. Because more water cannot leave the water treatment plant than enters the plant, these anomalies are likely due to metering errors. The City recognized this issue and replaced the raw and finished water flow meters in 2004. Further analysis of the UAF water demand is discussed later in this Section 2.

The total sales volume has increased by approximately 20 percent over the 15-year period from 1985 to 2000, averaging a 1.2 percent increase per year.

Figure 2-1. City of Willits  
Historical Flow Measurements



The available finished water meter data were used to assess peaking factors, which are summarized in Table 2-1. The highest maximum day demand occurred on July 19, 1998 resulting in maximum month/average day and maximum day/average day peaking factors of 1.37 and 1.97, respectively. Maximum day peaking factors increased until 1998, declined through 2001, and then increased again in 2002.

**Table 2-1. Historical Peaking Factors**

|         | Average Day, mgd | Maximum Month, mgd | Maximum Day, mgd | Maximum Day, date | Peaking Factors <sup>(a)</sup> |             |
|---------|------------------|--------------------|------------------|-------------------|--------------------------------|-------------|
|         |                  |                    |                  |                   | Maximum Month                  | Maximum Day |
| 1994    | 1.13             | 1.56               | 1.91             | July 19           | 1.39                           | 1.69        |
| 1995    | 1.04             | 1.41               | 1.76             | August 16         | 1.36                           | 1.69        |
| 1996    | 1.12             | 1.59               | —                | —                 | —                              | —           |
| 1997    | 1.22             | 1.57               | 1.82             | August 6          | 1.29                           | 1.49        |
| 1998    | 1.46             | 1.99               | 2.87             | July 19           | 1.37                           | 1.97        |
| 1999    | 1.33             | 1.80               | 2.55             | July 15           | 1.36                           | 1.92        |
| 2000    | 1.29             | 1.87               | 2.24             | June 16           | 1.45                           | 1.74        |
| 2001    | 1.27             | 1.68               | 1.98             | August 17         | 1.32                           | 1.56        |
| 2002    | 1.18             | 1.74               | 2.19             | July 30           | 1.47                           | 1.85        |
| Average | 1.22             | 1.69               | 2.16             | —                 | 1.38                           | 1.74        |
| Max     | 1.46             | 1.99               | 2.87             | —                 | 1.47                           | 1.97        |
| Min     | 1.04             | 1.41               | 1.76             | —                 | 1.29                           | 1.49        |

<sup>(a)</sup> As a function of average day demand

Rounding the maximum factors in Table 2-1, 1.5 is the recommended maximum month peaking factor and 2.0 is the recommended maximum day peaking factor for the demand projections and other planning purposes. While these peaking factors are similar to experiences elsewhere in California, the City should reevaluate the peaking factors when more data are available from the new finished water meter.

## CURRENT WATER DEMANDS

Current water demands are based on monthly customer metering data provided by the City from August 2002 through July 2004. The customer database includes meter readings inside and outside the City limits divided into the following customer types:

- Administrative Offices
- Commercial
  - Community Commercial
  - Heavy Commercial



- Industrial
  - Industrial Park
  - Heavy Industrial
  - Limited Industrial
- Public Facility
- Residential
  - Single Family Residence
  - Residential Medium Density
  - Multiple Residence
  - Residential Estate
- Unclassified (mostly rural residential)

Current monthly water demands by customer type inside and outside the City limits are presented graphically in Figure 2-2 and range from 46 to 113 acre-feet (AF) for the period of record. Minimum water demands typically occur in January or February, and maximum water demands typically occur in July and August, as is typical for municipal water systems.

Annual average water demand data are presented in Figure 2-3 by customer type inside and outside the City limits. Approximately 689 acre-feet per year (AF/year) or 78 percent of the current water demand occurs within the City limits. Over half of that is residential water use (368 AF/year) followed by commercial use (211 AF/year). Outside the City limits, the unclassified customers have the greatest water demand of approximately 162 AF/year, which is 82 percent of the total, followed by a residential water demand of 33 AF/year.


### **Significant Water Users**

The total number of customer connections inside and outside the City limits is approximately 2,245, resulting in an annual average water demand of 886 AF/year. Data for the top 10 percent (225) and the top 10 water users inside and outside the City limits are highlighted in Table 2-2. The top 10 percent of water users inside and outside the City limits comprise approximately half of the City's metered demand. The top 10 connections (0.4 percent of total) comprise approximately 13 percent of the total metered demand.


The top 10 percent of water users are characterized in Table 2-3 by customer type. Of the top 10 percent, the largest are commercial water users at approximately 32 percent of the total water use. The next largest are residential water users at approximately 29 percent of the total water use. The largest users outside of the City limits are unclassified. Comparing the percentage of connections to the percentage of water use, a proportionate share of the water use by customer type is apparent for the top 10 percent of users, comprising 50 percent of the metered demand.

The top 10 water users, including a mobile home park, a high school, and a heavy industrial customer inside the City limits, comprised approximately 111 AF/year per year or 13 percent of the total metered demand. Four of the top 10 users are unclassified and located outside the City limits, and used approximately 41 AF/year or 37 percent of the top 10 user demand.

Figure 2-2. City of Willits  
Monthly Water Demands



**Figure 2-3. City of Willits  
Annual Water Demands**



**Table 2-2. Top Water Users**

|  | All<br>Connections | Top 10<br>Percent of<br>Connections | Top 10<br>Connections |
|--|--------------------|-------------------------------------|-----------------------|
| Number of Connections                              | 2,245              | 225                                 | 10                    |
| Percent of Total Connections                       | 100                | 10                                  | 0.4                   |
| Annual Water Use, AF/year                          | 886                | 440                                 | 111                   |
| Percent of Total Annual Water Use                  | 100                | 50                                  | 13                    |
| Quantity Delivered Inside City Limits,<br>AF/year  | 689                | 354                                 | 70                    |
| Quantity Delivered Outside City Limits,<br>AF/year | 197                | 86                                  | 41                    |

**Table 2-3. Top 10 Percent of Water Customers**

| Customer Type         | Number of<br>Connections | Percentage of<br>Number of<br>Connections <sup>(a)</sup> | Average<br>Annual Water<br>Use, AF/year | Percentage of<br>Water Use <sup>(a)</sup> |
|-----------------------|--------------------------|--|---|---|
| Administrative Office | 6                        | 3  | 7                                       | 2   |
| Commercial            | 75                       | 33   | 142                                     | 32  |
| Industrial            | 16                       | 7  | 39                                      | 9   |
| Public Facilities     | 15                       | 7  | 39                                      | 9   |
| Residential           | 71                       | 32   | 128                                     | 29  |
| Outside, unclassified | 42                       | 19   | 86                                      | 19  |
| Total                 | 225                      | 100  | 440                                     | 100                                       |

<sup>(a)</sup> Percentage of top 10 percent of customers

## CURRENT LAND USE

Land use areas were calculated from the City zoning map that was adopted in January 1988, but using an electronic (AutoCAD) version of the zoning map dated September 4, 2003. The land use areas from the Vision 2020 Willits General Plan Revision and as calculated from the City zoning map are summarized in Table 2-4.

Some land use area discrepancies are apparent in Table 2-4, potentially resulting from land use adjustments by the City in preparing the General Plan and the zoning map at different times. The difference in total land use area may pertain to City-owned land located outside of the City zoning map such as the airport and water treatment plant. The land use areas in this report are based on the zoning map.



The approximate developed areas of administrative offices, commercial, industrial and public facilities were estimated by overlaying the land use map and the aerial photograph as shown in Figure 2-4. A significant amount of land is available for growth in all categories except commercial, which is 85 percent built out as presented in Table 2-4.

**Table 2-4. Land Use Summary**

| Description               | General Plan <sup>(a)</sup> , acres | Zoning Map <sup>(b)</sup> , acres | Difference, acres | Estimated Developed Area <sup>(c)</sup> , acres | Estimated Developed Area, percent <sup>(d)</sup> |
|---------------------------|-------------------------------------|-----------------------------------|-------------------|---|--|
| <b>Inside City Limits</b> |                                     |                                   |                   |   |  |
| Residential               | 650                                 | 688                               | 38.4              | 323   | 47   |
| Industrial                | 646                                 | 580                               | -66.4             | 172   | 30   |
| Commercial                | 241                                 | 241                               | 0.3               | 204   | 85   |
| Public Facilities         | 174                                 | 150                               | -24.4             | 66  | 45   |
| Open Space                | 35                                  | 33                                | -1.7              | —   | —  |
| <b>Total</b>              | <b>1,746</b>                        | <b>1,692</b>                      | <b>-53.8</b>      | <b>—</b>  | <b>—</b>   |

<sup>(a)</sup> From Vision 2020 Willits General Plan Revision

<sup>(b)</sup> As calculated using electronic version of City zoning map

<sup>(c)</sup> Estimated using overlay of land use map and aerial photograph

<sup>(d)</sup> Estimated developed area divided by zoning map area

## POPULATION

Historical and projected populations for the City were obtained from the 2003-2008 Housing Element as summarized in Table 2-5. The Housing Element used census reports, the State Department of Finance, Mendocino Council of Governments, and various City documents to determine the historical population and to project the future population. From 1980 to 1990, the City experienced an average annual growth rate of 2.5 percent. From 1990 to 2000 the City experienced an average annual growth rate of 0.1 percent. The 2000 census reported a City population of 5,073 people with an average of 2.56 persons per residence.

According to the Housing Element, the annual growth rate from 2000 to 2020 is projected to range from 1.1 to 2.6 percent, with an average annual growth rate of 1.66 percent over the 20-year period. Since the Housing Element stopped at 2020, the average annual growth rate of 1.66 percent was applied to estimate the 2025 and build-out populations of the City.

**Table 2-5. Historical and Projected Population**

| Year | Population <sup>(a)</sup> | Change | Percent Change | Annual Percent Change <sup>(b)</sup> |
|------|---------------------------|--------|----------------|--------------------------------------|
| 1980 | 4,008                     | —      | —              | —                                    |
| 1990 | 5,027                     | 1,019  | 25.4           | 2.5                                  |
| 2000 | 5,073                     | 46     | 0.9            | 0.1                                  |
| 2005 | 5,732                     | 659    | 13.0           | 2.6                                  |
| 2008 | 5,930                     | 198    | 3.5            | 1.2                                  |
| 2010 | 6,062                     | 132    | 2.2            | 1.1                                  |
| 2020 | 7,050                     | 988    | 16.3           | 1.6                                  |

<sup>(a)</sup> Population is projected after 2000

<sup>(b)</sup> Based on Housing Element population projections, and averaged in each 2 to 10-year increment

The build-out population was calculated using the residential areas in the zoning map, land use densities from the Housing Element, and the average occupancy of 2.56 persons per residence. The Housing Element reported both maximum allowable and typical land use densities. The resulting population projections for single family, medium density, multiple family, and residential estate residences are summarized in Table 2-6. The estimated total City population at build-out ranges from 13,058 to 16,019 people. Depending on actual density, build-out is estimated to occur between 2057 and 2070 as shown in Figure 2-5. The projected 2025 population is approximately 7,654 persons with an average annual growth rate of 1.66 percent.

## UNIT WATER DEMANDS

Unit water demands were calculated as a function of population and land use. To calculate the population based unit water demand, the total water demand was divided by the total population. Population based unit water demands are typically expressed in gallons per capita (person) per day (gpcd) or AF per person per year (AF/person/year). Projected water demands are calculated by multiplying the projected population by the estimated unit water demand, which is assumed to remain constant in the projection. Because development of the various land-use areas (residential and non-residential) could proceed at different rates and thereby change the unit water demands, projecting community water demands on a population basis carries an inherent risk of inaccuracy. Nevertheless, population based water demand projections can provide a reasonable comparison to land use based projections.

**Table 2-6. Projected Build-Out Population**

| Land Use Code | Description                | Density, units per acre <sup>(a)</sup> |         | Land Use Area <sup>(c)</sup> , acres | Projected Number of Units |         | Persons per Household <sup>(d)</sup> | Projected Population, persons |         |
|---------------|----------------------------|--|---------|--------------------------------------|---------------------------|---------|--------------------------------------|-------------------------------|---------|
|               |                            | Typical <sup>(b)</sup>                 | Maximum |                                      | Typical                   | Maximum |                                      | Typical                       | Maximum |
| R1            | Single Family Residence    | 7                                      | 7.26    | 365                                  | 2,555                     | 2,650   | 2.56                                 | 6,541                         | 6,784   |
| R2            | Residential Medium Density | 14                                     | 14.52   | 70                                   | 986                       | 1,022   | 2.56                                 | 2,523                         | 2,617   |
| R3            | Multiple Residence         | 18                                     | 29.04   | 77                                   | 1,384                     | 2,233   | 2.56                                 | 3,544                         | 5,717   |
| RE            | Residential Estate         | 1                                      | 2       | 176                                  | 176                       | 352     | 2.56                                 | 451                           | 902     |
| Total         |                            | —                                      | —       | 688                                  | 5,101                     | 6,257   | —                                    | 13,058                        | 16,019  |


<sup>(a)</sup> Based on General Plan

<sup>(b)</sup> Based on historical densities

<sup>(c)</sup> Calculated/measured from land use map

<sup>(d)</sup> Average from 2000 Census

**Figure 2-5. City of Willits  
Historical and Projected Populations**





The land use methodology takes into account the potential for the various land use areas to develop at different rates, and demands are calculated by dividing the current water demand by the developed area for each land use type to obtain a unit water demand, typically expressed in AF per year per acre (AF/year/acre), or AF per year per residential unit (AF/year/unit). Water demands are then projected by multiplying the total build-out area for each land use type by the estimated unit water demand in AF/year/acre or multiplying the number of residential units at build-out by the estimated unit water demand in AF/year/unit.

Both population and land use based projections were developed in this study, and the results were compared to formulate a water demand projection.

### **Population Based Water Demand**

The population based water demands, as determined from total sales data and the reported population of the City, are summarized in Table 2-7. The annual per capita water demand from 1985 to 2000 ranged from 146 to 168 gpcd and averaged 154 gpcd. The annual average per capita water demand increased in 1999/2000 to approximately 168 gpcd or 0.19 AF/person/year using the actual 2000 census population.

Because the maximum unit water demand of 0.19 AF/person/year occurred in 2000, which was a census year, a unit demand of 0.19 AF/person/year or 170 gpcd was used to project future water demands in this study.

### **Land Use Based Water Demand**

Historical and estimated unit water demands for each land use type inside and outside the City limits are presented in Table 2-8. Residential unit water demands are based on the annual customer meter readings divided by the number of services or connections. Commercial, industrial, and public facility unit water demands are based on the annual customer meter readings divided by the respective estimated developed areas from Table 2-4.

The current unit water demands were rounded up and used as the estimated future unit water demands as presented in Table 2-8.

## **PROJECTED WATER DEMANDS**

Water demands were projected to 2025 and build-out using both the population and the land use methodologies. The build-out projections are based on the zoning map and General Plan, and not influenced by the water supply and other growth limitations.

### **Population Based Demand Projections**

The population projections in 2025 and at build-out with typical and maximum residential land use densities were multiplied by the unit water demand as summarized in Table 2-9. The projected 2025 customer water demand of approximately 1,460 AF/year is 65 percent greater than the current customer water demand.

**Table 2-7. Historical Per Capita Unit Water Demands**

| Year    | Population <sup>(a)</sup> | Total Sales <sup>(b)</sup> ,<br>AF/year | Unit Water Demand  |      |
|---------|---------------------------|---|--------------------|------|
|         |                           |   | AF/person/<br>year | gpcd |
| 1980    | 4,008                     | —                                       | —                  | —    |
| 1981    | 4,110                     | —                                       | —                  | —    |
| 1982    | 4,212                     | —                                       | —                  | —    |
| 1983    | 4,314                     | —                                       | —                  | —    |
| 1984    | 4,416                     | —                                       | —                  | —    |
| 1985    | 4,518                     | 767                                     | 0.17               | 151  |
| 1986    | 4,619                     | 774                                     | 0.17               | 150  |
| 1987    | 4,721                     | 847                                     | 0.18               | 160  |
| 1988    | 4,823                     | 788                                     | 0.16               | 146  |
| 1989    | 4,925                     | 854                                     | 0.17               | 155  |
| 1990    | 5,027                     | 894                                     | 0.18               | 159  |
| 1991    | 5,032                     | 872                                     | 0.17               | 155  |
| 1992    | 5,036                     | 829                                     | 0.16               | 147  |
| 1993    | 5,041                     | 839                                     | 0.17               | 149  |
| 1994    | 5,045                     | 824                                     | 0.16               | 146  |
| 1995    | 5,050                     | 838                                     | 0.17               | 148  |
| 1996    | 5,055                     | 909                                     | 0.18               | 160  |
| 1997    | 5,059                     | 855                                     | 0.17               | 151  |
| 1998    | 5,064                     | 860                                     | 0.17               | 151  |
| 1999    | 5,068                     | 943                                     | 0.19               | 166  |
| 2000    | 5,073                     | 954                                     | 0.19               | 168  |
| Minimum | 4,518                     | 767                                     | 0.16               | 146  |
| Maximum | 5,073                     | 954                                     | 0.19               | 168  |
| Average | 4,947                     | 853                                     | 0.17               | 154  |

<sup>(a)</sup> Interpolated population from Housing Element

<sup>(b)</sup> From customer meter data

The projected customer water demand at build-out ranges from 2,490 to 3,050 AF/year depending on the residential land use density, which may continue at its historical value or reach the maximum allowable density. The build-out water demand is anticipated to occur between 2057 and 2070 and represents a significant increase from the City's current customer water demand of 886 AF/year. Such an increase in demand may appear unrealistic, but it is consistent with the General Plan, the Housing Element and other available planning documents.

**Table 2-8. Land Use Water Demand Factors**

|                     | Land Use Code | Description                | Annual Demand, AF/year <sup>(a)</sup> | Number of Services <sup>(a)</sup> | Approximate Developed Area, acre <sup>(b)(c)</sup> | Current Unit Water Demands |               | Estimated Future Unit Water Demands <sup>(d)</sup> |               |
|---------------------|---------------|----------------------------|---------------------------------------|-----------------------------------|--|----------------------------|---------------|--|---------------|
|                     |               |                            |                                       |                                   |  | AF/year /unit              | AF/year /acre | AF/year /unit                                      | AF/year /acre |
| Inside City Limits  | C0            | Administrative Offices     | 13                                    | 29                                | 5  | —                          | 2.5           | —  | 2.5           |
|                     | C1            | Community                  | 134                                   | 345                               | 115  | —                          | 1.2           | —  | 1.5           |
|                     | C2            | Heavy Commercial           | 77                                    | 74                                | 84   | —                          | 0.9           | —  | 1.0           |
|                     | IP            | Industrial Park            | 3                                     | 9                                 | —  | —                          | —             | —  | 1.0           |
|                     | MH            | Heavy Industrial           | 44                                    | 69                                | 158  | —                          | 0.3           | —  | 0.5           |
|                     | ML            | Limited Industrial         | 9                                     | 29                                | 14   | —                          | 0.7           | —  | 1.0           |
|                     | PF            | Public Facility            | 40                                    | 41                                | 66   | —                          | 0.6           | —  | 1.0           |
|                     | R1            | Single Family              | 226                                   | 848                               | —  | 0.27                       | —             | 0.28   | —             |
|                     | R2            | Residential Medium         | 35                                    | 63                                | —  | 0.55                       | —             | 0.56   | —             |
|                     | R3            | Multiple Residence         | 97                                    | 204                               | —  | 0.47                       | —             | 0.48   | —             |
|                     | RE            | Residential Estate         | 10                                    | 33                                | —  | 0.32                       | —             | 0.34   | —             |
|                     | I             | Inside City, unclassified  | 0                                     | —                                 | —  | —                          | —             | —  | —             |
|                     |               | Total Inside               | 689                                   | 1,744                             | —  | 0.40                       | —             | —  | —             |
| Outside City Limits | C0            | Administrative Offices     | 0.3                                   | 1                                 | —  | 0.3                        | —             | 0.3  | —             |
|                     | C1            | Community                  | 2                                     | 2                                 | —  | 1.0                        | —             | 1.0  | —             |
|                     | C2            | Heavy Commercial           | —                                     | —                                 | —  | —                          | —             | —  | —             |
|                     | IP            | Industrial Park            | —                                     | —                                 | —  | —                          | —             | —  | —             |
|                     | MH            | Heavy Industrial           | 0.1                                   | 1                                 | —  | 0.1                        | —             | 0.1  | —             |
|                     | ML            | Limited Industrial         | —                                     | —                                 | —  | —                          | —             | —  | —             |
|                     | PF            | Public Facility            | 0.1                                   | 1                                 | —  | 0.1                        | —             | 0.1  | —             |
|                     | R1            | Single Family              | 31                                    | 136                               | —  | 0.2                        | —             | 0.2  | —             |
|                     | R2            | Residential Medium         | —                                     | —                                 | —  | —                          | —             | —  | —             |
|                     | R3            | Multiple Residence         | —                                     | —                                 | —  | —                          | —             | —  | —             |
|                     | RE            | Residential Estate         | 2.3                                   | 5                                 | —  | 0.5                        | —             | 0.5  | —             |
|                     | O             | Outside City, unclassified | 162                                   | 355                               | —  | 0.5                        | —             | 0.5  | —             |
|                     |               | Total Outside              | 197                                   | 501                               | —  | 0.39                       | —             | —  | —             |
|                     |               | Total Inside and Outside   | 886                                   | 2,245                             | —  | —                          | —             | —  | —             |

<sup>(a)</sup> Based on August 2003 – July 2004 customer meter readings

<sup>(b)</sup> Estimated in City from aerial photo dated July 12, 1993 and zoning map dated January 1998

<sup>(c)</sup> Indeterminate outside City limits

<sup>(d)</sup> Current values rounded upward for conservative projections

**Table 2-9. Population Based Demand Projections**

|                               | Population,<br>people | Unit Water<br>Demand,<br>AF/person<br>/year | Projected Water<br>Demand, AF/year |
|-------------------------------|-----------------------|---|------------------------------------|
| 2025                          | 7,654                 | 0.19  | 1,458                              |
| Build-out, Typical<br>Density | 13,058                | 0.19  | 2,488                              |
| Build-out, Maximum<br>Density | 16,019                | 0.19  | 3,052                              |

### **Land Use Based Demand Projections**

Residential water demands inside the City limits at build-out were projected at the typical and maximum allowable densities as defined in the Housing Element. The housing unit densities in Table 2-6 were multiplied by the number of acres in each residential zone to determine the maximum number of connections. As summarized in Table 2-10, the unit water demand was multiplied by the number of connections to estimate the residential water demand in the City of approximately 1,990 AF/year at typical density and 2,500 AF/year at maximum density.

Projected water demands for administrative offices, commercial, industrial, and public facilities were calculated by multiplying the unit water demand by the zoning map area for each land use. The total projected non-residential water demand is approximately 840 AF/year.

It was assumed that the City will continue to serve the current customers but will not add customers outside the City limits without an annexation(s). Since annexations are not planned at this time, the projected demand outside the City limits is the same as the current demand of approximately 200 AF/year. In considering any future annexation(s), the City should consider the additional water demand that will result from the annexation(s).

In round numbers, the build-out water demand ranges from 3,000 to 3,500 AF/year depending on the actual residential land use densities. Demand curves spanning from 2000 to the projected population build-out dates from Figure 2-5, assuming build-out for all land uses occur at the same time as residential build-out, are presented in Figure 2-6. Customer water demands in 2025 were interpolated from the curves and range from 1,525 to 1,580 AF/year for typical and maximum land use densities, respectively.

### **Comparison of Population and Land Use Based Demand Projections**


The projected 2025 water demand is approximately 1,458 AF/year (Table 2-9) using the population method and between 1,525 and 1,580 AF/year using the land use method for typical and maximum residential land use densities, respectively (Figure 2-6). While the population and land use projections for 2025 are not very different, the land use projections are somewhat higher and therefore, are used as the basis for the remainder of this study. The current demand and land use based demand projections are summarized in Table 2-11.



**Table 2-10. Land Use Based Demand Projections**

| Land Use Code | Description                | 2003-2008 Housing Element       |                                 | Zoning Map Area, acres | Typical No. of Connections | Max. No. of Connections | Estimated Future Unit Water Demands |              | Water Demand at Build-Out         |                                   |
|---------------|----------------------------|---------------------------------|---------------------------------|------------------------|----------------------------|-------------------------|-------------------------------------|--------------|-----------------------------------|-----------------------------------|
|               |                            | Typical Density, units per acre | Maximum Density, units per acre |                        |                            |                         | AF/year /unit                       | AF/year/acre | Based on Typical Density, AF/year | Based on Maximum Density, AF/year |
| C0            | Administrative Offices     | —                               | —                               | 15                     | —                          | —                       | —                                   | 2.5          | 38                                | 38                                |
| C1            | Community Commercial       | —                               | —                               | 142                    | —                          | —                       | —                                   | 1.5          | 213                               | 213                               |
| C2            | Heavy Commercial           | —                               | —                               | 84                     | —                          | —                       | —                                   | 1.0          | 84                                | 84                                |
| IP            | Industrial Park            | —                               | —                               | 99                     | —                          | —                       | —                                   | 1.0          | 99                                | 99                                |
| MH            | Heavy Industrial           | —                               | —                               | 445                    | —                          | —                       | —                                   | 0.5          | 223                               | 223                               |
| ML            | Limited Industrial         | —                               | —                               | 35                     | —                          | —                       | —                                   | 1.0          | 35                                | 35                                |
| PF            | Public Facility            | —                               | —                               | 150                    | —                          | —                       | —                                   | 1.0          | 150                               | 150                               |
| R1            | Single Family Residence    | 7                               | 7.26                            | 365                    | 2,555                      | 2,650                   | 0.28                                | —            | 716                               | 743                               |
| R2            | Residential Medium Density | 14                              | 14.52                           | 70                     | 986                        | 1,022                   | 0.56                                | —            | 552                               | 573                               |
| R3            | Multiple Residence         | 18                              | 29.04                           | 77                     | 1,384                      | 2,233                   | 0.48                                | —            | 659                               | 1,064                             |
| RE            | Residential Estate         | 1                               | 2                               | 176                    | 176                        | 352                     | 0.34                                | —            | 59                                | 118                               |
| OS            | Open Space                 | —                               | —                               | 33                     | —                          | —                       | —                                   | —            | —                                 | —                                 |
| O             | Outside city limits        | —                               | —                               | —                      | —                          | —                       | —                                   | —            | 197                               | 197                               |
| Total         |                            | —                               | —                               | 1,692                  | 5,101                      | 6,257                   | —                                   | —            | 3,026                             | 3,537                             |

**Figure 2-6. City of Willits  
Land Use Based Water Demand Projections**



**Table 2-11. Current and Projected Customer Water Demands(a)**

|         | Current Density        | Average Density        | Maximum Density        |
|---------|------------------------|------------------------|------------------------|
| Year    | Annual Demand, AF/year | Annual Demand, AF/year | Annual Demand, AF/year |
| Current | 886                    | —                      | —                      |
| 2025    | —                      | 1,525                  | 1,580                  |
| 2057    | —                      | 3,030                  | —                      |
| 2070    | —                      | —                      | 3,540                  |

(a) Does not include UAF water demand

## **DEMAND MANAGEMENT MEASURES**

The City already practices some degree of demand management (i.e. water conservation). Although the City is not a signatory to the California Urban Water Conservation Council (CUWCC) Memorandum of Understanding, the City has implemented some of the CUWCC Best Management Practices (BMPs), which are equivalent to the demand management measures (DMMs) in California Water code section 10631 subdivision (f). The City may consider implementing additional BMPs/DMMs, and the water supply savings potential of the additional BMPs/DMMs is estimated as a function of the projected 2025 customer water demand.

### **DMM 1 - Water Survey Program for Single and Multiple Family Residential Customers (CUWCC BMP 1)**

A water survey program for single and multiple family residential customers would entail directly contacting at least 20 percent of the City's residential customers via letter or telephone in each annual reporting period, arranging indoor and outdoor water use surveys, and identifying the associated water savings potential. The indoor and outdoor water use surveys would include:

- Checking for leaks in plumbing fixtures, including toilets, faucets and meters
- Checking showerhead and faucet aerator flow rates, and offering to replace or recommending replacement if flow rates are excessive
- Checking toilet flow rates, offering to install or recommending installation of displacement device, replacing leaky flapper, and advising customer of any available ultra-low flush toilet (ULFT) replacement program if flow rates are excessive
- Checking irrigation system controllers and making or recommending program adjustments if irrigation rates are excessive

Potential water savings from DMM1 are discussed after the presentation of DMM 2.

## **DMM 2 - Residential Plumbing Retrofit (CUWCC BMP 2)**

The City already requires the installation of water conserving fixtures in remodeled or newly constructed residential housing and applies credits to customer bills for customers who repair their own plumbing in the case of leaks. The CUWCC assumes the water savings indicated in Table 2-12 with implementation of residential plumbing retrofits.

The CUWCC also assumes that making or recommending adjustments to irrigation system controllers will result in a residential outdoor water use reduction of 10 percent.

**Table 2-12. Water Savings via Plumbing Retrofits**

|                               | Pre-1980 Construction | Post-1980 Construction |
|-------------------------------|-----------------------|------------------------|
| Low-flow showerhead retrofit  | 7.2 gpcd              | 2.9 gpcd               |
| Toilet retrofit (5-year life) | 1.3 gpcd              | 0.0 gpcd               |
| Leak repair                   | 0.5 gpcd              | 0.5 gpcd               |
| Total                         | 9.0 gpcd              | 3.4 gpcd               |

## **DDM 1 and DDM 2 Water Savings Estimate**

The City population was 4,008 in 1980, according to the Census Bureau, and the projected 2025 population is 7,654. The population outside the City limits that is served by City water is estimated as 1,270 based on the current 496 connections and an average of 2.56 people per connection. Assuming that 20 percent of the residential customers already have completed plumbing retrofits in the pre-1980 constructed houses and the resultant water savings were part of the customer water demand projections in Table 2-11, the additional water savings potential is approximately 53 AF/year in the remaining 80 percent of pre-1980 constructed houses. The estimated population increase from 1980 to 2025 is 3,646. Assuming the additional population currently lives or will live in post 1980 constructed houses with completed plumbing retrofits or equivalent, the additional water savings potential is approximately 14 AF/year.

The projected 2025 residential water demand is approximately 930 AF/year. Therefore, completing the outdoor water use surveys and making adjustments to irrigation system controllers equates to a water savings potential of 93 AF/year.

The total additional indoor and outdoor water savings potential with 100 percent implementation of DMMs 1 and 2, therefore, is approximately 160 AF/year. While 100 percent implementation is the ultimate goal for the City, the timeframe for implementation will depend on available funding and other factors. Therefore, the estimated additional water savings by 2025 are 48 AF/year assuming 30 percent additional participation over the course of 20 years, which is similar to the experience elsewhere in California.



### **DMM 3 - System Water Audits, Leak Detection and Repair (CUWCC BMP 3)**

The original water system was constructed in the 1920s. Since acquiring the water system in 1984, the City has implemented an active leak detection and pipeline repair program, investing approximately \$3.5 million in pipeline replacements. Through 2005, the City replaced about 26,400 feet of the approximately 170,000 feet of distribution system pipelines. Furthermore the City replaced about 6,200 feet of the 17,500-foot of transmission main in 1997 and another 4,000 feet in 2004-2005. The replaced segments of the original transmission main consisted of leak-prone riveted steel pipe.

Unaccounted for (UAF) water demand is the difference between the system meter data and the customer meter data. Initial estimates of UAF water demand were based on the system meter that was replaced in 2004 and suggested an UAF water demand of approximately 31 percent, meaning the volume measured at the customer meters was 69 percent of the volume measured at the system meter (i.e., exiting the clearwell). However, a reduced UAF water demand is evident since replacement of the system meter and more of the transmission main although not enough data are available at this time to conduct a statistical analysis. Consequently, an UAF water demand of approximately 24 percent of the customer demand, typical for older water systems, was assumed as the current condition.

A more accurate estimate of the UAF water demand is anticipated as more data are collected from the new finished water flow meter in the future. Through the City's leak detection, pipeline replacement, and customer meter replacement programs, the UAF water demand is anticipated to decline to 12 percent of the customer water demand by 2025. The volumetric reduction of UAF water demand by 2025 is estimated after factoring in the water savings from implementation of other DMMs.

### **DMM 4 - Metering with Commodity Rates for All New Connections and Retrofit of Existing Connections (CUWCC BMP 4)**

The CUWCC defines a commodity rate structure as a billing system in which water customers are charged by metered volume. The City already meters each customer account and applies commodity rates. The City bills monthly based on customer meter size and consumption using fixed and volumetric charges, respectively. For the volumetric charge, the City currently applies a uniform rate of \$2.30 per 100 cubic feet.

Although the CUWCC assumes a water demand reduction with implementation of commodity rates, additional demand reduction is not anticipated in the City because DMM 4 is already in place and was factored into the demand projections.

### **DMM 5 - Large Landscape Conservation Programs (CUWCC BMP 5)**

Typical large landscape conservation programs include installing separate irrigation meters, performing water use surveys, notifying customers of the start and end of the irrigation season, and promoting climate-appropriate landscapes. In some cases, financial incentives are offered to improve irrigation system efficiency including loans, rebates and grants for the purchase and/or installation of water efficient irrigation systems.

The CUWCC estimates a water savings of 15 percent with a large landscape conservation and incentive program for Commercial, Industrial and Institutional (CII) accounts. The CII accounts within the City are projected to use approximately 420 AF/year in 2025. Applying 15 percent, the water savings potential is approximately 63 AF/year. While 100 percent implementation is the ultimate goal for the City, the timeframe for implementation will depend on available funding and other factors. The estimated water savings by 2025 are 13 AF/year assuming 20 percent participation over the course of 20 years and recognizing that most of the CII customers in the City are industries without significant landscaping on their properties.

#### **DMM 6 - High Efficiency Washing Machine Rebate Programs (CUWCC BMP 6)**

The CUWCC estimates approximately 5,100 gallons per year of potential savings for each household that replaces a low efficiency clothes washer with a high efficiency clothes washer. For the projected 2025 population of 7,654 within the City and 1,270 outside the City limits and a density of 2.56 persons per household, the 3,486 residential customers could save 47 AF/year with 100 percent participation in DMM 6 assuming that all existing clothes washers are low efficiency. While 100 percent implementation is the ultimate goal for the City, the timeframe for implementation will depend on available funding and other factors. A water savings estimate of 5 AF/year is based on 10 percent participation by 2025 given the economic conditions in the City and the possibility that some existing clothes washers already are high efficiency.

Implementation of a light-wash commercial and multi-family housing coin-operated washing machine rebate program could provide additional savings potential, but insufficient data are available to estimate the benefits.

#### **DMM 7- Public Information Programs (CUWCC BMP 7)**

The CUWCC does not provide any particular water savings assumption for a public information program, but recommends implementation of such a program with the following elements:

- Promotion of water conservation and water conservation related benefits.
- Provision of a speaker(s) for employee and community groups and the media; paid and public service advertising; bill inserts; billing information that includes billing period usage compared to the previous year.
- Coordination with other government agencies, industry groups, public interest groups, and the media.

#### **DMM 8 - School Education Programs (CUWCC BMP 8)**

The CUWCC does not provide any particular water savings assumption for a school education programs, but recommends implementation of such a program with the following elements:

- Promotion of water conservation and water conservation related benefits.
- Coordination with the school district(s) and private schools in the water service area to provide instructional assistance, educational materials, and classroom presentations that identify urban, agricultural, and environmental issues and conditions in the local

watershed; distributed materials should meet state education requirements with grade-appropriate materials.

## **DMM 9 - Conservation Programs for Commercial, Industrial and Institutional Accounts (CUWCC BMP 9)**

The first step of DMM 9 is to identify and rank the following Commercial, Industrial and Institutional (CII) accounts according to water use:

- Commercial Accounts: Any water user that provides or distributes a product or service, such as hotels, restaurants, office buildings, commercial businesses or other places of commerce. Does not include multiple family residences, agricultural users, and customers that fall within the industrial or institutional classifications.
- Industrial Accounts: Any water user that primarily manufactures or processes materials as defined by the Standard Industrial Classifications (SIC) Codes 2000 through 3999.
- Institutional Accounts: Any water using establishment dedicated to public service including schools, courts, churches, hospitals, and government facilities. All facilities serving these functions are considered institutions regardless of ownership.

The next steps of DMM 9 are to accelerate the replacement of existing toilets with ULFTs and execute one of the following programs:

### CII Water Use Survey and Customer Incentives Program

- Implement a survey and incentives program similar to DMM 1 but tailored to CII water customers.
- Develop a customer targeting and marketing strategy to complete 10 percent of the CII water use surveys within 10 years of program commencement.
- Directly contact via letter, telephone or personal visit, and offer water use surveys and customer incentives to at least 10 percent of each CII account type on a recurring basis. Follow-up each customer survey, within one year, to review water use reductions and system improvements.

### CII Conservation Performance Targets

- Implement a program(s) equaling or exceeding the CII Conservation Performance Target to achieve annual water use savings of 10 percent of the baseline use (1997 or alternative year) by CII customers in the agency's service area over a 10-year period.

Water savings assumptions by the CUWCC are 12 percent and 15 percent for commercial and industrial water users, respectively. The CUWCC has not made similar assumptions for institutional accounts. The projected 2025 commercial and industrial water demands are 257 AF/year and 164 AF/year, respectively. Therefore, the potential savings are approximately 31 AF/year and 25 AF/year, respectively, with 100 percent participation in DMM 9. While



100 percent implementation is the ultimate goal for the City, the timeframe for implementation will depend on available funding and other factors. Therefore, the estimated water savings by 2025 are 16 AF/year for commercial users and 12 AF/year for industrial users assuming 50 percent participation over the course of 20 years, similar to the experience elsewhere in California.

#### **DMM 10 - Wholesale Agency Programs (CUWCC BMP 10)**

The City is a water retailer rather than a wholesaler, and therefore, DMM 10 is not applicable to the City water system.

#### **DMM 11 - Conservation Pricing (CUWCC BMP 11)**

Conservation pricing gives customers an incentive to reduce their average and/or peak water use. The City already has implemented one type of conservation pricing as described under DMM 4. The City recovers the cost of providing water service through its rates, and bills the water and sewer customers partly based on the metered water use. Nevertheless, the City is planning to conduct a rate study in the near future including the consideration of conservation pricing alternatives, which may include:

- Tiered rates for increments of water use (i.e., increasing block rates).
- Seasonal rates or surcharges to reduce peak demands during summer months.
- Rates that are based on the long run marginal cost or the cost of adding the next increment of capacity to the water system.

The effect of conservation pricing is indefinite because the CUWCC does not provide a water savings assumption for implementation of DMM 11, and the resultant water savings are not estimated in this study. Nevertheless, it is recognized that conservation pricing is consistent with the overall objective of a water conservation program.

#### **DMM 12 - Water Conservation Coordinator (CUWCC BMP 12)**

The CUWCC recommends the following responsibilities for a water conservation coordinator position:

- Coordination and oversight of City water conservation programs.
- Preparation and submission of DMM Implementation Report.
- Communication and promotion of water conservation issues to agency senior management; coordination of agency conservation programs with operations and planning staff; preparation of annual conservation budget; participation in the City Council including regular attendance at City Council meetings; and preparation of the conservation elements of the Urban Water Management Plan, if applicable.

Because the CUWCC does not provide any particular water savings assumption for the implementation of DMM 12, the resultant water savings are not estimated in this study.

## **DMM - 13 Water Waste Prohibition (CUWCC BMP 13)**

Water waste prohibitions under DMM 13 include:

- Gutter flooding.
- Single pass cooling systems in new connections.
- Non-recycling in new conveyer car wash and commercial laundry facilities.
- Non-recycling decorative water fountains.

In addition, DMM 13 includes the inspection of water softeners as part of a water audit program and the distribution of information about demand-initiated regenerating and exchange-type water softeners to promote replacement of timer models.

Because the CUWCC does not provide any particular water savings assumption for the implementation of DMM 13, the resultant water savings are not estimated in this study.

## **DMM - 14 Residential Ultra-Low Flush Toilet Replacement Programs (CUWCC BMP 14)**

The CUWCC estimates that approximately 43 gallons per day of savings are possible if two pre-1980 toilets are replaced with two ULFTs in a typical household with an average of 2.5 persons. While 100 percent implementation is the ultimate goal for the City, the timeframe for implementation will depend on available funding and other factors. Therefore, the estimated additional water savings by 2025 are 14 AF/year assuming 10 percent of the pre-1980 toilets in City residences are replaced with ULFTs over the course of 20 years, which is similar to the experience elsewhere in California.

## **SUMMARY AND RESULTS OF DEMAND MANAGEMENT**

Implementing DMMs 1, 2, 5 through 9, and 11 through 14 as described herein would result in an overall water savings of 108 AF/year by 2025. The City already has implemented DMMs 3 and 4, and DMM 10 is not applicable to the City. Additional savings are achievable as the City continues to pursue 100 percent participation in the DMMs in the future.

Subtracting the savings of 108 AF/year from the projected 2025 customer water demand of 1,580 AF/year results in a reduced demand of 1,472 AF/year. Then applying the UAF water demand goal of 12 percent to 1,472 AF/year results in a 2025 UAF water demand of 177 AF/year. Therefore, the continued implementation of DMM 3 will save an additional 177 AF/year compared to the 2025 condition with an UAF water demand of 24 percent. In other words, the UAF water demand will decline by 17 percent while the customer water demand increases by 78 percent from the current condition to 2025. The total water savings estimate of 285 AF/year by 2025, therefore, is almost 20 percent of the projected 2025 customer water demand.

## **MONTHLY WATER SUPPLY REQUIREMENTS**

Current and projected monthly water demands are used in the existing water supply analysis. The average monthly water demands for the period of August 2002 through July 2004 were calculated as a percentage of the annual demand, as presented in Table 2-13. As is typical for most

municipal water systems, the lowest customer water demand is experienced in February and the greatest customer water demand is experienced in July.

**Table 2-13. Current Average Monthly Customer Water Demands**

| Month    | Demand, AF | Percentage of Annual | Month     | Demand, AF | Percentage of Annual |
|----------|------------|----------------------|-----------|------------|----------------------|
| January  | 50.6       | 5.7                  | July      | 112.4      | 12.7                 |
| February | 48.6       | 5.5                  | August    | 104.5      | 11.8                 |
| March    | 54.3       | 6.1                  | September | 89.7       | 10.1                 |
| April    | 58.4       | 6.6                  | October   | 78.4       | 8.8                  |
| May      | 72.0       | 8.1                  | November  | 54.1       | 6.1                  |
| June     | 101.3      | 11.4                 | December  | 62.1       | 7.0                  |
| Total    |            |                      |           | 886.4      | 100.0                |

The monthly customer water demands are listed together with monthly estimates of UAF water demand and the resulting net monthly water demands in Table 2-14.

The net monthly water demands in Tables 2-14 and 2-15 represent the demands on the Morris/Centennial Reservoir system if the City does not develop a supplemental water supply. As described in Section 3, the Morris/Centennial Reservoir system capacity is analyzed in the absence of a supplemental water supply to determine the current and projected 2025 worst-case water supply deficits. Supplemental water supply requirements and alternatives to eliminate the deficits are evaluated in Sections 4 and 5, respectively.

The monthly percentages from Table 2-13 were applied to the projected annual customer water demand for 2025 in Table 2-15 along with monthly estimates of demand reduction via DMMs and monthly estimates of UAF water demand at an annual average of 12 percent.

**Table 2-14. Current Water Supply Requirements**

|           | Customer Water Demand, AF | Demand Reduction via DMMs, AF <sup>(a)</sup> | UAF Water Demand, AF <sup>(b)</sup> | Net Monthly Water Demand, AF |
|-----------|---------------------------|--|-------------------------------------|------------------------------|
| January   | 50.6                      | —  | 16.0                                | 66.6                         |
| February  | 48.6                      | —  | 16.7                                | 65.3                         |
| March     | 54.3                      | —  | 17.4                                | 71.6                         |
| April     | 58.4                      | —  | 18.1                                | 76.5                         |
| May       | 72.0                      | —  | 18.8                                | 90.8                         |
| June      | 101.3                     | —  | 19.5                                | 120.8                        |
| July      | 112.4                     | —  | 19.5                                | 131.9                        |
| August    | 104.5                     | —  | 18.8                                | 123.3                        |
| September | 89.7                      | —  | 18.1                                | 107.8                        |
| October   | 78.4                      | —  | 17.4                                | 95.8                         |
| November  | 54.1                      | —  | 16.7                                | 70.8                         |
| December  | 62.1                      | —  | 16.0                                | 78.0                         |
| Total     | 886.4                     | —  | 212.7                               | 1099.1                       |

<sup>(a)</sup> With current savings via DMMs 3 and 4 not estimated but considered as baseline

<sup>(b)</sup> With current annual average of 24 percent of customer water demand


**Table 2-15. Projected 2025 Water Supply Requirements**

|           | Customer Water Demand, AF | Demand Reduction via DMMs, AF <sup>(a)</sup> | UAF Water Demand, AF <sup>(b)</sup> | Net Monthly Water Demand, AF |
|-----------|---------------------------|--|-------------------------------------|------------------------------|
| January   | 90.2                      | 6.8  | 13.2                                | 96.7                         |
| February  | 86.6                      | 6.8  | 13.8                                | 93.7                         |
| March     | 96.7                      | 7.7  | 14.4                                | 103.5                        |
| April     | 104.1                     | 8.6  | 15.0                                | 110.6                        |
| May       | 128.4                     | 9.5  | 15.6                                | 134.6                        |
| June      | 180.6                     | 10.4   | 16.2                                | 186.4                        |
| July      | 200.4                     | 11.3   | 16.2                                | 205.3                        |
| August    | 186.3                     | 11.3   | 15.6                                | 190.7                        |
| September | 159.9                     | 10.4   | 15.0                                | 164.6                        |
| October   | 139.8                     | 9.5  | 14.4                                | 144.8                        |
| November  | 96.4                      | 8.6  | 13.8                                | 101.7                        |
| December  | 110.6                     | 7.7  | 13.2                                | 116.2                        |
| Total     | 1580.0                    | 108.0  | 176.6                               | 1648.6                       |

<sup>(a)</sup> With current savings via DMMs 3 and 4 not estimated but considered as baseline

<sup>(b)</sup> With anticipated annual average of 12 percent of customer water demand





SOURCE: - CITY OF WILLITS, ADOPTED JANUARY, 1988  
- AERIAL PHOTOGRAPHY DATED JULY, 1993



### 3. EXISTING WATER SUPPLY CAPACITY

The existing City water supply is surface water from the Davis Creek watershed, impounded in reservoirs by the Centennial and Morris Dams. Figure 3-1 is a graphical depiction of the watershed together with photographs of the Centennial and Morris Reservoir system.

Centennial Reservoir captures runoff from the upper portion of the Davis Creek watershed to a maximum storage capacity of 635 AF when the flashboards are installed along the spillway in the spring and summer months. Since construction of the dam in 1989, Centennial Reservoir has filled to capacity in all but two years. Water is released from Centennial Reservoir into Morris Reservoir during the summer months and in the event that Centennial Reservoir overfills at other times of the year.

Controlled releases from Centennial Reservoir are the only inflow to Morris Reservoir during the summer months. Morris Reservoir has a maximum storage capacity of 726 AF when the flashboards are installed along the spillway in the spring and summer months. Because the City has captured and retained its water supply further upstream since the construction of Centennial Reservoir, Morris Reservoir has filled to capacity in only eight of the past 15 years.


#### WATER SUPPLY SIMULATIONS

The current and projected 2025 net monthly water demands summarized in Tables 2-14 and 2-15, respectively, and a water supply simulation model described in Appendices A, B and C were used to analyze the delivery capacity of the Centennial and Morris Reservoir system. With current water demands and reservoir operations, the modeling forecasts water supply deficits in 10 of the 34 simulated years (almost 30 percent of the years). Figure 3-2 depicts the simulated deliveries and deficits graphically with each bar representing the current demand of 1,099 AF. The shaded portion of each bar represents the volume of water delivered in the simulated year, and the empty portion of some bars represents the anticipated water supply deficit. The average of the deficits (excluding years without shortages) is 275 AF. Based on the hydrologic conditions of an extremely dry year such as 1977, the maximum deficit is 650 AF with current demands.

Figure 3-3 presents the simulated deliveries and deficits with the projected 2025 demand of 1,649 AF. Deficits are anticipated in 29 of the 34 simulated years (85 percent of the years), with an average deficit of 458 AF and maximum deficit of 1,300 AF. The empty portion of some bars in Figure 3-3 represents the additional water supply capacity needed to avoid future deficits.

Figure 3-4 depicts the probability of meeting current and projected 2025 demands with the Centennial and Morris Reservoir system. The blue line, representing simulated deliveries with the current demand, is horizontal to a probability of 70 percent, meaning the demand will exceed the supply in 30 percent of the years. Only 449 AF of supply is available at the right end of the blue line, corresponding to the current maximum deficit of 650 AF.

**Figure 3-1. Watershed and Reservoirs**







The red line in Figure 3-4 represents simulated deliveries with the projected 2025 demand, and reveals that 1,649 AF is available for 15 percent of the simulated years. Only 349 AF of supply is available at the right end of the red line, corresponding to the projected 2025 maximum deficit of 1,300 AF.

Reservoir storage volumes and deficits with current and future demands, respectively, are presented in Figures 3-5 and 3-6. Deficits occur when reservoir storage falls to minimum operating pool, and further diversions are not possible. Monthly deficits are denoted by the red areas in Figures 3-5 and 3-6.


**Figure 3-2. Annual Delivery and Deficit with Current Demands**



**Figure 3-3. Annual Delivery and Deficit with Projected 2025 Demands**




**Figure 3-4. Probability of Delivery**






**Figure 3-5. End-of-Month Storage and Deficit with Current Demands**



**Figure 3-6. End-of-Month Storage and Deficit with Projected 2025 Demands**



## HYDROLOGY UPDATE

The initial hydrologic analyses and modeling were conducted using DWR stream flow measurements from 1986 to 1988. While only 27 measurements were reported by DWR, the resulting simulation compares well with the DWR data, and the simulated data correlate closely to the Elder Creek gage. Details of the initial hydrologic analyses and reservoir simulations are provided in Appendices A, B, C and D.


The City has collected Davis Creek stream flow data periodically since 1999 and recently upgraded the water level gages to record the data automatically. In 2005, the water levels were recorded every six hours and converted to stream flow data. These data were correlated to the Elder Creek gage, and the hydrologic dataset was updated in additional simulations as presented in Appendix D. The average annual inflow to Centennial Reservoir is approximately 400 AF greater with the updated hydrology, and the simulated deliveries to the City water system are 60 AF/year greater with current demands and 100 AF/year greater with the projected 2025 demands as compared to the initial simulations.

Figure 3-7 depicts the projected 2025 annual deliveries with deficits anticipated in six of the 34 simulated years (17 percent of the years) based on the updated hydrology. Figure 3-8 depicts the updated deficits and shortages, and Figure 3-9 reveals a reduced probability and severity of deficits. The red curve in Figure 3-9 represents the probability of deliveries with the updated hydrology while the blue curve represents the probability of deliveries with the original hydrology.


Hydrology modeling is influenced by climatic variations during data collection. The DWR measurements were taken from late 1986 to 1988, a slightly drier than average period, while the City measurements were taken in 2005 during a slightly wetter than average period. To provide a greater margin of safety in planning for the City water supply, the reservoir simulations based on DWR measurements are used in the analysis of supplemental supply requirements in Section 4 and the evaluation of supplemental supply alternatives in Section 5. Nevertheless, it is recommended that the City continue to record water levels every six hours and periodically update the reservoir simulations to refine the water supply planning criteria in the future.



**Figure 3-7. Annual Delivery and Shortage with Projected 2025 Demands: Regression with City Measurements**




**Figure 3-8. End-of-Month Storage and Shortage with Projected 2025 Demands: Regression with City Measurements**





**Figure 3-9. Probability of Delivery**



## 4. SUPPLEMENTAL SUPPLY REQUIREMENTS

The current and projected City water demands, the existing water supply, and the current and projected 2025 worst-case water supply deficits are summarized in Table 4-1.

**Table 4-1. Comparison of Water Demands and Existing Supply**

|   | Current | Projected 2025 |
|---|---------|----------------|
| Water Demand, AF/year   | 1,099   | 1,649          |
| Reservoir Supply in Critically Dry Year, AF/year <sup>(a)</sup> | 449     | 349            |
| Worst-Case Deficit, AF/year                                     | 650     | 1,300          |

<sup>(a)</sup> Reservoir supplies are projected to decline in future due to increased demands and correspondingly reduced reserves leading into critically dry years; actual 2025 reservoir supplies in critically dry years may approach current conditions with implementation of supplemental supply

The City adopted Ordinance 95-4, defining emergency restrictions for water use, after experiencing severe droughts in the 1980s and 1990s. The purpose of Ordinance 95-4 is to curtail nonessential water use and preserve the City's available water resources to maintain an adequate supply for human consumption, sanitation, and fire protection during water supply emergencies. While water supply forecasting is difficult and uncertain, the City could enforce Ordinance 95-4 during a critically dry year to reduce demand and correspondingly reduce the actual deficit.

Three stages of water emergency and related rationing measures are defined in Ordinance 95-4. Water emergency Stage I is a voluntary stage with an overall demand reduction goal of 15 percent for all customers. Water emergency Stage II is a mandatory stage that prohibits nonessential water use including outdoor use such as landscape irrigation. The Department of Water Resources estimates that 50 percent of all residential water use is outdoors. Therefore, it is estimated that enforcing water emergency Stage II would reduce residential water demands by 50 percent. For other customers, the assumed demand reductions are 15 percent. Water emergency Stage III is a mandatory stage that restricts single family residential customers to 50 gallons per capita per day (gpcd) and multiple family residential customers to 45 gpcd and requires 50 percent demand reductions by other customers.

The calculated effects of enforcing each stage of Ordinance 95-4 in 2004 and 2025 are summarized in Table 4-2.

**Table 4-2. Effects of Enforcing Ordinance 95-4**

| Water Emergency Stage | Type of Rationing | Based on Current Customer Demands <sup>(a)</sup>  | Based on Projected 2025 Customer Demands <sup>(b)</sup>   |
|-----------------------|-------------------|---|---|
| I                     | Voluntary         | All customers = 15% reductions<br>Estimated savings = 133 AF/year   | All customers = 15% reductions<br>Estimated savings = 221 AF/year   |
| II                    | Mandatory         | All residential customers = 50% reductions<br>Other customers = 15% reductions<br>Estimated savings = 331 AF/year   | All residential customers = 50% reductions<br>Other customers = 15% reductions<br>Estimated savings = 528 AF/year   |
| III                   | Mandatory         | Single family residential customers = 50 gpcd limitation<br>Multiple family residential customers = 45 gpcd limitation<br>Other customers = 50% reductions<br>Estimated savings = 545 AF/year | Single family residential customers = 50 gpcd limitation<br>Multiple family residential customers = 45 gpcd limitation<br>Other customers = 50% reductions<br>Estimated savings = 922 AF/year |

<sup>(a)</sup> Current customer demands = 886 AF/year; residential portion = 565 AF/year; other portion = 321 AF/year; single family residential demand = 468 AF/year at 154 gpcd; multiple family portion = 97 AF/year at 154 gpcd

<sup>(b)</sup> Projected 2025 customer demands = 1,472 AF/year; residential portion = 878 AF/year; other portion = 594 AF/year; single family residential demand = 699 AF/year at 170 gpcd; multiple family portion = 179 AF/year at 170 gpcd

Most water emergency ordinances in California align the rationing and demand reduction goals with defined water supply deficits. Normally, the first stage is voluntary with an overall demand reduction goal of 15 percent, similar to Stage I of Ordinance 95-4. Subsequent stages are mandatory but with three to four increments based on the potential water supply deficit and a maximum overall demand reduction goal of 50 percent. Stage III of Ordinance 95-4 is even more severe and potentially unrealistic because its enforcement would result in greater than 50 percent reduction of the overall demand. Stage II is realistic as its enforcement would result in about 30 percent reduction of the overall demand, and 30 percent is the maximum reasonable reduction after implementation of the DMMs, as described in Section 2. Therefore, only Stages I and II are considered in estimating the water supply deficit reductions in Table 4-3.

**Table 4-3. Deficit Reductions by Enforcing Ordinance 95-4**

|   | Current | Projected 2025 |
|---|---------|----------------|
| Water Demand, AF/year   | 1,099   | 1,649          |
| Reservoir Supply in Critically Dry Year, AF/year                                  | 449     | 349            |
| Worst-Case Deficit without Enforcing Ordinance 95-4, AF/year                      | 650     | 1,300          |
| Savings by Enforcing Ordinance 95-4 Stage I for 12 months, AF/year                | 133     | 221            |
| Reduced Deficit, AF/year  | 517     | 1,079          |
| Savings by Enforcing Ordinance 95-4 Stage II for 12 months, AF/year               | 331     | 528            |
| Reduced Deficit, AF/year  | 319     | 772            |
| Savings by Enforcing Ordinance 95-4 Stage I for 8 months, AF/year <sup>(a)</sup>  | 89      | 147            |
| Reduced Deficit, AF/year  | 561     | 1,153          |
| Savings by Enforcing Ordinance 95-4 Stage II for 8 months, AF/year <sup>(a)</sup> | 221     | 352            |
| Reduced Deficit, AF/year  | 429     | 948            |

<sup>(a)</sup> Considering potential for delayed enforcement in critically dry years

Table 4-3 demonstrates that enforcement of Ordinance 95-4 would reduce but not eliminate the current and projected 2025 worst-case water supply deficits. Therefore, the City will need a supplemental supply to eliminate the remaining deficits. Supplemental source capacity requirements are expressed in terms of million gallons per day (mgd) in Table 4-4 based on 8-month enforcement of Ordinance 95-4 and 8-month operation of the supplemental source. The 8-month assumption is reasonable because critically dry years are difficult to forecast, and a response during the early months of a critically dry year is unlikely.

# 5. SUPPLEMENTAL SUPPLY ALTERNATIVES

The following supplemental supply alternatives were evaluated to determine the most feasible means to satisfy the City’s requirements:

- Additional surface water supply
- Neighboring water system interconnection
- Recycled water supply
- Groundwater supply

The implementation of DMMs was addressed and incorporated into the water demand projections in Section 2, and therefore, not considered as a supplemental supply alternative.

The evaluation addresses the feasibility and cost of the identified water supply alternatives. Recommendations are made to ensure that the supplemental supply, in combination with the existing surface water supply, is of sufficient capacity to satisfy the current and projected water demands. The supplemental source and production capacity requirements in Table 4-6 are used to determine the adequacy or capacity needs of each supplemental supply alternative.

## ADDITIONAL SURFACE WATER SUPPLY

The development of additional surface water supply capacity is achievable by raising or replacing Morris Dam, raising the Morris Dam flashboards, dredging Morris Reservoir and deepening the raw water pump station, building another dam, or gaining access to Wente Lake. Raising Centennial Dam is not feasible because an increase in Centennial Reservoir’s maximum water surface elevation would cause flooding of Highway 101 and the Northwestern Pacific railroad tracks to the west.

### Raising or Replacing Morris Dam

The 1985 Water System Master Plan for the City indicated that raising Morris Dam by 50 feet would provide 2,000 to 3,000 AF of additional storage capacity. However, the Master Plan recommended against raising Morris Dam because at the time, Morris Reservoir was the sole source of water supply for the City, and raising the dam would have required taking Morris Reservoir out of service for an extended period of time.

Since the City constructed Centennial Dam, it is now possible to provide a temporary connection from Centennial Reservoir to the water treatment plant, drain Morris Reservoir, and raise Morris Dam while maintaining the production and delivery of potable water to the City. Extrapolation of the Morris Reservoir elevation-capacity curve confirms that a 50-foot height increase would provide 2,000 to 3,000 AF of additional storage capacity. Increasing the Morris Dam crest height and maximum water surface elevation would require thickening or otherwise increasing the structural capacity of the existing dam to support the additional hydrostatic pressure. The taller Morris Dam would have a crest length of about 500 feet. However, raising Morris Dam is



complicated by the presence of Centennial Dam upstream, which may limit the Morris Reservoir water surface to prevent saturation of the outside toe of Centennial Dam.

Expanding Morris Reservoir would increase the surface water supply capacity. However, determining the source capacity would require surveying the watershed to a higher elevation, additional modeling of the reservoir system, and consulting with the State Water Resources Control Board and the DWR Division of Safety of Dams. The environmental review and permitting process would add to the cost and schedule of the project, considering the federal Clean Water and Endangered Species Acts, the California Environmental Quality Act (CEQA) and the other permitting requirements.

The construction phase would require dewatering Morris Reservoir and keeping it out of service for at least eight months during the dry season. Using the entire volume of Centennial Reservoir for eight months would provide approximately 1.0 mgd, which is less than the average water demand during the dry season. Furthermore, because Centennial Reservoir would empty toward the end of the dry season, the risk of not finishing the work in time to refill Morris Reservoir during the following wet season is significant.

Alternatively, the City could construct a taller dam just downstream of the existing Morris Dam and then remove or submerge the existing dam in an expanded Morris Reservoir. Although the 1985 Water System Master Plan indicated that Davis Creek downstream of Morris Dam is geologically unstable, additional research may reveal that constructing a dam just downstream from the Morris Dam is costly yet feasible. It would entail similar environmental permitting requirements as raising Morris Dam but would allow Morris Reservoir to remain in service during construction of the downstream dam.

Increasing the height of Morris Dam or building a taller dam just downstream would expand the surface water supply capacity only. To increase the potable water production capacity, the City would also need to replace the raw water pump station and expand the water treatment plant, adding significant cost to this alternative. A very preliminary estimate of the capital cost of raising Morris Dam or building a taller dam just downstream and expanding the water treatment plant is \$20 million, as itemized in Appendix E.

**Increasing Height of Morris Dam Flashboards**

The 1985 Water System Master Plan indicated that increasing the Morris Dam flashboard height to 3.7 feet would provide 60 AF of additional storage capacity, and extrapolation of the Morris Reservoir elevation-capacity curve confirms that estimate. While increasing the flashboard height is not as costly as raising Morris Dam, it would encompass many of the same environmental permitting and logistical hurdles, including the potential need to strengthen the existing dam to support the additional hydrostatic pressure. The 60 AF increase in the reservoir storage capacity is small compared to the water supply needs of the City. Consequently, increasing the Morris Dam flashboard height is not considered a feasible alternative to satisfy the City’s need for a supplemental water supply.

**Dredging Morris Reservoir**

Previous estimates of sedimentation in Morris Reservoir have ranged from 50 to 100 AF. The 1987 Limnological Investigation of Morris Reservoir by DWR determined a sedimentation



volume of 99 AF. While the current sediment volume in Morris Reservoir is unknown, the City water system operators have reported noticeable increases in vegetative growth over the past several years. A bathymetric survey is required to determine the current elevation-capacity curve for Morris Reservoir. However, even a bathymetric survey would not quantify the volume of sediment because the soundings would indicate the water depth to sediment, not the water depth to the original bottom of the reservoir.

Dredging to remove 100 AF of sediment would cost approximately \$3.2 million at a unit cost of \$20 per cubic yard for dredging and disposal. Furthermore, the City would need to deepen the lowest outlet and suction well of the raw water pump station to reduce the minimum pool and conduct maintenance dredging routinely to maintain the reduced minimum pool.

The environmental review and permitting process for such a project would add to the cost and schedule, considering the federal Clean Water and Endangered Species Acts, CEQA and other permitting requirements. The reservoir storage capacity increase by dredging and deepening is relatively small, the benefit-to-cost ratio is very low, and the environmental review and permitting requirements are significant. Consequently, dredging of Morris Reservoir is not considered a feasible alternative to satisfy the City's need for a supplemental water supply.

Nevertheless, it is recommended that the City continue to operate the existing lower outlet(s) of Morris Reservoir as necessary to scour the immediate bottom area and minimize future sedimentation within Morris Reservoir, and work with the County to promote erosion control in the upper Davis Creek watershed.

**Building another Dam**

The City could augment its surface water supply by constructing another dam in the Davis Creek watershed or in a separate watershed of the Little Lake Valley.

Preliminary analysis indicates that constructing another dam upstream of Morris Reservoir, on a tributary to Davis Creek but separate from Centennial Reservoir, would provide limited storage capacity due to the relatively steep terrain and narrow gullies. Constructing another dam on Davis Creek but far enough downstream of Morris Dam to create a separate reservoir would provide limited storage capacity due to the steep terrain and narrow gullies leading to the Little Lake Valley floor.

Constructing another dam in a separate watershed of the Little Lake Valley is feasible but costly. A very preliminary estimate of the capital cost for a fixed dam to create a 600 to 800 AF storage reservoir, a water treatment plant with a capacity of 1.8 mgd, and a pipeline connecting to the existing transmission main or distribution system is \$18 million, as itemized in Appendix E. Such a project would involve significant environmental permitting requirements, potentially reducing its feasibility.

If construction of a concrete dam is not permitted due to environmental constraints, an alternative is to use an inflatable dam to retain stream flow during the dry seasons, and deflate the dam to accommodate fish passage during the migration seasons. However, this alternative would not provide as much storage capacity as a fixed dam due to the height limitations of an inflatable dam compared to the generally steep terrain surrounding the Little Lake Valley. The significant cost of a water treatment plant and pipeline connecting to the City water distribution system would

remain the same whether a fixed or inflatable dam is used to impound the supplemental surface water supply.

### **Gaining Access to Wente Lake**

Wente Lake is an 800 AF reservoir located four miles east of the City in the Finney Valley as depicted in Figure 5-1. It was constructed by the San Francisco Bay Area Council of the Boy Scouts of America (Boy Scouts), and is used by the Boy Scouts for recreational activities. The Boy Scouts also used the reservoir as a potable water supply until they converted to groundwater in the late 1990s. The City gained emergency access to Wente Lake from November 1987 through May 1988 during a severe drought. Approximately 75 AF was diverted from Wente Lake via creek channels and a temporary overland pipeline to the original water treatment plant, which was located downstream from Morris Dam. (The existing plant is located uphill and adjacent to Morris Dam.)

Recent discussions with the Boy Scouts revealed a willingness to explore the possibility of using Wente Lake as an emergency or permanent water supply component for the City. The Boy Scouts hold water rights License 8042 (Application 19415) and License 8043 (Application 19755) for a combined 800 AF/year from a Berry Creek tributary to replace water lost from Wente Lake through evaporation and seepage. City use of Wente Lake as a water supply would require a reservoir capacity analysis, further discussions with the Boy Scouts, and resolution of water right issues. However, the projected 2025 worst-case water supply deficit for the City is potentially greater than the Boy Scouts' entire licensed diversion to Wente Lake even with enforcement of Ordinance 95-4 Stage II (Table 4-3). Because such a diversion would impede the Boy Scouts' use of Wente Lake, accessing Wente Lake is not considered a feasible alternative to satisfy the City's need for a supplemental water supply.

Nevertheless, the City could make Wente Lake part of a water supply contingency plan. Using Wente Lake only in emergencies would entail fewer permitting requirements. A gravity diversion from Wente Lake to Morris Reservoir is achievable with a closed conduit connection, comprising about 4.4 miles of cross-country pipeline together with flow and pressure control facilities.

Another potential approach for emergency use of Wente Lake is to:

- Divert water from Wente Lake into creek channels for open channel flow to a temporary impoundment about 1.4 miles downstream
- Pump water from the impoundment into a nearby portable water treatment plant
- Deliver finished water from the portable water treatment plant to the existing transmission main at East Hill and East Side Roads via 7,700 lineal feet (LF) of temporary pipeline

To minimize cost, the City could rent rather than purchase the portable water treatment plant and temporary pipeline only as needed during a water supply deficit, or obtain the temporary components through the Office of Emergency Services. Portable water treatment plants are commercially available at capacities approaching 1.0 mgd per trailer. The stream channel approach is illustrated in Figure 5-1.

Depending on the selected supplemental supply alternative and the timeframe for implementation, the City should consider further developing a water supply contingency plan, potentially involving Wente Lake.

**NEIGHBORING WATER SYSTEM INTERCONNECTION**

The City obtained 70 AF through a temporary 8-inch diameter overland pipeline connection to the Brooktrails water system during the 1970s drought. Brooktrails relies on a relatively small surface water supply but is considering a project to expand the reservoir storage capacity, and the City is in discussions with Brooktrails regarding possible participation in the project. While the project is conceptual and the water supply capacity from Brooktrails to the City is unknown at this time, the City is encouraged to take advantage of any cost effective opportunity to supplement the City water supply by participating in the Brooktrails project.

The next closest sizeable community, the City of Ukiah, is greater than 20 miles from the City of Willits. The City of Ukiah uses both groundwater and riverbank filtered surface water from a collector well at the Russian River. The riverbank filtered surface water is treated in a conventional filtration plant. The Director of Public Utilities indicated that the City of Ukiah has emergency interconnections with two neighboring small water systems, but does not have sufficient water supply capacity to share on a regular basis. In fact, the City of Ukiah is exploring the development of additional groundwater supply capacity to meet its own needs.

Furthermore, this alternative would entail significant cost and permitting requirements, including the need to address interbasin transfer issues. Considering the water supply, cost, and environmental permitting issues, interconnecting with the City of Ukiah is not considered as a feasible alternative to satisfy the City’s need for a supplemental water supply.

**RECYCLED WATER SUPPLY**

Many water systems in California have developed or are pursuing the development of recycled water supplies to offset the demand for potable water. Most recycled water supply systems entail advanced treatment of wastewater to generate a non-potable water supply that is compliant with the terms and conditions of California Code of Regulations Title 22, distribution of the recycled water supply through a dedicated distribution system, and in some cases, storage in dedicated reservoirs. The recycled water supply is typically used to irrigate crops, turf and landscapes.

The City is in the process of designing a major upgrade of its wastewater treatment facilities. The project includes an effluent storage pond and a dedicated irrigation field, and several farmers have expressed interest in receiving effluent for irrigation of their crops. However, those farmers do not currently use City water, so irrigating the crops with treated wastewater will not offset potable water demand from the City.

The current wastewater treatment facilities upgrade project is not intended to generate recycled water that complies with Title 22. The City previously explored providing recycled water to offset potable water demands within the City, but the large customers that were interested in receiving recycled water have since gone out of business. The City does not anticipate a significant demand for recycled water, and therefore, the development of a recycled water supply to offset some of the



potable water demand is not considered a feasible alternative to satisfy the City’s need for a supplemental water supply.

Nevertheless, irrigating nearby crops with treated wastewater will offset some of the groundwater supply needs of the local area farmers and indirectly benefit the City if groundwater is developed as a potable water supply for the City water system.

**GROUNDWATER SUPPLY**

The feasibility of implementing a groundwater supply for the City to supplement the existing surface water supply depends on the groundwater quality and treatment requirements, the location and yield of proposed wells, and the effect of City pumping on local area agricultural and domestic wells. References for the groundwater supply analysis include:

- Weeks Drilling and Pump Company. 1984. Water Well Drillers Report. (Weeks 1984)
- Weeks Drilling and Pump Company. 1984. Test Pump Log. (Weeks 1984)
- Alpha Analytical Laboratories, Inc. 1984. Chemical Examination Report. (Alpha 1984)
- Farrar, C.D. 1986. Ground-Water Resources in Mendocino County, California. USGS Water-Resources Investigations Report 85-4258. (USGS 1986)
- State of California – Resources Agency, Department of Water Resources, Northern District. 1987. City of Willits – Department of Water Resources Ground Water Study. (DWR 1987)
- State of California – Resources Agency, Department of Water Resources, Northern District. 1988. Letter to City of Willits. (DWR 1988)
- Alpha Analytical Laboratories, Inc. 2000. Chemical Examination Report. (Alpha 2000)
- Willits Environmental Remediation Trust. 2002. Former Remco Hydraulics, Inc. Site, Willits, California, Final Remedial Investigation Report Summary. (WERT 2002)
- California Department of Water Resources. 2004. California’s Ground Water Bulletin 118. Little Lake Valley Groundwater Basin. (DWR 2004)
- California State Water Resources Control Board. 2005. [www.Geotracker.com](http://www.Geotracker.com). (SWRCB 2005)

**Little Lake Valley Groundwater Basin**

The Little Lake Valley groundwater basin is an irregularly shaped basin in the Coast Range within central Mendocino County (DWR 2004). The basin is approximately seven miles long and as much as three miles wide near the centerline of the valley and likely was formed by faulting along its margins. The City is located in the west-central portion of the basin. The Little Lake Valley is drained to the north by several streams including Baechtel, Broaddus, Davis, Haehl and Willits Creeks and then to the northwest through Outlet Creek.

Water-bearing formations in the basin consist of the Quaternary alluvial deposits and older Pliocene to Pleistocene continental basin deposits. Groundwater is locally available in fractures in

the underlying and surrounding consolidated bedrock of the Jurassic-Cretaceous Franciscan Complex. The alluvial deposits are Holocene in age and cover most of the flat portions of the valley, an area of approximately 12 square miles. The alluvium, which consists of uncemented gravel, sand, silt and clay, is the most productive aquifer in the valley, and properly constructed wells in favorable areas of the alluvium can yield several hundred gallons per minute. Most of the groundwater in the alluvium is either confined or semiconfined beneath extensive sheets of fine-grained sediments, or unconfined along the valley margins and in the shallow alluvium along creek channels. Specific yield for the alluvium is estimated at about eight percent, which is reasonable for water supply wells. Most recharge to the alluvium occurs at the southern margin of the alluvial plain. Hydrographs of groundwater levels from the late 1950s to present show typical seasonal water level fluctuations without any significant long-term trends.

**Park Well**

The City constructed a groundwater well known as the Park Well east of Lenore Avenue and just south of Commercial Street in 1984. The Park Well was drilled to a depth of 240 feet below ground surface, and it has a 50-foot deep sanitary seal, an 8 5/8-inch diameter steel casing of 0.188-inch wall thickness, a high capacity wire wrapped screen with 0.07-inch slot openings, and a packing of fine pea gravel (Weeks 1984). The steel casing is not corrosion resistant, the casing wall is relatively thin, and the packing is not sized or graded to maximize yield and prevent sand production from the well.

Pumping tests in the 1980s revealed that the Park Well can support a pumping rate of approximately 225 gallons per minute (gpm) for 180 consecutive days per year (i.e. 360 AF/year), causing a maximum drawdown of about 7.5 feet in neighboring wells within a 1,000 feet radius (DWR 1987 and 1988). However, the existing pump in the Park Well has a greater capacity than 225 gpm and causes more significant drawdown of neighboring wells. The Park Well was not connected to the City water system, but is used seasonally to irrigate athletic fields in the vicinity of the wellhead.

**Groundwater Quality**

Groundwater in the Little Lake Valley is characterized as calcium-magnesium bicarbonate and magnesium-calcium bicarbonate, with a few exceptions characterized by sodium bicarbonate and sodium chloride (DWR 2004). Total dissolved solids concentrations from 17 wells in the Little Lake Valley range from 97 to 1,710 mg/L and average 340 mg/L (USGS 1986) while some local area wells contain significant concentrations of arsenic, boron, iron and manganese (DWR 2004). Arsenic is a health concern in drinking water, and the federal maximum contaminant level (MCL) was reduced to 0.010 mg/L in January 2006. Significant concentrations of boron in a water supply can restrict crop yield and adversely affect landscaping and house plants. Iron and manganese are the cause of aesthetic concerns but not health effects in drinking water, and are subject to secondary MCLs.

Pertinent water quality data for the Park Well are summarized in comparison to the respective drinking water MCLs in Table 5-1 (Alpha 1984 and 2000 and DWR 1987).

**Table 5-1. Park Well Water Quality**

|                                       | Sample Collection Date |                   |                | MCL <sup>(a)</sup>        |
|---------------------------------------|------------------------|-------------------|----------------|---------------------------|
|                                       | May 8, 1984            | September 4, 1986 | March 21, 2000 |                           |
| Alkalinity, mg/L as CaCO <sub>3</sub> | 382                    | 344               | 357            | None                      |
| Apparent Color, PCU                   | —                      | —                 | 7              | 10 <sup>(b)</sup>         |
| Arsenic, mg/L                         | —                      | 0.122             | 0.150          | 0.010 <sup>(c)</sup>      |
| Boron, mg/L                           | BDL <sup>(d)</sup>     | 0.2               | —              | 3 <sup>(e)</sup>          |
| Chloride, mg/L                        | 12                     | 8                 | 7.9            | 250 <sup>(b)</sup>        |
| Fluoride, mg/L                        | 0.4                    | —                 | 0.23           | 2 <sup>(c)</sup>          |
| Hardness, mg/L as CaCO <sub>3</sub>   | 330                    | —                 | 298            | 250 <sup>(b)</sup>        |
| Iron, mg/L                            | 0.9                    | 1.1               | 2.0            | 0.3 <sup>(b)</sup>        |
| Manganese, mg/L                       | 2.7                    | 3.2               | 3.5            | 0.05 <sup>(b)</sup>       |
| Nitrate, mg/L                         | BDL                    | —                 | BDL            | 45 <sup>(c)</sup>         |
| Odor, TON                             | —                      | —                 | BDL            | 3 <sup>(b)</sup>          |
| pH                                    | 7.4                    | —                 | 7.1            | 6.5 to 8.5 <sup>(b)</sup> |
| Specific Conductance, umhos/cm        | 910                    | —                 | 667            | None                      |
| Sulfate, mg/L                         | BDL                    | 4                 | BDL            | 250 <sup>(b)</sup>        |
| Total Dissolved Solids, mg/L          | 395                    | —                 | 384            | 500 <sup>(b)</sup>        |
| Turbidity, NTU                        | 7.8                    | —                 | 18             | 0.3 <sup>(c)(f)</sup>     |

- <sup>(a)</sup> Maximum contaminant level
- <sup>(b)</sup> Secondary (aesthetic based) MCL
- <sup>(c)</sup> Primary (health based) MCL; listed arsenic value is federal MCL
- <sup>(d)</sup> Below detection limit
- <sup>(e)</sup> Threshold for agriculture and landscape irrigation rather than state or federal MCL
- <sup>(f)</sup> Value applicable to filtered surface water supplies

The water quality parameters of concern in the Park Well are arsenic, hardness, iron, manganese and turbidity. The removal of these undesirable constituents from a water supply is readily achievable via oxidation-filtration enhanced by coagulant addition. However, the relatively high turbidity of the groundwater from the Park Well is indicative of sand production from the well, which can cause excessive wear of the wellhead equipment. Hardness is a cause of aesthetic concerns but not health effects in drinking water. City water customers who are accustomed to the existing surface water supply with a hardness of 120 mg/L may experience more scaling in plumbing fixtures and appliances with the 300 to 330 mg/L of hardness in the groundwater supply. The customers also may use more soap to generate lather and more water for rinsing with the groundwater supply. Hardness reduction is achievable via softening but the cost of centralized softening is generally greater than the benefit. Alternatively, individual water customers can install point-of-entry softeners at their discretion.



The most publicized groundwater contamination in the City is the former Remco Hydraulics facility, located southwest of the intersection of Highways 20 and 101, where leaky chrome plating tanks introduced volatile organic chemicals (VOCs) and hexavalent chromium into the groundwater beneath the site. The remedial investigation has determined the horizontal extent of contamination is widespread only near the ground surface, the contamination is mostly contained within the site, the contamination has not migrated far from the source, and interim remedial actions have removed the contamination sources and limited the routes of migration (WERT 2002). Nevertheless, continued monitoring of the groundwater quality in the vicinity of the Remco Hydraulics site is advisable to confirm the adequacy of remediation.

Several leaky underground storage tanks (LUSTs) were identified in the northeast quadrant of the City, but the identified leaks were relatively minor (SWRCB 2005). Nevertheless, investigation of the case files containing more detailed information about the LUST sites is recommended prior to final site selection for a City well(s).

**Proposed Groundwater Supply**

The City will need about 1.8 mgd of supplemental water supply by 2025 without enforcing Ordinance 95-4 during critically dry periods (Table 4-6). It is assumed herein that the maximum reliable pumping capacity of the proposed wells is 330 gpm per well. Therefore, delivering 1.8 mgd of groundwater into the distribution system would require the development of four wells with a pumping capacity of 330 gpm each. The combined pumping capacity of the proposed wells is somewhat greater than 1.8 mgd because a portion of the groundwater flow is needed to backwash filters and for other non-potable purposes in a typical groundwater treatment plant.


Alternatively, the City could redevelop and re-equip the Park Well as a 225 gpm potable water supply well after video logging and an additional pumping test to evaluate the well condition, identify needed repairs, determine the severity of sand production, and confirm the groundwater quality. However, because the current condition and longevity of the Park Well are questionable, and at best, conversion of the Park Well into a potable water supply well would defer the need for one of the proposed wells, it is recommended that the City retain the Park Well for non-potable use (i.e. irrigation) only.

Under current demand conditions, the City will need about 0.6 mgd of supplemental water supply in critically dry periods while enforcing Ordinance 95-4 Stage II, and 0.9 mgd to avoid enforcement of Ordinance 95-4 (Table 4-6). Whether the City is willing to enforce Ordinance 95-4 to survive critically dry periods in the long-term is a policy decision that may entail significant deliberation by the City. Consequently, phased implementation of the groundwater supply project is recommended to allow time for such deliberations and to minimize the immediate capital investment.


The phasing plan would entail:

- Phase 1 – Developing two 330 gpm wells, and constructing a centralized 0.9 mgd groundwater treatment plant to eliminate the current water supply deficit
- Phase 2 – Developing an additional well to pump 330 gpm, and expanding the groundwater treatment plant to a capacity of 1.35 mgd by 2015 or as dictated by increasing demands

I:\706\706-04-02-FG5-2.dwg 2-15-06 09:15:15 AM JSeebach







LEGEND

— LEGEND TEXT



0 1500 3000  
SCALE IN FEET

Figure 5-1

City Of Willits  
Water Supply Planning Study  
Proposed Water Supply Contingency Plan



Phase 3 – Developing an additional well to pump 330 gpm, and expanding the groundwater treatment plant to a capacity of 1.8 mgd by 2025 or as dictated by increasing demands

The approximate locations of the Phase 1 groundwater supply facilities are depicted in Figure 5-2. Approximately 2,500 LF of 8-inch diameter pipeline would connect the proposed wells to the groundwater treatment plant, and approximately 500 LF of 12-inch diameter pipeline would connect the groundwater treatment plant to an existing 8-inch diameter pipeline in Valley Street. It is assumed that each of the Phase 2 and Phase 3 wells will require about 1,000 LF of 8-inch diameter pipeline to connect to the centralized groundwater treatment plant. An additional 1,100 LF of pipeline, from the groundwater treatment plant connection in Valley Street to Lenore Avenue, may prove necessary in the future depending on the final groundwater supply capacity. A side benefit of the proposed groundwater supply location is that the treated groundwater would enter the distribution system in the northern sector of the City while the treated surface water would continue to enter at the south end, potentially reducing the need for future distribution system improvements in other areas of the City water system.

Locating the groundwater supply and treatment facilities as depicted in Figure 5-2 would place the wells in a 100-year flood plain and potentially in a floodway. Nevertheless, this general location is recommended to maximize the groundwater quality and yield. Locating the wells further to the east and closer to the centerline of the Little Lake Valley would help to maximize the groundwater quality and yield, but would entail property acquisition and extend the time requirements for project implementation. The Department of Health Services (DHS) prohibits the construction of water supply wells in a 100-year floodplain unless there are no viable alternatives, and consultation with DHS is a recommended early step in the groundwater supply project. It is anticipated that DHS will accept the proposed locations of the groundwater supply and treatment facilities, providing that the wellheads and treatment facilities are high enough in elevation to prevent surface water from contaminating the groundwater supply and to protect the pumping and treatment facilities from potential flood damage.

To achieve 330 gpm per well, the preliminary recommendation is to drill the proposed wells to a similar depth as the Park Well but with a larger diameter to achieve greater yield and efficiency. Other recommendations to provide greater efficiency, strength and durability in the proposed wells as compared to the Park Well include:

- Casing wall thickness of at least 0.32 inches
- Casing and screen construction with corrosion resistant materials such as copper-bearing steel, high-strength low alloy steel, or type 304 stainless steel
- Packing composed of durable and appropriately sized and graded gravel to maximize yield and minimize sand production for site-specific conditions

Screening intervals are typically determined as part of the drilling operation. Nevertheless, screening intervals generally similar to the Park Well are anticipated in the proposed wells.

The groundwater treatment facilities would remove arsenic, iron, manganese, turbidity and other undesirable constituents as necessary, depending on the actual groundwater quality, to produce potable water in compliance with the drinking water regulations. Constructing the Phase 1 treatment facilities and then incrementally expanding the plant capacity would cost more, even in current dollars, than initially constructing 1.8 mgd of treatment facilities due to economies of scale. However, incremental expansion of the plant together with phased implementation of the other project components would minimize the initial effect on rates.

The groundwater treatment plant would include an oxidation-filtration system, chemical storage and feed facilities, and waste handling facilities as well as instrumentation and controls to accommodate remote control of the well pumps and treatment facilities from the existing plant at Morris Reservoir. The use of backwash ponds is assumed in the costs estimates and Figure 5-2 although discharging the waste streams to the City sewer system, if feasible, could reduce the cost and footprint of the groundwater supply project. Softening to reduce hardness is not included in the cost estimates. Standby power is not needed at the wells or groundwater treatment plant because a concurrent electrical power supply interruption at the groundwater treatment plant and the surface water treatment plant is very unlikely, and after implementation of Phase 2 of the groundwater supply project, either plant could supply the average demands. The development of more specific design criteria for the groundwater treatment plant will depend on the groundwater quality from the proposed wells as determined after pumping tests.

The preliminary estimated capital cost of Phases 1, 2 and 3 combined is \$7.0 million as itemized in Appendix E. Lower capital costs are potentially achievable by:

- Discharging the groundwater treatment plant waste streams to the City sewer system instead of providing on-site treatment
- Reducing the capacity of the groundwater supply facilities and enforcing Ordinance 95-4 Stage II to survive critically dry periods in the long-term
- Reducing the capacity of the groundwater treatment facilities and using additional groundwater as a non-potable water supply

Determining the feasibility of discharging the waste streams to the City sewer system and other sub-alternatives to reduce the cost of the groundwater supply project is appropriate for the preliminary design phase of the project.

**COMPARISON OF ALTERNATIVES**

The following water supply alternatives were deemed inadequate to satisfy the City’s need for a supplemental water supply or were otherwise not feasible:

- Raising Morris Dam
- Increasing height of Morris Dam flashboards
- Dredging Morris Reservoir
- Gaining access to Wente Lake



- Interconnecting with neighboring water system
- Implementing recycled water supply

While gaining access to Wentle Lake is not considered a feasible alternative to satisfy the City’s need for a supplemental water supply, the City could make Wentle Lake part of a water supply contingency plan, as described in this report.

The three feasible alternatives to augment the City water supply and a matrix comparison of critical evaluation criteria are provided in Table 5-2.

**Table 5-2. Comparison of Water Supply Alternatives**

| Alternative                                | Expanded Morris Reservoir <sup>(a)</sup> | Supplemental Surface Water Supply <sup>(b)</sup> | Groundwater Supply                  |
|--|--|--|-------------------------------------|
| Capacity through 2025                      | High                                     | High   | High                                |
| Capacity to accommodate growth beyond 2025 | High                                     | Uncertain <sup>(c)</sup>                         | Uncertain <sup>(d)</sup>            |
| Water quality perception                   | Positive                                 | Positive   | Potentially negative <sup>(e)</sup> |
| Benefit to distribution system             | Low                                      | Uncertain <sup>(c)</sup>                         | High                                |
| Relative cost                              | High                                     | High   | Moderate                            |
| Environmental permitting requirements      | Major                                    | Major  | Moderate                            |
| Land purchase requirements                 | Minor <sup>(f)</sup>                     | Major  | Minor <sup>(g)</sup>                |
| Phasing potential                          | None                                     | None   | High                                |
| Implementation timeframe                   | 10 years                                 | 10 years   | 2 years                             |


- <sup>(a)</sup> Raising or replacing Morris Dam
- <sup>(b)</sup> Building another dam elsewhere in Little Lake Valley
- <sup>(c)</sup> Depends on capacity and location of additional dam and reservoir
- <sup>(d)</sup> Potentially limited by groundwater basin capacity
- <sup>(e)</sup> Greater hardness of groundwater supply may cause aesthetic concerns for some customers
- <sup>(f)</sup> Potentially none
- <sup>(g)</sup> Potentially none in Phase 1

Developing a supplemental surface water supply would entail a similar cost and timeframe as expanding Morris Reservoir, but would require a much greater land purchase and may not provide as much capacity to accommodate growth beyond 2025. Consequently, expanding Morris Reservoir and developing a groundwater supply are the more feasible alternatives to satisfy the

City’s need for an additional water supply. The primary benefits of a groundwater supply are its lower cost and more rapid implementation compared to an expanded surface water supply and its phasing potential. The capital cost estimate for all three phases of a groundwater supply is \$7.0 million, which is less than half of the capital cost estimate for an expanded surface water supply. Because the groundwater supply would require treatment, the operations and maintenance (O&M) cost for a groundwater supply is similar to the O&M cost for an expanded surface water supply, and the capital cost is the primary differentiator. Furthermore, phasing the implementation of the groundwater supply can minimize the initial effect on rates, which is not the case for an expanded surface water supply. The principal downside of a groundwater supply is its uncertain capacity to accommodate growth beyond 2025.

Given the cost and other advantages, the development of a groundwater supply is the recommended alternative for the City to provide an adequate water supply through 2025. Nevertheless, it is recommended that the City plan to expand Morris Reservoir and the surface water treatment plant in the future if annexations and growth projections require a greater water supply capacity than the existing surface water supply and proposed groundwater supply can support.

I:\706\706-04-02-FIG5-2.dwg 2-15-06 09:15:15 AM JSeebach



SUBMITTED :  
DATE : 8/19/05  
APPROVED :  
DATE :

THIS LINE IS 1 INCH  
AT FULL SCALE  
IF NOT SCALE ACCORDINGLY  
SCALE : 1"=400'-00"  
DRAWN BY : HJS  
DESIGNED BY :  
PROJ. MGR. : REH

| NO. | ZONE | REVISIONS | BY | DATE |
|-----|------|-----------|----|------|
|     |      |           |    |      |
|     |      |           |    |      |
|     |      |           |    |      |
|     |      |           |    |      |
|     |      |           |    |      |
|     |      |           |    |      |
|     |      |           |    |      |
|     |      |           |    |      |
|     |      |           |    |      |

**WEST**  
**YOST**  
& ASSOCIATES  
Consulting Engineers  
1280 Lake Boulevard, Suite 240  
Davis, California 95616  
(530) 756-5905  
FAX (530) 756-5991

**CITY OF WILLITS  
WATER SUPPLY PLANNING STUDY**

**GROUNDWATER SUPPLY PROJECT  
PHASE 1  
CONCEPTUAL VICINITY MAP**

JOB NUMBER  
706-04-04-02  
FIGURE 5-2  
SHEET NUMBER  
OF  
REVISION



## 6. CONCLUSIONS AND RECOMMENDATIONS

Population and land use methodologies were used to project the 2025 and build-out water demands for the City. The land use methodology was considered more accurate, and the land use based demand projections were used as a basis of planning for the remainder of the study. Demand management measures were determined to have significant potential to reduce water demands in the future, and estimates of demand reduction were incorporated into the projected 2025 water supply requirements.

Hydrological analysis and modeling of the Centennial and Morris Reservoir system revealed a current worst-case water supply deficit of 650 AF/year and a projected 2025 worst-case deficit of 1,300 AF/year in critically dry years. Enforcement of Ordinance 95-4 during critically dry years would reduce but not eliminate the worst-case deficits. The supplemental water supply requirements for the City are summarized in Table 6-1.

**Table 6-1. Supplemental Water Supply Requirements**

|                             | Without Enforcement of Ordinance 95-4 | With Enforcement of Ordinance 95-4 Stage I | With Enforcement of Ordinance 95-4 Stage II |
|-----------------------------|---------------------------------------|--|---|
| Current Demands, mgd        | 0.9                                   | 0.8  | 0.6   |
| Projected 2025 Demands, mgd | 1.8                                   | 1.5  | 1.3   |

The supplemental water supply alternatives for the City include:

- Additional surface water supply
- Neighboring water system interconnection
- Recycled water supply
- Groundwater supply

Several of the alternatives were deemed inadequate to satisfy the City's need for a supplemental water supply or were otherwise not feasible. The three feasible alternatives are: 1) expanding the capacity of Morris Reservoir, 2) building another dam elsewhere in the Little Lake Valley to expand the surface water supply, and 3) developing a groundwater supply. The capital cost estimate for a supplemental or expanded surface water supply is \$18 to \$20 million while the capital cost estimate for a groundwater supply is \$7.0 million (Appendix E). In addition to the cost and other advantages of the groundwater supply alternative, it is feasible to implement the groundwater supply project in phases and minimize the initial effect on rates, which is not the case for an expanded surface water supply. The principal downside of the groundwater supply alternative is that the long-term annual yield of the Little Lake Valley groundwater basin may limit the groundwater supply potential to accommodate City water system growth beyond 2025.

As a result of this Water Supply Planning Study, it is recommended that the City:

- Designate a Water Conservation Coordinator to develop, launch and manage a City water conservation program and oversee the implementation of demand management measures, as described in this report.
- Continue aggressively detecting and repairing leaks in the water distribution system and maintaining or replacing meters to reduce the UAF water demand to 12 percent of the customer water demand.
- Determine whether to develop enough supplemental water supply capacity to avoid enforcement of Ordinance 95-4 in critically dry years.
- Continue to operate the lower outlet(s) of Morris Reservoir as necessary to scour the immediate bottom area and minimize future sedimentation, and work with the County to promote erosion control in the upper Davis Creek watershed.
- Pursue the use of Wente Lake as part of a water supply contingency plan, as described in this report.
- Provide treated wastewater to local area farmers to offset the agricultural demand for groundwater and increase the groundwater supply availability to the City.
- Incorporate the water supply needs of any future annexation into the capacity of a supplemental water supply project(s).
- Continue discussions with Brooktrails to determine the feasibility and potential advantages of participating in an expansion of the Brooktrails water supply capacity.
- Develop a groundwater supply as described in this report.
- Plan to expand Morris Reservoir and the surface water treatment plant in the future if annexations and growth projections require a greater water supply capacity than the existing surface water supply and proposed groundwater supply can support.

Implementation of the first phase of the groundwater supply project, as described in this report and depicted in Figure 5-2, will entail:

1. Evaluating environmental impacts, preparing necessary environmental documentation, and soliciting public comments for CEQA compliance.
2. Consulting with DHS, investigating potentially contaminating activities that may affect water quality, and adjusting proposed well locations and screening intervals as necessary.
3. Initiating detailed design of wells, pipelines and groundwater treatment plant, and securing easements as necessary.
4. Drilling wells, conducting pumping tests, collecting water quality data, and incorporating test results and water quality data into detailed design.
5. Finalizing design and amending domestic water supply permit from DHS.
6. Advertising project, evaluating and awarding construction contract, and administering contract through completion.



7. Commissioning facilities and training operators as regards groundwater supply operations and maintenance requirements.

The preliminary description of the groundwater supply project, found in this report, will serve as a rational foundation to pursue CEQA compliance and proceed into design.

11

## APPENDIX A

---

### Detailed Model Description

16

2

# APPENDIX A - Detailed Model Description

## GENERAL MODEL DESCRIPTION


The Willits water supply model was developed as a spreadsheet. System conditions (e.g., beginning reservoir storage and water demands) are initialized for a given date, with subsequent operations determined by a series of rules and constraints. Each day's operation is dependent upon the state of the system at the end of the previous day. The model is used to simulate continuous operation of the system, day-to-day, month-to-month and year-to-year, over a time period of 36 years. The effects of a set of operating rules can be evaluated by running a simulation over the long-term hydrologic record that includes periods of flood and prolonged drought. Appendix A contains a detailed description of the model.

This type of model can be used to evaluate a given set of demands or operational rules over a long sequence of months and years. Starting with the historical hydrology (watershed inflows), the model stores or moves water based on a given set of rules and constraints such as demands, bypass requirements, flood control or spillway requirements. The results indicate what water is expected to be available for various purposes under the specified operational rules.

## SYSTEM DEPICTION

Figure 1-A is the model representation of the City's reservoir system. Daily inflows are input, along with evaporation rates, reservoir operating parameters, flow requirements, and water demands. Operations of the reservoir system were designed, based on discussions with system operators, to mimic actual operations.

**Figure 1-A Model Schematic**



## **BASIC MODEL ASSUMPTIONS**

### **Operations**

The primary purpose of Centennial and Morris Reservoirs is water supply; these reservoirs are not operated to provide flood protection. Safety of Dams criteria dictates operation of flashboards at Centennial and Morris Dams, these flashboards increase storage capacity when they are in place.

In the winter, water is held upstream in Centennial Reservoir until it is required for water supply or spills into Morris. Morris is filled during the winter from Centennial spills and from local area runoff.

In the summer, water released from Centennial at a constant rate so that Centennial will reach its minimum pool by October 31. The algorithm used does not “look ahead”, so increases in inflow or additional water required by Morris can alter summertime operations.

State Water Resources Control Board License 11311, Permit 17613 and Permit 20352 govern reservoir operations. Permit 20352 specifies Davis Creek bypass flow requirements for both reservoirs. These bypass requirements are implemented using two lookup tables: one table for the normal year bypasses (as defined in the Permit); and a second table for the drought year bypasses (as defined in the Permit). These tables match the seasonal bypass requirements specified in Permit 20352, paragraphs 18 and 19. The model looks up the value for the condition and the month, and bypasses the minimum of this value or the actual reservoir inflow, whichever is less. This same bypass procedure is used for each reservoir.

### **Hydrologic Data Development**

The volume and timing of runoff into the reservoir system significantly influences water supply results. Therefore, it is important to use the best inflow data available. Because there are no long-term stream gage records for the inflow into Centennial and Morris Reservoirs, inflows were estimated based on data provided by the State of California Department of Water Resources, data provided by the City of Willits, and USGS streamflow reports. The inflow and evaporation data are described in detail in Appendix B.


Figure 2-A contains a chart showing annual inflows to both Centennial and Morris Reservoirs; the average total inflow to both the reservoirs is 3,100 acre feet.

### **Calibration / Validation**

To verify the accuracy of the model and the conclusions that are based on model results, modeled storage was compared with historical storage. Actual water deliveries and dates of flashboard use were used as inputs to the model and the reservoir storage levels were compared with historic data. This comparison and discussions with system operators confirm that the model is an acceptable tool for this water supply analysis. Appendix C contains a detailed comparison of the modeled results and historical data.



**Figure 2-A Reservoir Inflows**



## User Interfaces

Inflows, storage and outflows from Centennial and Morris Reservoirs are graphically depicted in Figure 3-A. These modeled parameters show the month-by-month results of each simulation.

Several sheets within the model provide additional graphic and tabled information regarding the results of each simulation. These sheets are described later in this report.

## Model Layout

The model is coded by several worksheets within a single Excel workbook. The individual worksheets group common functions or purposes. Several of the worksheets are further organized into sections to provide the user with logically grouped information.

The Excel workbook contains the following worksheets:

- System schematic
- Control
- Daily Model
- Monthly Charts
- Operations Chart
- Annual Charts
- Period of Record Charts
- Lookup
- License and Permits
- Centennial Area-Capacity
- Morris Area-Capacity

Each of these worksheets is described here:

## **System Schematic Worksheet**

This worksheet contains a schematic representation (Figure 3-A) of the major components in the water system that are simulated by the model. The flowchart reports an end of month “snapshot” of reservoir storage and modeled flows. The user can specify the month to display by typing the year and month in the control box located in the worksheet. The user may also step through the simulation one month at a time or one year at a time by clicking on the forward and backward arrows in the control boxes.

## **Control Worksheet**

The control worksheet contains parameters used to control the simulation of the water system. The control worksheet is shown in Figure 4-A.

The *control worksheet* is divided into the following sections:

- **Demand Data**  
Current and future water demand requirements are entered into this monthly table.
- **Reservoir Operations**  
The physical operations criteria for the system are defined in this section. For each reservoir, the minimum pool, maximum storage, and flashboard installation dates may be entered. The minimum pool is the lowest level that water can be drawn out of a reservoir. The outflow could be limited by the elevation of the gates or sediment filling the bottom of the reservoir. Installing flashboards across the spillway of each reservoir increases the maximum storage capacity. The dates that flashboards are installed and the new maximum capacities are entered in this table.
- **System Losses**  
The only losses considered this model are evaporative losses; storage losses due to seepage and sedimentation are not modeled. These losses are entered separately for each month for each reservoir. The procedure for estimating the evaporative losses is described in Appendix B.
- **License and Permit Requirements**  
Requirements for various licenses and permits are specified in this section.
  - License 11311 restricts direct diversions, diversions to storage, the sum of the direct diversions and diversions to storage, and the sum of the direct diversions and withdrawals from storage.
  - Permit 17613 adds an additional 280 acre-feet that may be collected to storage in Morris Reservoir.
  - Permit 20352 allows up to 767 acre-feet to be diverted and put to beneficial use. This permit also specifies Normal and Drought year minimum bypass requirements for both reservoirs.

## **Daily Model Worksheet**

The actual simulation is performed in this worksheet. Details of the model logic are contained in Figure 5-A. This chart includes the equations that are embedded in the model and their descriptions.

The *Daily Model Worksheet* is visually grouped into four sections:

- **Inflows**  
Two series of inflow were analyzed. Both sets of inflow data were developed by regression with a similar basin with a USGS gage. The first inflow series was based on data taken by the Department of Water Resources from 1986 – 1988; the second series was based on the 2005 Centennial inflow records kept by the City of Willits. There are more details on development of the inflow series in Appendix B. The simulated data for Centennial and Morris and the entire watershed is an input to the model in this section.
- **Centennial Reservoir**  
This section of the model simulates Centennial reservoir operations.
- **Morris Reservoir**  
This section of the model simulates Morris reservoir operations.

### **Monthly Charts Worksheet**

This worksheet can be used to step through and view water supply system information for each month. Controls allow stepping through simulation one month or one year at a time or jumping to a specific month and year.

### **Operations Chart 1 Worksheet**

This chart graphically depicts the monthly shortages and end-of-month storages for the entire simulation.

### **Operations Chart 2 Worksheet**

This chart graphically depicts the daily shortages and storages for the entire simulation.

### **Annual Charts Worksheet**

This worksheet totals daily data from the simulation into monthly tables. Charts allow stepping through and viewing simulation data for a single year.

### **Period of Record Charts Worksheet**

This worksheet totals daily data from the simulation into a yearly table. Charts summarize simulation results in various formats.

### **Lookup Worksheet**

This worksheet contains data for looking up year type (Normal or Drought). The year type is estimated twice a year, on March 1 and on April 30. Figure 4-A shows the historical year types. This information is used to determine bypass flow requirements for the coming year.

**License and Permits Worksheet**

This worksheet contains water supply limits and bypass requirements from the license and permits.

**Centennial Area-Capacity Worksheet**


This worksheet contains elevation, capacity and area data for Centennial Reservoir. This table is used to determine surface area of the reservoir for evaporation calculations. Area-Capacity is discussed further in Appendix B, and the curves are in Figure 5-B.

**Morris Area-Capacity Worksheet**

This worksheet contains elevation, capacity and area data for Morris Reservoir. This table is used to determine surface area of the reservoir for evaporation calculations. Area-Capacity is discussed further in Appendix B, and the curves are in Figure 5-B.



Figure 3-A



# Figure 4-A

## CONTROL DATA

NOTE This is a listing of all the variables for the simulation model. The values in the yellow cells are the values that may be changed.

### Demand Data

#### Monthly Demand Pattern (less backwash) - acre feet

|                | OCT   | NOV   | DEC   | JAN  | FEB  | MAR   | APR   | MAY   | JUN   | JUL   | AUG   | SEP   | Total (af) | Total (mg) |
|----------------|-------|-------|-------|------|------|-------|-------|-------|-------|-------|-------|-------|------------|------------|
| Current (2003) | 95.8  | 70.8  | 78.0  | 66.6 | 65.3 | 71.6  | 76.5  | 90.8  | 120.8 | 131.9 | 123.3 | 107.8 | 1099       | 358        |
| Future         | 144.8 | 101.7 | 116.2 | 96.7 | 93.7 | 103.5 | 110.6 | 134.6 | 186.4 | 205.3 | 190.7 | 164.6 | 1649       | 537        |

### Reservoir Operations

|            | Flashboard Date | Min Pool | Max Storage with FB | Max Storage w/o FB |
|------------|-----------------|----------|---------------------|--------------------|
| Centennial | Apr 2           | 50       | 635                 | 512                |
| Morris     | Mar 16          | 100      | 726                 | 628                |

### System Losses

#### Reservoir Evaporation (in)

|            | OCT  | NOV  | DEC  | JAN  | FEB  | MAR  | APR  | MAY  | JUN  | JUL  | AUG  | SEP  | Total |
|------------|------|------|------|------|------|------|------|------|------|------|------|------|-------|
| Centennial | 2.52 | 1.07 | 0.66 | 0.83 | 1.21 | 2.55 | 3.88 | 5.77 | 6.53 | 7.91 | 6.97 | 4.67 | 44.59 |
| Morris     | 2.52 | 1.07 | 0.66 | 0.83 | 1.21 | 2.55 | 3.88 | 5.77 | 6.53 | 7.91 | 6.97 | 4.67 | 44.59 |

### License and Permit Requirements

|                            |      |                         |     |                             |     |                                   |      |  |      |
|----------------------------|------|-------------------------|-----|-----------------------------|-----|-----------------------------------|------|--|------|
| Max Direct Diversion (cfs) | 2.00 | Max Morris Storage (af) | 915 | Max Centennial Storage (af) | 767 | Max Diversion plus Morris Storage | 1888 | Max Diversion plus Morris Withdrawals (af) | 2491 |
|----------------------------|------|-------------------------|-----|-----------------------------|-----|-----------------------------------|------|--|------|

Permit 17613 addition 280

#### Minimum Bypass (cfs) - Normal Year

|            | OCT | NOV | DEC | JAN | FEB | MAR | APR | MAY  | JUN | JUL | AUG | SEP |
|------------|-----|-----|-----|-----|-----|-----|-----|------|-----|-----|-----|-----|
| Centennial | 1   | 1   | 1   | 1   | 1   | 1   | 1   | 1    | 1   | 1   | 1   | 1   |
| Morris     | 1   | 5   | 5   | 5   | 5   | 1.5 | 0.5 | 0.75 | 1   | 1   | 1   | 1   |

#### Minimum Bypass (cfs) - Drought Year

|            | OCT | NOV | DEC | JAN | FEB | MAR | APR | MAY | JUN | JUL | AUG | SEP |
|------------|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|
| Centennial | 0.5 | 0.5 | 0.5 | 0.5 | 0.5 | 0.5 | 0.5 | 0.5 | 0.5 | 0.5 | 0.5 | 0.5 |
| Morris     | 0.1 | 1.5 | 3.5 | 3.5 | 3.5 | 1   | 0.5 | 0.1 | 0.1 | 0.1 | 0.1 | 0.1 |



**Figure 5-A**  
**List of Columns in Daily Model**

| Heading           | Title  | Units      | Column | Equation  | Description  |
|-------------------|--|------------|--------|---|--|
| <b>Dates</b>      | Month - Year                                     |            | A      | =DATE(YEAR(B16),MONTH(B16),1)   | Used for creating monthly totals and graphics  |
|                   | Date   |            | B      |   |  |
|                   | Year Type  |            | C      | =VLOOKUP(IF(MONTH(B16)<3,YEAR(B16)-1,YEAR(B16)),Year_Type,IF(MONTH(B16)=OR(3,4),2,3),FALSE)   | Normal or Drought as defined in Permit 20352, used to determine bypass requirements  |
| <b>Inflows</b>    | Centennial                                       | CFS        | D      | Model input developed separately  | Simulated daily inflow based on regression with Elder Creek near Branscomb   |
|                   | Morris+ Cent                                     | CFS        | E      | Model input developed separately  | Simulated daily inflow based on regression with Elder Creek near Branscomb   |
|                   | Morris   | CFS        | F      | Model input developed separately  | Total basin flow less Centennial inflow  |
|                   |  |            |        |   |  |
| <b>Centennial</b> | Inflow   | ACRE- FEET | H      | =D16*1.983  | Centennial inflow converted to acre-feet   |
|                   | Evaporation                                      | ACRE- FEET | I      | =HLOOKUP(MONTH(B16),Control!\$C\$25:\$N\$28,3,FALSE)/IF(DAY(B16)=31,31,EDATE(B16,1)-B16)*VLOOKUP(T15,'Centennial Area-Capacity'!\$C\$7:\$D\$34,2,TRUE)/12 | Multiplies the evaporation rate on control page times the reservoir area. Area is looked up based on beginning of month storage. |
|                   | Bypass Release                                   | ACRE- FEET | J      | =MIN(H16,HLOOKUP(MONTH(B16),Control!\$C\$39:\$N\$46,IF(C16="Normal",3,7),FALSE)*1.983)  | This value is minimum of bypass flow and Centennial inflow   |
|                   | Max Storage                                      |            | K      | =IF(AND(B16>DATE(YEAR(B16),MONTH(Control!\$C\$18),DAY(Control!\$C\$18)),B16<DATE(YEAR(B16),10,1)),Control!\$E\$18,Control!\$F\$18)                        | Maximum capacity of Centennial. This value changes when the flashboards are installed  |
|                   | Number of days left of summer drawdown to Morris | ACRE- FEET | L      | =IF(AND(MONTH(B16)>4,MONTH(B16)<11),DATE(1967,11,1)-DATE(1967,MONTH(B16),DAY(B16)),0)   | Number of days until November 1, if date is after April 30   |

| Heading           | Title                                   | Units         | Column | Equation   | Description   |
|-------------------|---|---------------|--------|--|---|
| <b>Centennial</b> | Standard summer drawdown to Morris      | ACRE-<br>FEET | M      | =IF(L16>0,MAX(0,(T15-Control!\$D\$18)/L16+H16-I16),0)  | Useable water left in Centennial divided by the number of days left of summer drawdown  |
|                   | Extra Summer release when Morris is low | ACRE-<br>FEET | N      | =IF(AG15<Control!\$D\$19+75,MAX(0,MIN(T15-Control!\$D\$18,AB15+AA15)),0)   | If Morris has less than 75 acre-feet of useable water left, release the amount of water used by Morris from Centennial if the water is available  |
|                   | Extra winter release when Morris is low | ACRE-<br>FEET | O      | =IF(OR(AND(AG15<Control!\$D\$19+75,AA15>=Z15),AND(AG15<Control!\$D\$19+10,(T15-Control!\$D\$18)>(Z15-V15))),T15-Control!\$D\$18,0) | If Morris has less than 75 acre-feet of useable water left and the full bypass is already being released from Morris, or if Morris has less than 10 acre-feet, release whatever water Centennial has available  |
|                   | Extra Releases to Morris                | ACRE-<br>FEET | P      | =IF(AG15>Y16-100,0,IF(L16>0,MAX(M16,N16),MAX(0,O16)))  | If Morris is within 100af of full don't make extra release. If making summer drawdowns, release the greater of regular drawdown or extra summer release. During the winter make extra winter releases if needed.  |
|                   | Spill                                   | ACRE-<br>FEET | Q      | =MAX(T15+H16-I16-MAX(J16,P16)-K16,0)   | Amount of water that is over the spillway (>max storage)  |
|                   | Release to Davis Creek                  | ACRE-<br>FEET | R      | =MAX(T15+H16-I16-K16,MAX(J16,P16+Q16),0)   | Sum of Bypass release, extra releases to Morris and Spills  |
|                   | Max Change - Release to Davis Creek     | ACRE-<br>FEET | S      | =IF(Q16=0,MIN(R16,IF(C16="Normal",'License and Permits!\$D\$33,'License and Permits!\$D\$37)+S15),R16)                             | Permit 20352 paragraphs 19A and 19B limit increases or decreases in bypass flows to prevent stranding of fish and damage to aquatic invertebrates. When the reservoir isn't spilling, the releases to Davis Creek may be limited by these requirements. |
|                   | End of Day Storage                      | ACRE-<br>FEET | T      | =T15+H16-I16-S16   | End of day storage in Centennial.   |



| Heading | Title                        | Units         | Column        | Equation  | Description  |
|---------|------------------------------|---------------|---------------|---|--|
| Morris  | Local Inflow                 | ACRE-<br>FEET | V             | =F16*1.983  | Morris local inflow converted to acre-feet   |
|         | Actual Inflow                | ACRE-<br>FEET | W             | =S16+V16  | Total release from Centennial plus local Morris inflow   |
|         | Evaporation                  | ACRE-<br>FEET | X             | =HLOOKUP(MONTH(B16),Control!\$C\$25:\$N\$28,4,FALSE)/IF(DAY(B16)=31,31,EDATE(B16,1)-B16)*VLOOKUP(AG15,'Morris Area-Capacity'!\$C\$8:\$D\$407,2,TRUE)/12 | Multiplies the evaporation rate on control page times the reservoir area. Area is looked up based on beginning of month storage. |
|         | Max Storage                  | ACRE-<br>FEET | Y             | =IF(AND(B16>DATE(YEAR(B16),MONTH(Control!\$C\$19),DAY(Control!\$C\$19)),B16<DATE(YEAR(B16),10,1)),Control!\$E\$19,Control!\$F\$19)                      | Maximum capacity of Morris. This value changes when the flashboards are installed  |
|         | Max bypass requirement       | ACRE-<br>FEET | Z             | =HLOOKUP(MONTH(B16),Control!\$C\$39:\$N\$46,IF(C16="Normal",4,8),FALSE)*1.983   | The Morris bypass requirement specified in Permit 20352 for the month  |
|         | Bypass Release to Davis Ck   | ACRE-<br>FEET | AA            | =MIN(W16,Z16)   | Minimum of the total Morris inflow or the bypass requirement specified in Permit 20352   |
|         | Scheduled Delivery to WTP    | ACRE-<br>FEET | AB            | =HLOOKUP(MONTH(B16),Control!\$C\$9:\$N\$12,MATCH(\$AB\$1,Control!\$B\$11:\$B\$12,0)+2,FALSE)/IF(DAY(B16)=31,31,EDATE(B16,1)-B16)                        | Monthly value looked up based on demand schedule selected on schematic page  |
|         | Spill                        | ACRE-<br>FEET | AC            | =MAX(AG15+W16-X16-AA16-AB16-Y16,0)  | Amount of water that is over the spillway (>max storage)   |
|         | Net Delivery to WTP          | ACRE-<br>FEET | AD            | =MAX(MIN(AG15-Control!\$D\$19+W16-X16-AA16,AB16),0)   | Minimum of scheduled delivery and water available in Morris  |
|         | Total Release to Davis Creek | ACRE-<br>FEET | AE            | =MAX(MIN(AG15-Control!\$D\$19+W16-X16-AA16)+AC16+MAX(IF(MONTH(B16)=OR(7,8,9),W16-X16-AA16-AC16-AD16,0),0),0)  | Sum of bypass release from Morris and spills   |
|         | Total Release and Delivery   | ACRE-<br>FEET | ACRE-<br>FEET | =AD16+AE16  | Sum of delivery to water treatment plant and releases to Davis Creek   |
|         | End of Day Storage           | ACRE-<br>FEET | AG            | =AG15+W16-X16-AF16  | End of day storage in Morris   |
|         | Shortage                     | ACRE-<br>FEET | AH            | =MAX(AB16-AD16,0)   | Shortage in deliveries to the water treatment plant  |

**Figure 6-A  
Year Type Lookup Table**

| Year Type |                 |                   |
|-----------|-----------------|-------------------|
|           | Calculated Mar1 | Calculated Apr 30 |
| 1961      | Normal          | Normal            |
| 1962      | Normal          | Normal            |
| 1963      | Normal          | Normal            |
| 1964      | Normal          | Normal            |
| 1965      | Normal          | Normal            |
| 1966      | Normal          | Normal            |
| 1967      | Normal          | Normal            |
| 1968      | Normal          | Normal            |
| 1969      | Normal          | Normal            |
| 1970      | Normal          | Normal            |
| 1971      | Normal          | Normal            |
| 1972      | Normal          | Normal            |
| 1973      | Normal          | Normal            |
| 1974      | Normal          | Normal            |
| 1975      | Normal          | Normal            |
| 1976      | Drought         | Drought           |
| 1977      | Drought         | Drought           |
| 1978      | Normal          | Normal            |
| 1979      | Normal          | Normal            |
| 1980      | Normal          | Normal            |
| 1981      | Drought         | Drought           |
| 1982      | Normal          | Normal            |
| 1983      | Normal          | Normal            |
| 1984      | Normal          | Normal            |
| 1985      | Normal          | Normal            |
| 1986      | Normal          | Normal            |
| 1987      | Normal          | Normal            |
| 1988      | Normal          | Normal            |

| Year Type |                 |                   |
|-----------|-----------------|-------------------|
|           | Calculated Mar1 | Calculated Apr 30 |
| 1989      | Normal          | Normal            |
| 1990      | Drought         | Drought           |
| 1991      | Normal          | Normal            |
| 1992      | Normal          | Normal            |
| 1993      | Normal          | Normal            |
| 1994      | Normal          | Normal            |
| 1995      | Normal          | Normal            |
| 1996      | Normal          | Normal            |
| 1997      | Normal          | Normal            |
| 1998      | Normal          | Normal            |
| 1999      | Normal          | Normal            |
| 2000      | Normal          | Normal            |
| 2001      | Normal          | Normal            |
| 2002      | Normal          | Normal            |

## **APPENDIX B**

---

### **Development of Hydrology**


## APPENDIX B

### Development of Hydrology

This appendix describes the development of the hydrologic data that are used in the simulation model. Estimates of reservoir inflow were developed by relating the Davis Creek watershed to the Elder Creek watershed. Development of evaporation data is also presented in this Appendix.

#### ***Selection of similar basin***

The Centennial-Morris watershed drains 5.8 square miles. The region can experience heavy rainfall in the winter with little or no rain through the summer. The watershed has a small spring which flows throughout the summer, providing a small amount of inflow to Centennial reservoir.





Centennial Reservoir (from DWR Bulletin 17-93):  
Mendocino County, California  
Hydrologic Unit Code 18010106  
Latitude 39°21'30", Longitude 123°18'42" NAD27  
Crest of Dam 1,682 feet above sea level NGVD29

Morris Reservoir (from DWR Bulletin 17-93):  
Mendocino County, California  
Hydrologic Unit Code 18010106  
Latitude 39°22'12", Longitude 123°17'54" NAD27  
Crest of Dam 1,552 feet above sea level NGVD29

### **Branscomb Gage on Elder Creek**

USGS 11475560 ELDER C NR BRANSCOMB CA  
Mendocino County, California  
Hydrologic Unit Code 18010106  
Latitude 39°43'47", Longitude 123°38'34" NAD27  
Drainage area 6.50 square miles  
Gage datum 1,391.08 feet above sea level NGVD29

The USGS has compiled daily streamflow data from this gage since October 1, 1967.

### **Hydrologic Benchmark Network**

The following abstract is from "Hydrologic Benchmark Network Stations in the U.S. 1963-95 (USGS Circular 1173)". The full text of the report can be found at <http://ny.cf.er.usgs.gov/hbn/report.cfm>

"The Hydrologic Benchmark Network was established in 1963 to provide long-term measurements of streamflow and water quality in areas that are minimally affected by human activities. These data were to be used to study time trends and to serve as controls for separating natural from artificial changes in other streams. The network has consisted of as many as 58 drainage basins in 39 States. This report describes the environmental characteristics and water quality at 56 benchmark basins including 16 in the Eastern United States, 14 in the Midwestern United States, 14 in the West-Central United States, and 12 in the Western United States. The information in this report was compiled to aid in the application and interpretation of historical water-quality data collected as part of the U.S. Geological Survey Hydrologic Benchmark Network program.

"The site characteristics vary amount the stations in the Hydrologic Benchmark Network. Land-use activities range from recreational use and timber harvesting on publicly owned land to agriculture and residential development on privately owned land. The streams drain a variety of physiographic, geologic, and ecologic settings that range from low-elevation coastal plain environments to high-elevation alpine environments. The streamflow characteristics of the stations are variable. Some of the sites are dominated by steady ground-water flows, and others have snow-dominated hydrographs where a large part of the flow results from the melting of the annual snowpack.

“Stream-water chemistry at most Hydrologic Benchmark Network stations appears to be controlled by the interaction of acidic precipitation with underlying soils and bedrock. Land use has a minimal effect on stream-water chemistry except for a few stations in the Eastern and Midwestern regions of the United States. Temporal trends in water-quality constituents were observed at several of the stations and were attributed either to environmental or to method-related factors. Environmental factors that may have caused water-quality trends include increases in residential population, trends in atmospheric deposition, agricultural activities, landscape disturbance, and extended periods of drought. A few common trends were observed among stations, including downward trends in sulfate and upward trends in pH at several stations, which were attributed to changes in field instrumentation and analytical techniques rather than environmental change.”

### ***Development of Streamflow Regression Equations***

#### **California Department of Water Resources Centennial and Morris Inflow Data**

From 1986 through 1988 (before construction of Centennial Reservoir), the California Department of Water Resources (DWR) took flow measurements of the tributaries that discharged into Morris Reservoir. Measurements for Davis Creek, the un-named middle tributary and the un-named east tributary are included in Figure 1-B.

#### **City of Willits Centennial Inflow Data**

Since 1999, the City of Willits has been collecting periodic inflow data for Centennial and Morris reservoirs. Recently, automatic recorders have been added to the weirs and data is currently being collected every six hours. Hydrology was developed using the 2005 inflow data.

#### **Elder Creek (Branscomb Gage) Data**

Elder Creek flow records for the same dates as the DWR measurements are included in Figure 2-B

#### **Regression Equations**

Two sets of regression equations were developed:

1 - Regression of Elder Creek with Davis Creek using 27 DWR measurements:

$$\text{Centennial inflow} = 0.0888 \times \text{Elder Creek flow} + 0.5930$$

$$\text{Correlation coefficient (R}^2\text{)} = 0.8579$$

$$\text{Total Morris and Centennial inflow} = 0.1513 \times \text{Elder Creek flow} + 0.3757$$

$$\text{Correlation coefficient (R}^2\text{)} = 0.9163$$

Morris local inflow was calculated by subtracting the Centennial inflow from the Total inflow.

Figure 3-B is a graphical representation of these regressions with the DWR measurements.

2 - Regression of Elder Creek with Davis Creek using City of Willits 2005 measurements:

$$\text{Centennial low inflow (Elder Creek flow} < 3.5 \text{ cfs)} = 0.017 \times \text{Elder Creek flow} + 0.07$$

$$\text{Correlation coefficient (R}^2\text{)} = 0.96$$

Centennial mid inflow ( $3.5 \text{ cfs} < \text{Elder Creek flow} < 10 \text{ cfs}$ ) =  $0.03 \times \text{Elder Creek flow} + 1.07$

Correlation coefficient ( $R^2$ ) = 0.92

Centennial high inflow ( $\text{Elder Creek flow} > 10 \text{ cfs}$ ) =  $0.09 \times \text{Elder Creek flow} + 0.98$

Correlation coefficient ( $R^2$ ) = 0.62

When Centennial inflow is low ( $< 2 \text{ cfs}$ ) it was assumed that Morris would have no additional local inflow. When Centennial inflow was higher ( $> 2 \text{ cfs}$ ) Morris additional local inflow was assumed to be 38% of the basins inflow.

Figure 4-B, 5-B, and 6-B are graphical representations of these regressions with the City of Willits 2005 measurements.

### ***Estimate of Reservoir Evaporation***

DWR Bulletin 73-79 was used to estimate the monthly evaporation from each reservoir. The Fullerton Pan A coefficient was multiplied by the average pan evaporation recorded at Covello 1E, Lake Pillsbury, and Coyote Dam. Figure 7-B shows these calculations.

Inches of evaporation are converted to acre-feet in the simulation model by multiplying by the surface area of each reservoir. Surface area was estimated using the volume of storage at the beginning of the month and the reservoir area capacity graphs in Figure 8-B.

**Figure 1-B**  
**Department of Water Resources**  
**Davis Creek Streamflow Measurements**

OF CALIFORNIA—RESOURCES AGENCY  
**DEPARTMENT OF WATER RESOURCES**  
 NORTHERN DISTRICT  
 140 MAIN STREET  
 P.O. BOX 607  
 SLO BLUFF 96080  
 (916) 527-6530

GEORGE DEUKMEJIAN, Governor



**MORRIS RESERVOIR TRIBUTARY DISCHARGE (cfs)**


| <u>Date</u> | <u>Davis Creek</u> | <u>Middle Tributary</u> | <u>East Tributary</u> |
|-------------|--------------------|-------------------------|-----------------------|
| 4-24-86     | 2.69               | Pooled                  |                       |
| 5-21-86     | 1.27               | -                       | 0.17                  |
| 6-05-86     | 1.76               | -                       | 0.08                  |
| 6-18-86     | 1.37               | -                       | 0.04                  |
| 7-09-86     | 0.89               | -                       | -                     |
| 7-24-86     | 0.12               | -                       | -                     |
| 8-07-86     | 0.54               | -                       | -                     |
| 8-21-86     | 0.58               | -                       | -                     |
| 9-11-86     | 0.61               | -                       | -                     |
| 9-25-86     | 1.03               | -                       | -                     |
| 10-10-86    | 0.80               | -                       | -                     |
| 10-24-86    | -                  | -                       | -                     |
| 11-06-86    | 0.52               | -                       | -                     |
| 11-21-86    | 0.88               | -                       | -                     |
| 12-11-86    | 0.53               | -                       | -                     |
| 12-23-86    | 1.65               | 0.31                    | 0.77                  |
| 1-09-87     | 1.87               | 0.35                    | 0.66                  |
| 1-22-87     | 0.99               | 0.02                    | 0.13                  |
| 2-05-87     | 4.41               | 0.80                    | 2.04                  |
| 2-18-87     | 5.42               | 1.01                    | 2.34                  |
| 3-04-87     | 1.79               | 0.24                    | 0.81                  |
| 3-17-87     | 8.54               | 1.36                    | 3.53                  |
| 4-03-87     | 3.03               | 0.24                    | 0.74                  |
| 4-13-87     | 1.70               | -                       | -                     |
| 5-07-87     | 1.07               | -                       | -                     |
| 6-05-87     | 0.99               | -                       | Pooled                |
| 6-25-87     | 0.76               | -                       | -                     |
| 7-01-87     | 0.75               | -                       | -                     |
| 8-07-87     | 0.26               | No data                 | No data               |
| 9-03-87     | -                  | "                       | "                     |
| 10-08-87    | 0.30               | "                       | "                     |
| 11-03-87    | 0.50               | "                       | "                     |
| 12-03-87    | 10.03              | "                       | "                     |
| 1-08-88     | 10.47              | "                       | "                     |
| 2-09-88     | 2.23               | "                       | "                     |
| 3-09-88     | 1.81               | "                       | "                     |
| 4-07-88     | 1.08               | "                       | "                     |
| 5-03-88     | 3.67               | "                       | "                     |
| 6-10-88     | 1.46               | "                       | "                     |



**Figure 2-B**  
**Elder Creek Gage Data Compared with**  
**Department of Water Resources Data**

| Date       | Elder Creek<br>(Branscomb)<br>Gage | Centennial<br>Inflow (Davis<br>Creek) DWR<br>Data | Total Inflow<br>(Davis Creek<br>+ Middle<br>Tributary +<br>East<br>Tributary<br>DWR Data |
|------------|------------------------------------|---|--|
|            | cfs                                | cfs   | cfs  |
| 4/24/1986  | 7                                  | 2.69  | 2.69   |
| 5/21/1986  | 6.6                                | 1.27  | 1.44   |
| 6/5/1986   | 4.4                                | 1.76  | 1.84   |
| 6/18/1986  | 3.4                                | 1.37  | 1.41   |
| 7/9/1986   | 1.8                                | 0.89  | 0.89   |
| 7/24/1986  | 1.3                                | 0.12  | 0.12   |
| 8/7/1986   | 1                                  | 0.54  | 0.54   |
| 8/21/1986  | 0.85                               | 0.58  | 0.58   |
| 9/11/1986  | 0.7                                | 0.61  | 0.61   |
| 9/25/1986  | 2.5                                | 1.03  | 1.03   |
| 10/10/1986 | 1.6                                | 0.8   | 0.8  |
| 11/6/1986  | 4                                  | 0.52  | 0.52   |
| 11/21/1986 | 4.6                                | 0.88  | 0.88   |
| 12/11/1986 | 5.1                                | 0.53  | 0.53   |
| 12/23/1986 | 15                                 | 1.65  | 2.73   |
| 1/9/1987   | 25                                 | 1.87  | 2.88   |
| 1/22/1987  | 8.8                                | 0.99  | 1.14   |
| 2/5/1987   | 57                                 | 4.41  | 7.25   |
| 2/18/1987  | 62                                 | 5.42  | 8.77   |
| 3/4/1987   | 22                                 | 1.79  | 2.84   |
| 3/17/1987  | 67                                 | 8.54  | 13.43  |
| 4/3/1987   | 19                                 | 3.03  | 4.01   |
| 4/13/1987  | 11                                 | 1.7   | 1.7  |
| 5/7/1987   | 5.7                                | 1.07  | 1.07   |
| 6/5/1987   | 3                                  | 0.99  | 0.99   |
| 6/25/1987  | 2                                  | 0.76  | 0.76   |
| 7/1/1987   | 1.7                                | 0.75  | 0.75   |


**Figure 3-B**



**Figure 4-B**

**Davis Creek Low Flow Regression Equation**  
From regression of Elder Creek with Davis Creek  
Using City of Willits 2005 measurements


2005 Low Flow Regression (Elder Creek < 3.5 cfs)



**Figure 5-B**

**Davis Creek Mid Range Flow Regression Equation  
From regression of Elder Creek with Davis Creek  
Using City of Willits 2005 measurements**


2005 Mid Flow Regression (3.5 < Elder Creek < 10)



**Figure 6-B**

**Davis Creek High Flow Regression Equation  
From regression of Elder Creek with Davis Creek  
Using City of Willits 2005 measurements**

2005 High Flow Regression (Elder Creek > 10)





**Figure 7-B**  
**Estimate of Monthly Evaporation**

|   | OCT         | NOV         | DEC         | JAN         | FEB         | MAR         | APR         | MAY         | JUN         | JUL         | AUG         | SEP         | Total        |
|---|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|--------------|
| <b>DWR Bulletin 73-79 Pan A Coefficient</b> |             |             |             |             |             |             |             |             |             |             |             |             |              |
| Fullerton                                   | 0.65        | 0.77        | 0.76        | 0.8         | 0.81        | 0.82        | 0.81        | 0.81        | 0.76        | 0.75        | 0.72        | 0.66        | 0.76         |
|   |             |             |             |             |             |             |             |             |             |             |             |             |              |
| <b>DWR Bulletin 73-79 Pan data (mm)</b>     |             |             |             |             |             |             |             |             |             |             |             |             |              |
| Covelo 1E                                   | 92          | 28          | 15          | 27          | 30          | 77          | 111         | 165         | 193         | 240         | 231         | 163         | 1372         |
| Lake Pillsbury                              | 87          | 30          | 22          | 16          | 36          | 76          | 117         | 188         | 211         | 265         | 238         | 176         | 1462         |
| Coyote Dam                                  | 117         | 48          | 29          | 36          | 48          | 84          | 137         | 190         | 251         | 299         | 269         | 200         | 1708         |
| Ave Cov-Pills-Coy                           | 99          | 35          | 22          | 26          | 38          | 79          | 122         | 181         | 218         | 268         | 246         | 180         | 1514         |
|   |             |             |             |             |             |             |             |             |             |             |             |             |              |
| Centennial/Morris (mm)                      | 64          | 27          | 17          | 21          | 31          | 65          | 99          | 147         | 166         | 201         | 177         | 119         | 1132         |
| <b>Centennial/Morris (inches)</b>           | <b>2.52</b> | <b>1.07</b> | <b>0.66</b> | <b>0.83</b> | <b>1.21</b> | <b>2.55</b> | <b>3.88</b> | <b>5.77</b> | <b>6.53</b> | <b>7.91</b> | <b>6.97</b> | <b>4.67</b> | <b>44.59</b> |



**Figure 8-B  
Area Capacity Charts**



## **APPENDIX C**

---

### **Model Validation**

## **APPENDIX C**

### **Model Validation**

The water supply simulation model was validated by comparing the model's predicted water storage with historical periodic measured storage. For this comparison, a simulation was run that used historical water treatment plant deliveries and flashboard installation dates. Because Centennial Reservoir is a fairly new reservoir, comparison was only performed from October 1993 through September 2002 (after Centennial had filled and stabilized).

#### ***Historical Operations Data Used for Validation***

##### **City of Willits Water Treatment Plant Production Data**

The City of Willits provided data on withdrawals from Morris Reservoir ("Production") and water delivered from the treatment plant into the City's water system ("System"). The difference between these values is the water used for backwashing filters that was returned to Morris reservoir. Water treatment plant data provided is included as Figure 1-C.

For the simulation model, this data was converted from monthly to daily values and used in place of the demand data.

##### **Flashboard Installation Dates**

DWR Division of Safety of Dams (DSOD) has approved the use of flashboards across the spillways, which increases the storage capacity of each reservoir. On March 7, 1978, DSOD authorized the installation of flashboards across the Morris spillway from March 16 through October 31. And on January 5, 1990, DSOD authorized the installation of flashboards across the Centennial spillway from April 2 through September 30.

Because the reservoirs fill quickly during the spring runoff, available water supply is very sensitive to the exact date of installation of the flashboards. The historical installation dates, shown in Figure 2-C, were used to validate the simulation model's operations.

##### **Reservoir Storage and Lake Level Data**

Figure 3-C shows historical weekly reservoir storage data provided by the City of Willits. These data were compared with the simulated storage data to validate the model.

#### ***Comparison of Modeled and Historical Total System Storage***

For validation of the simulation model, the water stored in Centennial was added to water stored in Morris and total system storage was compared with historical storage data. Comparison of these values is shown graphically in Figure 4-C and Figure 5-C. Overall, the model does a good job of predicting system operations and water supply both with the DWR inflow series and with the City of Willits inflow series.

The DWR inflow series was based on measurements taken from 1986 – 1988. This was a fairly dry period with annual precipitation slightly below average. The City of Willits inflow series was based on measurements taken in 2005. 2005 was fairly wet with annual precipitation somewhat higher than average. The summer periods for the City of Willits validation shows the reservoirs

being drawn down faster than predicted. It is possible that the regression predicts higher inflow than actually occurs during dry periods.

The filling of Centennial and Morris Reservoirs is sensitive to the exact timing of storm runoff and exact installation date of the flashboards in the spring. In many years the Reservoirs will spill before the flashboards are installed, giving the graphs the stepped rise in the spring. If a storm's runoff estimated by the model is a few days different than historical, or if the modeled flashboards installation is a few days different than historical, there can be significant differences in predicted and actual water stored during the spring. This extra water could cause validation differences in the spring, through the summer, and possibly into the following year.

Differences in validation could also be due to historic surcharging of the reservoirs. Reservoirs often hold more water than their capacity for a short period during storms events or periods of high runoff. The model does not allow the reservoirs to overfill, and so does not predict the capture of the extra surcharged water.

In 1998 and in 2000, the model does not capture as much runoff in the spring as was historically captured. In 1998, the reservoirs were spilling and the surcharge effect increased the historical storage above the modeled storage. This extra water would make a difference throughout the summer. In 2000, the reservoirs were spilling on the flashboard installation date. The surcharge effect, timing of storm and flashboard installation date have all reduced the modeled storage.



**Figure 1-C****Water Treatment Plant Production Data**

| Month  | Production<br>(mg) | Sales<br>(mg) | System<br>(mg) | Month  | Production<br>(mg) | Sales<br>(mg) | System<br>(mg) |
|--------|--------------------|---------------|----------------|--------|--------------------|---------------|----------------|
| Jan-90 | 24.52              | 18.60         | 21.21          | Sep-93 | 35.90              | 30.15         | 43.03          |
| Feb-90 | 20.75              | 20.32         | 21.16          | Oct-93 | 28.60              | 28.13         | 35.85          |
| Mar-90 | 27.09              | 17.91         | 25.87          | Nov-93 | 25.29              | 18.55         | 33.88          |
| Apr-90 | 27.72              | 18.62         | 27.87          | Dec-93 | 26.71              | 19.38         | 30.00          |
| May-90 | 30.66              | 25.28         | 31.00          | Jan-94 | 33.78              | 18.42         | 26.02          |
| Jun-90 | 39.00              | 26.74         | 31.60          | Feb-94 | 33.26              | 25.68         | 23.15          |
| Jul-90 | 49.18              | 28.54         | 44.50          | Mar-94 | 41.66              | 17.98         | 30.46          |
| Aug-90 | 52.45              | 36.59         | 43.71          | Apr-94 | 39.89              | 20.35         | 28.58          |
| Sep-90 | 30.63              | 32.42         | 31.75          | May-94 | 38.27              | 18.80         | 32.00          |
| Oct-90 | 29.83              | 23.33         | 29.52          | Jun-94 | 44.96              |               | 40.15          |
| Nov-90 | 21.36              | 23.78         | 23.30          | Jul-94 | 50.68              | 34.12         | 48.44          |
| Dec-90 | 30.70              | 19.09         | 30.75          | Aug-94 | 54.24              | 34.71         | 46.67          |
| Jan-91 | 29.46              | 16.95         | 24.68          | Sep-94 | 49.51              | 31.91         | 42.24          |
| Feb-91 | 23.09              | 19.07         | 18.46          | Oct-94 | 46.48              | 26.60         | 38.16          |
| Mar-91 | 29.26              | 16.95         | 21.11          | Nov-94 | 33.93              | 21.45         | 27.48          |
| Apr-91 | 23.84              | 16.67         | 21.10          | Dec-94 | 29.64              | 18.39         | 27.68          |
| May-91 | 26.37              | 19.65         | 24.31          | Jan-95 | 34.08              | 20.66         | 28.64          |
| Jun-91 | 43.09              | 27.10         | 33.30          | Feb-95 | 35.17              | 13.51         | 24.75          |
| Jul-91 | 38.64              | 28.20         | 38.57          | Mar-95 | 41.14              | 16.97         | 27.01          |
| Aug-91 | 38.70              | 35.59         | 36.80          | Apr-95 | 30.91              | 16.48         | 26.57          |
| Sep-91 | 38.86              | 31.45         | 35.35          | May-95 | 33.01              | 18.29         | 29.00          |
| Oct-91 | 33.57              | 31.58         | 28.37          | Jun-95 | 39.56              | 23.60         | 35.71          |
| Nov-91 | 25.02              | 23.93         | 23.22          | Jul-95 | 39.36              | 28.80         | 41.25          |
| Dec-91 | 20.10              | 17.10         | 21.48          | Aug-95 | 39.93              | 36.12         | 43.86          |
| Jan-92 | 26.36              | 18.51         | 21.95          | Sep-95 | 36.17              | 31.01         | 37.07          |
| Feb-92 | 24.48              | 15.05         | 19.20          | Oct-95 | 33.33              | 26.36         | 33.00          |
| Mar-92 | 19.53              | 14.84         | 21.20          | Nov-95 | 29.82              | 21.10         | 27.88          |
| Apr-92 | 18.01              | 18.21         | 21.40          | Dec-95 | 34.75              | 20.12         | 25.75          |
| May-92 | 24.56              | 21.26         | 29.60          | Jan-96 | 33.07              | 20.59         | 25.70          |
| Jun-92 | 41.00              | 27.18         | 34.52          | Feb-96 | 33.31              | 15.14         | 25.80          |
| Jul-92 | 43.46              | 30.01         | 36.33          | Mar-96 | 37.70              | 19.31         | 29.69          |
| Aug-92 | 48.61              | 33.66         | 38.84          | Apr-96 | 31.70              | 18.72         | 28.15          |
| Sep-92 | 38.41              | 28.41         | 32.14          | May-96 | 32.36              | 19.14         | 29.66          |
| Oct-92 | 33.98              | 24.64         | 28.07          | Jun-96 | 39.96              | 25.77         | 38.59          |
| Nov-92 | 27.20              | 21.81         | 24.15          | Jul-96 | 45.54              | 31.42         | 49.33          |
| Dec-92 | 30.61              | 16.40         | 25.42          | Aug-96 | 49.38              | 38.67         | 49.39          |
| Jan-93 | 23.90              | 17.96         | 31.99          | Sep-96 | 38.54              | 38.97         | 41.00          |
| Feb-93 | 21.49              | 14.10         | 28.30          | Oct-96 | 33.07              | 32.00         | 34.10          |
| Mar-93 | 23.46              | 16.29         | 28.62          | Nov-96 | 29.02              | 19.03         | 28.03          |
| Apr-93 | 24.11              | 19.96         | 28.26          | Dec-96 | 28.80              | 17.51         | 28.05          |
| May-93 | 24.95              | 18.94         | 32.03          | Jan-97 | 35.32              | 20.16         | 31.04          |
| Jun-93 | 29.50              | 19.36         | 31.29          | Feb-97 | 34.19              | 16.63         | 28.58          |
| Jul-93 | 39.41              | 39.33         | 42.76          | Mar-97 | 38.56              | 16.86         | 32.40          |
| Aug-93 | 40.54              | 31.28         | 43.93          | Apr-97 | 39.11              | 18.89         | 33.65          |

| Month  | Production<br>(mg) | Sales<br>(mg) | System<br>(mg) | Month  | Production<br>(mg) | Sales<br>(mg) | System<br>(mg) |
|--------|--------------------|---------------|----------------|--------|--------------------|---------------|----------------|
| May-97 | 44.96              | 23.47         | 39.28          | Apr-01 | 32.45              | 19.08         | 28.65          |
| Jun-97 | 47.01              | 24.90         | 39.79          | May-01 | 46.49              | 20.94         | 42.44          |
| Jul-97 | 48.34              | 30.16         | 48.72          | Jun-01 | 48.35              | 37.13         | 47.28          |
| Aug-97 | 42.15              | 35.70         | 46.36          | Jul-01 | 50.48              | 30.44         | 51.95          |
| Sep-97 | 35.55              | 31.11         | 36.51          | Aug-01 | 47.43              | 35.67         | 50.46          |
| Oct-97 | 33.44              | 21.25         | 35.11          | Sep-01 | 43.42              | 34.13         | 45.10          |
| Nov-97 | 36.84              | 18.25         | 34.17          | Oct-01 | 42.63              | 24.71         | 40.52          |
| Dec-97 | 43.38              | 21.25         | 38.81          | Nov-01 | 34.67              | 22.58         | 31.08          |
| Jan-98 | 45.76              | 18.98         | 39.64          | Dec-01 | 31.62              | 19.56         | 29.49          |
| Feb-98 | 43.18              | 16.77         | 37.71          | Jan-02 | 32.29              | 19.18         | 26.29          |
| Mar-98 | 48.72              | 15.69         | 40.92          | Feb-02 | 28.28              | 21.91         | 26.76          |
| Apr-98 | 46.74              | 18.81         | 39.87          | Mar-02 | 29.00              | 16.11         | 28.40          |
| May-98 | 47.49              | 18.43         | 41.85          | Apr-02 | 30.43              | 18.28         | 29.57          |
| Jun-98 | 57.85              | 21.61         | 47.03          | May-02 | 42.23              | 20.53         | 36.94          |
| Jul-98 | 65.80              | 29.99         | 60.49          | Jun-02 | 50.01              | 28.59         | 44.56          |
| Aug-98 | 66.56              | 37.68         | 61.76          | Jul-02 | 50.91              | 33.26         | 53.86          |
| Sep-98 | 57.52              | 36.53         | 53.33          | Aug-02 | 52.40              | 38.13         | 50.74          |
| Oct-98 | 45.65              | 27.14         | 40.24          | Sep-02 | 46.90              | 32.68         | 43.00          |
| Nov-98 | 36.53              | 19.83         | 32.69          | Oct-02 | 40.59              | 27.39         | 37.40          |
| Dec-98 | 40.89              | 18.63         | 36.07          | Nov-02 | 32.57              | 22.65         | 28.27          |
| Jan-99 | 40.10              | 21.57         | 33.09          | Dec-02 | 35.53              | 19.32         | 25.44          |
| Feb-99 | 35.68              | 18.51         | 27.45          | Jan-03 | 35.80              | 16.83         | 24.11          |
| Mar-99 | 41.98              | 16.13         | 32.87          | Feb-03 | 31.59              | 15.83         | 22.99          |
| Apr-99 | 31.40              | 19.46         | 31.25          | Mar-03 | 37.44              | 15.75         | 26.33          |
| May-99 | 37.29              | 20.91         | 41.95          | Apr-03 | 37.29              | 18.23         | 26.38          |
| Jun-99 | 46.17              | 29.55         | 50.69          | May-03 | 46.74              | 17.20         | 29.86          |
| Jul-99 | 51.06              | 35.62         | 55.91          | Jun-03 | 53.35              | 26.17         | 46.42          |
| Aug-99 | 45.66              | 35.79         | 50.69          | Jul-03 | 54.43              | 37.00         | 52.69          |
| Sep-99 | 39.35              | 36.66         | 48.47          | Aug-03 | 51.17              | 34.83         | 47.49          |
| Oct-99 | 40.09              | 32.41         | 47.41          |        |                    |               |                |
| Nov-99 | 25.04              | 22.19         | 32.10          |        |                    |               |                |
| Dec-99 | 23.69              | 18.41         | 32.20          |        |                    |               |                |
| Jan-00 | 30.00              | 20.64         | 32.26          |        |                    |               |                |
| Feb-00 | 27.34              | 22.57         | 28.57          |        |                    |               |                |
| Mar-00 | 39.10              | 20.68         | 32.38          |        |                    |               |                |
| Apr-00 | 37.61              | 21.14         | 34.44          |        |                    |               |                |
| May-00 | 44.05              | 22.87         | 44.04          |        |                    |               |                |
| Jun-00 | 52.34              | 29.02         | 53.70          |        |                    |               |                |
| Jul-00 | 49.59              | 31.67         | 56.16          |        |                    |               |                |
| Aug-00 | 45.67              | 40.17         | 54.29          |        |                    |               |                |
| Sep-00 | 37.28              | 33.21         | 41.12          |        |                    |               |                |
| Oct-00 | 31.93              | 27.44         | 34.67          |        |                    |               |                |
| Nov-00 | 26.09              | 22.08         | 30.10          |        |                    |               |                |
| Dec-00 | 25.40              | 19.22         | 30.69          |        |                    |               |                |
| Jan-01 | 30.43              | 20.92         | 30.50          |        |                    |               |                |
| Feb-01 | 25.57              | 18.45         | 26.67          |        |                    |               |                |
| Mar-01 | 36.73              | 17.63         | 39.69          |        |                    |               |                |

**Figure 2-C**  
**Historical Flashboard Installation Dates**

| MORRIS AND CENTENNIAL DAM BOARDS INSTALLATION DATES |            |        |
|---|------------|--------|
| YEAR  | CENTENNIAL | MORRIS |
| 2004  | 1-Apr      | 24-Mar |
| 2003  | 1-Apr      | 14-Mar |
| 2002  | 3-Apr      | 15-Mar |
| 2001  | 29-Mar     | 15-Mar |
| 2000  | 31-Mar     | 16-Mar |
| 1999  | 7-Apr      | 29-Mar |
| 1998  | 10-Apr     | 17-Mar |
| 1997  | 4-Apr      | 19-Mar |
| 1996  | 3-Apr      | 21-Mar |
| 1995  | 13-Apr     | 20-Mar |
| 1994  | 1-Apr      | 17-Mar |
| 1993  | 13-Apr     | 29-Mar |
| 1992  | 17-Apr     | 31-Mar |
| 1991  | 1-Mar      | 25-Mar |
| 1990  | 30-Mar     | 16-Mar |
| 1989  | N/A        | 1-Mar  |
| 1988  | N/A        | 16-Mar |
| 1987  | N/A        | N/A    |

**Figure 3-C**  
**Historical Lake Storage Levels**

| Date     | Morris<br>(acre-<br>feet) | Board/I.O. | Centennial<br>(acre-feet) | Board/I.O. | Date     | Morris<br>(acre-<br>feet) | Board/I.O. | Centennial<br>(acre-feet) | Board/I.O. |
|----------|---------------------------|------------|---------------------------|------------|----------|---------------------------|------------|---------------------------|------------|
| 1/23/99  | 575                       | o          | 512                       | o          | 10/23/99 | 535                       | o          | 275                       | o          |
| 2/6/99   | 575                       | o          | 512                       | o          | 11/4/04  | 532                       | o          | 268                       | o          |
| 2/20/99  | 575                       | o          | 512                       | o          | 11/6/99  | 529                       | o          | 193                       | o          |
| 2/27/99  | 575                       | o          | 512                       | o          | 11/13/99 | 546                       | o          | 294                       | o          |
| 3/6/99   | 575                       | o          | 512                       | o          | 11/20/99 | 542                       | o          | 318                       | o          |
| 3/13/99  | 575                       | o          | 512                       | o          | 11/26/99 | 539                       | o          | 340                       | o          |
| 3/20/99  | 575                       | o          | 512                       | o          | 12/4/99  | 571                       | o          | 384                       | o          |
| 4/1/99   | 575                       | o          | 502.1                     | o          | 12/11/99 | 575                       | o          | 455                       | o          |
| 4/3/99   | 575                       | o          | 492.2                     | o          | 12/18/99 | 575                       | o          | 448                       | o          |
| 4/4/99   | 575                       | o          | 482.3                     | o          | 12/24/99 | 560                       | o          | 456                       | o          |
| 4/6/99   | 575                       | o          | 496.1                     | o          | 12/31/99 | 542                       | o          | 458                       | o          |
| 4/7/99   | 575                       | o          | 608.2                     | i          | 1/1/00   | 542                       | o          | 458                       | o          |
| 4/10/99  | 575                       | o          | 635                       | i          | 1/8/00   | 529                       | o          | 465                       | o          |
| 4/17/99  | 575                       | o          | 635                       | i          | 1/16/00  | 590                       | o          | 536                       | o          |
| 4/29/99  | 575                       | i          | 635                       | i          | 1/22/00  | 582                       | o          | 552                       | o          |
| 5/1/99   | 672                       | i          | 635                       | i          | 1/29/00  | 578                       | o          | 528                       | o          |
| 5/8/99   | 640                       | i          | 635                       | i          | 2/5/00   | 590                       | o          | 560                       | o          |
| 5/15/99  | 621                       | i          | 635                       | i          | 2/12/00  | 590                       | o          | 532                       | o          |
| 5/22/99  | 621                       | i          | 635                       | i          | 2/20/00  | 582                       | o          | 528                       | o          |
| 5/29/99  | 617                       | i          | 635                       | i          | 2/26/00  | 590                       | o          | 540                       | o          |
| 6/5/99   | 613                       | i          | 635                       | i          | 3/4/00   | 590                       | o          | 540                       | o          |
| 6/12/99  | 601                       | i          | 635                       | i          | 3/11/00  | 586                       | o          | 540                       | o          |
| 6/15/99  | 590                       | i          | 635                       | i          | 3/18/00  | 609                       | i          | 526                       | o          |
| 6/19/99  | 575                       | i          | 635                       | i          | 3/25/00  | 645                       | i          | 526                       | o          |
| 6/23/99  | 575                       | o          | 635                       | i          | 4/1/00   | 650                       | i          | 429                       | i          |
| 6/26/99  | 575                       | o          | 635                       | i          | 4/8/00   | 609                       | i          | 500                       | i          |
| 7/6/99   | 546                       | o          | 635                       | i          | 4/15/00  | 590                       | i          | 558                       | i          |
| 7/7/99   | 549                       | o          | 613                       | i          | 4/22/00  | 663                       | i          | 622                       | i          |
| 7/10/99  | 549                       | o          | 613                       | i          | 4/29/00  | 637                       | i          | 655                       | i          |
| 7/17/99  | 553                       | o          | 613                       | i          | 5/6/00   | 629                       | i          | 645                       | i          |
| 7/24/99  | 553                       | o          | 572                       | i          | 5/20/00  | 654                       | i          | 655                       | i          |
| 7/31/99  | 553                       | o          | 548                       | i          | 5/28/00  | 625                       | i          | 645                       | i          |
| 8/7/99   | 553                       | o          | 504.1                     | i          | 6/10/00  | 597                       | i          | 645                       | i          |
| 8/14/99  | 553                       | o          | 484.2                     | i          | 6/17/00  | 578                       | o          | 645                       | i          |
| 8/21/99  | 553                       | o          | 467.1                     | i          | 7/1/00   | 549                       | o          | 627                       | i          |
| 8/28/99  | 553                       | o          | 458.3                     | i          | 7/8/00   | 557                       | o          | 622.5                     | i          |
| 9/1/99   | 553                       | o          | 455                       | i          | 7/14/00  | 525                       | o          | 625                       | i          |
| 9/4/99   | 557                       | o          | 452.5                     | o          | 7/22/00  | 564                       | o          | 548                       | i          |
| 9/18/99  | 557                       | o          | 370.3                     | o          | 7/29/00  | 549                       | o          | 538                       | i          |
| 9/25/99  | 557                       | o          | 336                       | o          | 8/19/00  | 539                       | o          | 408                       | i          |
| 10/2/99  | 557                       | o          | 302                       | o          | 8/27/00  | 564                       | o          | 405.9                     | i          |
| 10/16/99 | 557                       | o          | 288                       | o          | 9/2/00   | 514                       | o          | 401.1                     | o          |
| 10/16/99 | 549                       | o          | 280                       | o          | 9/9/00   | 529                       | o          | 377.4                     | o          |



| Date     | Morris<br>(acre-<br>feet) | Board/I.O. | Centennial<br>(acre-feet) | Board/I.O. | Date     | Morris<br>(acre-<br>feet) | Board/I.O. | Centennial<br>(acre-feet) | Board/I.O. |
|----------|---------------------------|------------|---------------------------|------------|----------|---------------------------|------------|---------------------------|------------|
| 9/23/00  | 546                       | o          | 298.3                     | o          | 8/25/01  | 529                       |            | 168.9                     |            |
| 10/7/00  | 529                       | o          | 270.2                     | o          | 9/1/01   | 539                       |            | 121.3                     |            |
| 10/21/00 | 525                       | o          | 225.5                     | o          | 9/8/01   | 529                       |            | 121.3                     |            |
| 11/4/00  | 546                       | o          | 255.6                     | o          | 9/15/01  | 493                       |            | 102                       |            |
| 11/18/00 | 549                       | o          | 250.8                     | o          | 9/19/01  | 486                       |            | 108                       |            |
| 11/26/00 | 549                       | o          | 268.5                     | o          | 9/22/01  | 472                       |            | 96                        |            |
| 12/2/00  | 567                       | o          | 255.6                     | o          | 9/28/01  |                           |            | 110                       |            |
| 12/9/00  | 567                       | o          | 266.9                     | o          | 9/29/01  | 452                       |            | 116                       |            |
| 12/16/00 | 578                       | o          | 268.5                     | o          | 9/30/01  | 441                       |            |                           |            |
| 1/13/01  | 578                       | o          | 389.3                     | o          | 10/2/01  | 431                       |            | 104.7                     |            |
| 1/27/01  | 578                       | o          | 467.1                     | o          | 10/7/01  | 414                       |            | 104.7                     |            |
| 2/3/01   | 578                       | o          | 504.1                     | o          | 10/13/01 | 424                       |            | 90                        |            |
| 2/18/01  | 586                       | o          | 536.3                     | o          | 10/20/01 | 428                       |            | 104                       |            |
| 2/24/01  | 590                       | o          | 560.1                     | o          | 10/27/01 | 356                       |            | 104.7                     |            |
| 3/11/01  | 578                       | i          | 560.1                     | o          | 11/3/01  | 338                       |            | 121.3                     |            |
| 3/16/01  | 590                       | i          |                           | o          | 11/10/01 | 323                       |            | 121.3                     |            |
| 3/24/01  | 629                       | i          |                           | o          | 11/13/01 | 323                       |            | 148.6                     |            |
| 3/31/01  | 629                       | i          | 484.2                     | i          | 11/14/01 | 323                       |            | 153.7                     |            |
| 4/7/01   | 609                       | i          | 504.1                     | i          | 11/16/01 | 323                       |            | 160.2                     |            |
| 4/11/01  | 601                       | i          |                           | i          | 11/17/01 | 326                       |            | 160.2                     |            |
| 4/15/01  | 590                       | i          | 538.5                     | i          | 11/18/01 | 335                       |            | 155                       |            |
| 4/17/01  |                           |            |                           |            | 11/19/01 | 338                       |            | 148.6                     |            |
| 4/21/01  | 590                       |            | 544.2                     |            | 11/20/01 | 344                       |            | 136.3                     |            |
| 4/28/01  | 582                       |            | 564.1                     |            | 11/21/01 | 353                       |            | 131.3                     |            |
| 5/6/01   | 567                       |            | 570                       |            | 11/22/01 | 472                       |            | 208.4                     |            |
| 5/12/01  | 553                       |            |                           |            | 11/24/01 | 529                       |            | 271.8                     |            |
| 5/17/01  | 539                       |            | 579.9                     |            | 11/23/01 | 574                       |            | 300.5                     |            |
| 5/19/01  | 532                       |            |                           |            | 12/9/01  | 570                       |            | 538.3                     |            |
| 5/23/01  | 518                       |            | 579.9                     |            | 12/15/01 | 586                       |            | 544.2                     |            |
| 5/26/01  | 525                       |            | 568                       |            | 12/25/01 | 582                       |            | 542.3                     |            |
| 6/2/01   | 518                       |            | 556.1                     |            | 12/29/01 | 582                       |            | 544.2                     |            |
| 6/9/01   | 525                       |            | 542.1                     |            | 1/5/02   | 582                       | o          | 544.2                     | o          |
| 6/17/01  | 536                       |            | 482.3                     |            | 1/20/02  | 574                       | o          | 536.3                     | o          |
| 6/23/01  | 536                       |            | 456.9                     |            | 1/26/02  | 582                       | o          | 542.3                     | o          |
| 6/26/01  | 536                       |            | 445.2                     |            | 2/2/02   | 574                       | o          | 538.3                     | o          |
| 6/30/01  | 542                       |            | 445.2                     |            | 2/10/02  | 582                       | o          | 544.2                     | o          |
| 7/2/01   | 539                       |            |                           |            | 2/15/02  | 578                       | o          |                           | o          |
| 7/4/01   | 539                       |            |                           |            | 2/17/02  | 578                       | o          | 536.3                     | o          |
| 7/8/01   | 536                       |            |                           |            | 2/24/02  | 582                       | o          | 538.3                     | o          |
| 7/14/01  | 529                       |            | 389.3                     |            | 3/1/02   | 578                       | o          |                           | o          |
| 7/22/01  | 521                       |            | 330                       |            | 3/3/02   | 575                       | o          | 536.3                     | o          |
| 7/27/01  | 529                       |            |                           |            | 3/9/02   | 578                       | o          | 538.3                     | o          |
| 7/28/01  |                           |            |                           |            | 3/13/02  | 578                       | o          | 538.3                     | o          |
| 8/4/01   | 542                       |            | 254                       |            | 3/17/02  | 601                       | i          | 536.3                     | o          |
| 9/11/01  | 535                       |            |                           |            | 3/24/02  | 650                       | i          | 536.3                     | o          |
| 8/19/01  | 518                       |            | 208.4                     |            | 3/29/02  |                           | i          | 504.1                     | o          |

| Date     | Morris<br>(acre-<br>feet) | Board/I.O. | Centennial<br>(acre-feet) | Board/I.O | Date    | Morris<br>(acre-<br>feet) | Board/I.O. | Centennial<br>(acre-feet) | Board/I.O |
|----------|---------------------------|------------|---------------------------|-----------|---------|---------------------------|------------|---------------------------|-----------|
| 4/6/02   | 650                       | i          | 536.3                     | i         | 2/16/03 | 654                       | o          | 546.2                     | o         |
| 4/12/02  | 650                       | i          | 542.3                     | i         | 2/22/03 | 579                       | o          | 546.2                     | o         |
| 4/13/02  | 648                       | i          | 546.2                     | i         | 3/2/03  | 578                       | o          | 542.3                     | o         |
| 4/20/02  | 633                       | i          | 570                       | i         | 3/9/03  | 557                       | o          | 566                       | o         |
| 4/27/02  | 621                       | i          | 593.9                     | i         | 3/15/03 | 641                       | i          | 566                       | o         |
| 5/4/02   | 613                       | i          | 605.8                     | i         | 3/29/03 | 676                       | i          | 482.3                     | o         |
| 5/11/02  | 600                       | i          | 617.7                     | i         | 4/5/03  | 676                       | i          | 546.2                     | i         |
| 5/18/02  | 579                       | i          | 624.9                     | i         | 4/12/03 | 676                       | i          | 576                       | i         |
| 5/26/02  | 570                       | i          | 645.5                     | i         | 4/19/03 | 676                       | i          | 647.9                     | i         |
| 6/1/02   | 564                       | i          | 647.9                     | i         | 4/26/03 | 676                       | i          | 659.9                     | i         |
| 6/8/02   | 546                       | i          | 645.5                     | i         | 5/3/03  | 676                       | i          | 647.9                     | i         |
| 6/16/02  | 532                       | i          | 643.1                     | i         | 5/12/03 | 676                       | i          | 647.9                     | i         |
| 6/22/02  | 518                       | i          | 629.6                     | i         | 5/19/03 | 676                       | i          | 647.9                     | i         |
| 6/27/02  | 49.4                      | i          | 629.6                     | i         | 5/26/03 | 672                       | i          | 647.9                     | i         |
| 6/29/02  | 497                       | i          | 624.9                     | i         | 6/2/03  | 667                       | i          | 647.9                     | i         |
| 7/6/02   | 501                       | i          | 596.3                     | i         | 6/8/03  | 667                       | i          | 645.5                     | i         |
| 7/13/02  | 514                       | o          | 566                       | i         | 6/15/03 | 667                       | i          | 645.5                     | i         |
| 7/20/02  | 518                       | o          | 536.3                     | i         | 6/22/03 | 654                       | i          | 645.5                     | i         |
| 7/28/02  | 542                       | o          | 465.6                     | i         | 6/29/03 | 633                       | i          | 645.5                     | i         |
| 8/4/02   | 546                       | o          | 451                       | i         | 7/6/03  | 593                       | i          | 645.5                     | i         |
| 8/10/02  | 546                       | o          | 398.8                     | i         | 7/13/03 | 564                       | o          | 645.5                     | i         |
| 3/15/02  | 539                       | o          | 375                       | o         | 7/20/03 | 553                       | o          | 627.2                     | i         |
| 8/17/02  | 529                       | o          | 372.6                     | o         | 7/27/03 | 553                       | o          | 584.4                     | i         |
| 8/24/02  | 497                       | o          | 372.6                     | o         | 8/3/03  | 553                       | o          | 558.1                     | o         |
| 8/31/02  | 479                       | o          | 367.9                     | o         | 8/10/03 | 553                       | o          | 448.8                     | o         |
| 9/7/02   | 452                       | o          | 363.1                     | o         | 8/17/03 | 557                       | o          | 448.8                     | o         |
| 9/15/02  | 414                       | o          | 353.6                     | o         | 8/24/03 | 553                       | o          | 448.8                     | o         |
| 9/22/02  | 391                       | o          | 353.6                     | o         | 8/30/03 | 546                       | o          | 448.8                     | o         |
| 9/28/02  | 375                       | o          | 348                       | o         | 9/3/03  | 542                       | o          | 372.6                     | o         |
| 10/6/02  | 435                       | o          | 263.7                     | o         |         |                           |            |                           |           |
| 10/13/02 | 441                       | o          | 222                       | o         |         |                           |            |                           |           |
| 10/26/02 | 416                       | o          | 213.5                     | o         |         |                           |            |                           |           |
| 11/3/02  | 414                       | o          | 209.4                     |           |         |                           |            |                           |           |
| 11/9/02  | 418                       | o          | 230.6                     |           |         |                           |            |                           |           |
| 11/17/02 | 416                       | o          | 223.8                     |           |         |                           |            |                           |           |
| 11/28/02 | 418                       | o          | 223.8                     |           |         |                           |            |                           |           |
| 12/7/02  | 401                       | o          | 222                       |           |         |                           |            |                           |           |
| 12/16/02 | 654                       | o          | 218.6                     |           |         |                           |            |                           |           |
| 12/22/02 | 654                       | o          | 542.3                     |           |         |                           |            |                           |           |
| 12/28/02 | 654                       | o          | 546.2                     |           |         |                           |            |                           |           |
| 1/4/03   | 654                       | o          | 546.2                     | o         |         |                           |            |                           |           |
| 1/11/03  | 654                       | o          | 546.2                     | o         |         |                           |            |                           |           |
| 1/18/03  | 579                       | o          | 537.3                     | o         |         |                           |            |                           |           |
| 1/25/03  | 579                       | o          | 537.3                     | o         |         |                           |            |                           |           |
| 2/1/03   | 579                       | o          | 537.3                     | o         |         |                           |            |                           |           |
| 2/8/03   | 571                       | o          | 464.2                     | o         |         |                           |            |                           |           |

Figure 4-C

## Morris Plus Centennial End of Month Storage

Inflow based on regression with DWR measurements







Figure 5-C

## Morris Plus Centennial End of Month Storage

Inflow based on City of Willits 2005 data





## **APPENDIX D**

---

### **Detailed Model Results**

## APPENDIX D

### Detailed model results

#### *Current Level of Demand with DWR Inflow*

**Table 1-D Current Annual Operations Summary - Calendar Year**

|      |             |      |         |         |  |                |      |      |       |         |                   |
|------|-------------|------|---------|---------|--|----------------|------|------|-------|---------|-------------------|
| max  | 3508        | 102  | 3409    | 512     |  | 5687           | 46   | 1099 | 4542  | 628     | 651               |
| ave  | 1913        | 83   | 1820    | 276     |  | 2975           | 36   | 1018 | 1913  | 348     | 81                |
|      | Centennial  |      |         |         |  | Morris         |      |      |       |         |                   |
|      | End of Dec  |      |         |         |  | Net Release to |      |      |       |         |                   |
|      | Delivery to |      |         |         |  | Davis          |      |      |       |         |                   |
| Year | Inflow      | Evap | Release | Storage |  | Inflow         | Evap | WTP  | Creek | Storage | Delivery Shortage |
| 1968 | 1889        | 82   | 1428    | 512     |  | 2565           | 37   | 1099 | 1262  | 292     |                   |
| 1969 | 2405        | 93   | 2391    | 432     |  | 3892           | 43   | 1099 | 2605  | 437     |                   |
| 1970 | 2886        | 83   | 2723    | 512     |  | 4563           | 38   | 1099 | 3235  | 628     |                   |
| 1971 | 1895        | 95   | 2118    | 194     |  | 3260           | 44   | 1099 | 2359  | 385     |                   |
| 1972 | 1839        | 92   | 1585    | 356     |  | 2687           | 43   | 1099 | 1550  | 381     |                   |
| 1973 | 2940        | 93   | 2691    | 512     |  | 4569           | 42   | 1099 | 3180  | 628     |                   |
| 1974 | 2548        | 94   | 2875    | 91      |  | 4477           | 44   | 1099 | 3612  | 350     |                   |
| 1975 | 2185        | 94   | 2012    | 170     |  | 3359           | 44   | 1099 | 2185  | 380     |                   |
| 1976 | 920         | 85   | 955     | 51      |  | 1410           | 32   | 1099 | 421   | 238     |                   |
| 1977 | 896         | 23   | 469     | 455     |  | 908            | 12   | 449  | 433   | 252     | 651               |
| 1978 | 2023        | 95   | 2334    | 49      |  | 3567           | 44   | 1099 | 2286  | 389     |                   |
| 1979 | 1683        | 90   | 1269    | 373     |  | 2262           | 40   | 1099 | 1168  | 344     |                   |
| 1980 | 1576        | 92   | 1763    | 94      |  | 2680           | 43   | 1099 | 1588  | 294     |                   |
| 1981 | 2056        | 84   | 1554    | 512     |  | 2809           | 31   | 1099 | 1345  | 628     |                   |
| 1982 | 2440        | 96   | 2344    | 512     |  | 3870           | 44   | 1099 | 2726  | 628     |                   |
| 1983 | 3508        | 99   | 3409    | 512     |  | 5687           | 46   | 1099 | 4542  | 628     |                   |
| 1984 | 1688        | 97   | 1591    | 512     |  | 2586           | 45   | 1099 | 1601  | 469     |                   |
| 1985 | 926         | 84   | 1302    | 53      |  | 1763           | 33   | 1084 | 1016  | 100     | 16                |
| 1986 | 2012        | 87   | 1911    | 66      |  | 3135           | 41   | 1069 | 1893  | 233     | 30                |
| 1987 | 1641        | 78   | 1181    | 448     |  | 2145           | 25   | 978  | 1107  | 268     | 122               |
| 1988 | 1062        | 71   | 1360    | 79      |  | 1916           | 20   | 888  | 1088  | 189     | 211               |
| 1989 | 1299        | 82   | 1247    | 49      |  | 1970           | 35   | 1099 | 869   | 155     |                   |
| 1990 | 1099        | 55   | 1040    | 54      |  | 1623           | 28   | 1099 | 528   | 122     |                   |
| 1991 | 858         | 47   | 819     | 46      |  | 1231           | 18   | 606  | 629   | 100     | 493               |
| 1992 | 1122        | 40   | 956     | 171     |  | 1554           | 16   | 579  | 888   | 172     | 520               |
| 1993 | 2051        | 102  | 1813    | 307     |  | 3065           | 45   | 1099 | 1710  | 382     |                   |
| 1994 | 892         | 73   | 1068    | 58      |  | 1504           | 21   | 834  | 931   | 100     | 265               |
| 1995 | 3111        | 98   | 2678    | 394     |  | 4676           | 45   | 1091 | 3144  | 495     | 8                 |
| 1996 | 3485        | 99   | 3268    | 512     |  | 5529           | 45   | 1099 | 4251  | 628     |                   |
| 1997 | 1885        | 87   | 2119    | 190     |  | 3254           | 40   | 1099 | 2547  | 196     |                   |
| 1998 | 3069        | 100  | 2702    | 457     |  | 4671           | 45   | 1099 | 3267  | 455     |                   |
| 1999 | 1950        | 94   | 2219    | 94      |  | 3400           | 43   | 1099 | 2373  | 339     |                   |
| 2000 | 1648        | 85   | 1603    | 54      |  | 2571           | 39   | 1099 | 1612  | 159     |                   |
| 2001 | 1570        | 43   | 1068    | 512     |  | 1982           | 16   | 661  | 1083  | 381     | 439               |



## Future Level of Demand with DWR Inflow

**Table 2-D Future Annual Operations Summary - Calendar Year**

| max  | 3508       | 97   | 3412    | 512                      | 5689   | 43     | 1649                      | 3804                         | 628                      | 1299                 |
|------|------------|------|---------|--------------------------|--------|--------|---------------------------|------------------------------|--------------------------|----------------------|
| ave  | 1913       | 72   | 1828    | 229                      | 2983   | 28     | 1258                      | 1690                         | 226                      | 391                  |
|      | Centennial |      |         |                          |        | Morris |                           |                              |                          |                      |
| Year | Inflow     | Evap | Release | End of<br>Dec<br>Storage | Inflow | Evap   | Net<br>Delivery to<br>WTP | Release to<br>Davis<br>Creek | End of<br>Dec<br>Storage | Delivery<br>Shortage |
| 1968 | 1889       | 71   | 1421    | 452                      | 2559   | 23     | 1180                      | 1192                         | 263                      | 469                  |
| 1969 | 2405       | 88   | 2431    | 337                      | 3931   | 35     | 1481                      | 2425                         | 254                      | 168                  |
| 1970 | 2886       | 77   | 2634    | 512                      | 4474   | 30     | 1386                      | 2684                         | 628                      | 263                  |
| 1971 | 1895       | 93   | 2254    | 60                       | 3396   | 38     | 1574                      | 2305                         | 108                      | 75                   |
| 1972 | 1839       | 82   | 1576    | 241                      | 2678   | 32     | 1376                      | 1197                         | 180                      | 273                  |
| 1973 | 2940       | 87   | 2582    | 512                      | 4460   | 34     | 1597                      | 2381                         | 628                      | 52                   |
| 1974 | 2548       | 92   | 2913    | 55                       | 4515   | 37     | 1497                      | 3506                         | 103                      | 153                  |
| 1975 | 2185       | 92   | 2094    | 54                       | 3441   | 37     | 1598                      | 1809                         | 100                      | 51                   |
| 1976 | 920        | 48   | 882     | 45                       | 1337   | 16     | 862                       | 459                          | 100                      | 787                  |
| 1977 | 896        | 23   | 488     | 430                      | 927    | 11     | 350                       | 442                          | 223                      | 1299                 |
| 1978 | 2023       | 92   | 2312    | 49                       | 3544   | 36     | 1483                      | 2148                         | 100                      | 166                  |
| 1979 | 1683       | 67   | 1543    | 121                      | 2537   | 20     | 1318                      | 1180                         | 118                      | 331                  |
| 1980 | 1576       | 85   | 1554    | 58                       | 2471   | 33     | 1414                      | 1042                         | 100                      | 235                  |
| 1981 | 2056       | 58   | 1544    | 512                      | 2800   | 17     | 1180                      | 1075                         | 628                      | 469                  |
| 1982 | 2440       | 94   | 2346    | 512                      | 3872   | 38     | 1649                      | 2381                         | 432                      | 0                    |
| 1983 | 3508       | 96   | 3412    | 512                      | 5689   | 40     | 1649                      | 3804                         | 628                      | 0                    |
| 1984 | 1688       | 95   | 1703    | 401                      | 2699   | 38     | 1649                      | 1471                         | 169                      | 0                    |
| 1985 | 926        | 47   | 1224    | 56                       | 1685   | 15     | 881                       | 858                          | 100                      | 768                  |
| 1986 | 2012       | 82   | 1928    | 58                       | 3152   | 33     | 1313                      | 1807                         | 100                      | 336                  |
| 1987 | 1641       | 51   | 1200    | 448                      | 2164   | 16     | 967                       | 1058                         | 223                      | 682                  |
| 1988 | 1062       | 52   | 1359    | 99                       | 1915   | 16     | 967                       | 1042                         | 114                      | 682                  |
| 1989 | 1299       | 68   | 1282    | 48                       | 2005   | 21     | 1157                      | 840                          | 100                      | 493                  |
| 1990 | 1099       | 26   | 1068    | 54                       | 1651   | 19     | 1091                      | 541                          | 100                      | 558                  |
| 1991 | 858        | 40   | 830     | 41                       | 1242   | 15     | 622                       | 605                          | 100                      | 1027                 |
| 1992 | 1122       | 35   | 957     | 171                      | 1555   | 14     | 629                       | 873                          | 140                      | 1020                 |
| 1993 | 2051       | 97   | 2028    | 97                       | 3280   | 43     | 1649                      | 1514                         | 214                      | 0                    |
| 1994 | 892        | 29   | 901     | 58                       | 1337   | 13     | 577                       | 860                          | 100                      | 1072                 |
| 1995 | 3111       | 95   | 2812    | 263                      | 4810   | 40     | 1637                      | 3020                         | 213                      | 12                   |
| 1996 | 3485       | 96   | 3140    | 512                      | 5401   | 40     | 1649                      | 3296                         | 628                      | 0                    |
| 1997 | 1885       | 80   | 2264    | 53                       | 3399   | 30     | 1339                      | 2558                         | 100                      | 310                  |
| 1998 | 3069       | 95   | 2691    | 335                      | 4660   | 41     | 1640                      | 2935                         | 145                      | 9                    |
| 1999 | 1950       | 92   | 2142    | 52                       | 3323   | 36     | 1480                      | 1852                         | 100                      | 169                  |
| 2000 | 1648       | 78   | 1569    | 53                       | 2537   | 31     | 1258                      | 1249                         | 100                      | 391                  |
| 2001 | 1570       | 37   | 1073    | 512                      | 1987   | 14     | 678                       | 1063                         | 332                      | 971                  |



## Current Level of Demand with City of Willits Inflow

**Table 3-D Current Annual Operations Summary - Calendar Year**

|      |            |      |         |         |  |   |      |              |       |         |  |                   |
|------|------------|------|---------|---------|--|---|------|--------------|-------|---------|--|-------------------|
| max  | 3960       | 104  | 3861    | 512     |  | 5728                                      | 46   | 1099         | 4583  | 628     |  | 284               |
| ave  | 2332       | 90   | 2233    | 342     |  | 3137                                      | 40   | 1078         | 2012  | 406     |  | 122               |
|      | Centennial |      |         |         |  | Morris                                    |      |              |       |         |  |                   |
|      |            |      |         |         |  | Net Delivery into Water Release to End of |      |              |       |         |  |                   |
|      |            |      |         | Dec     |  |   |      | Distribution | Davis | Dec     |  |                   |
| Year | Inflow     | Evap | Release | Storage |  | Inflow                                    | Evap | System       | Creek | Storage |  | Delivery Shortage |
| 1968 | 2384       | 89   | 1978    | 512     |  | 2865                                      | 41   | 1099         | 1254  | 607     |  | 0                 |
| 1969 | 2790       | 94   | 2720    | 488     |  | 3923                                      | 44   | 1099         | 2886  | 500     |  | 0                 |
| 1970 | 3315       | 84   | 3207    | 512     |  | 4699                                      | 40   | 1099         | 3432  | 628     |  | 0                 |
| 1971 | 2417       | 97   | 2528    | 304     |  | 3419                                      | 45   | 1099         | 2507  | 396     |  | 0                 |
| 1972 | 2288       | 94   | 1986    | 512     |  | 2842                                      | 44   | 1099         | 1660  | 435     |  | 0                 |
| 1973 | 3407       | 94   | 3314    | 512     |  | 4837                                      | 43   | 1099         | 3502  | 628     |  | 0                 |
| 1974 | 2977       | 96   | 3173    | 221     |  | 4457                                      | 45   | 1099         | 3550  | 390     |  | 0                 |
| 1975 | 2581       | 97   | 2407    | 298     |  | 3470                                      | 45   | 1099         | 2315  | 400     |  | 0                 |
| 1976 | 1336       | 96   | 1233    | 305     |  | 1533                                      | 43   | 1099         | 391   | 399     |  | 0                 |
| 1977 | 1264       | 61   | 997     | 512     |  | 1286                                      | 18   | 1040         | 385   | 242     |  | 59                |
| 1978 | 2398       | 97   | 2694    | 119     |  | 3678                                      | 45   | 1099         | 2376  | 399     |  | 0                 |
| 1979 | 2189       | 97   | 1699    | 512     |  | 2492                                      | 45   | 1099         | 1303  | 445     |  | 0                 |
| 1980 | 1939       | 94   | 2216    | 141     |  | 2918                                      | 44   | 1099         | 1835  | 384     |  | 0                 |
| 1981 | 2488       | 89   | 2028    | 512     |  | 3032                                      | 43   | 1099         | 1646  | 628     |  | 0                 |
| 1982 | 2854       | 97   | 2757    | 512     |  | 3990                                      | 45   | 1099         | 2845  | 628     |  | 0                 |
| 1983 | 3960       | 100  | 3861    | 512     |  | 5728                                      | 46   | 1099         | 4583  | 628     |  | 0                 |
| 1984 | 2100       | 99   | 2001    | 512     |  | 2785                                      | 45   | 1099         | 1737  | 532     |  | 0                 |
| 1985 | 1345       | 86   | 1530    | 241     |  | 1832                                      | 39   | 1099         | 1014  | 212     |  | 0                 |
| 1986 | 2435       | 90   | 2457    | 129     |  | 3404                                      | 42   | 1099         | 2141  | 333     |  | 0                 |
| 1987 | 2061       | 84   | 1594    | 512     |  | 2349                                      | 36   | 1099         | 1220  | 327     |  | 0                 |
| 1988 | 1426       | 81   | 1724    | 133     |  | 2105                                      | 26   | 1054         | 1165  | 187     |  | 45                |
| 1989 | 1703       | 88   | 1683    | 66      |  | 2205                                      | 41   | 1099         | 861   | 389     |  | 0                 |
| 1990 | 1479       | 85   | 1229    | 230     |  | 1627                                      | 38   | 1099         | 477   | 402     |  | 0                 |
| 1991 | 1248       | 85   | 1317    | 76      |  | 1576                                      | 35   | 1099         | 672   | 172     |  | 0                 |
| 1992 | 1549       | 58   | 1347    | 220     |  | 1772                                      | 17   | 816          | 963   | 148     |  | 284               |
| 1993 | 2449       | 104  | 2199    | 366     |  | 3205                                      | 45   | 1099         | 1828  | 381     |  | 0                 |
| 1994 | 1242       | 82   | 1472    | 55      |  | 1726                                      | 25   | 985          | 996   | 100     |  | 114               |
| 1995 | 3519       | 99   | 2978    | 497     |  | 4612                                      | 45   | 1091         | 3118  | 458     |  | 8                 |
| 1996 | 3911       | 99   | 3796    | 512     |  | 5661                                      | 46   | 1099         | 4346  | 628     |  | 0                 |
| 1997 | 2265       | 89   | 2436    | 251     |  | 3313                                      | 42   | 1099         | 2491  | 309     |  | 0                 |
| 1998 | 3497       | 101  | 3135    | 512     |  | 4736                                      | 46   | 1099         | 3464  | 436     |  | 0                 |
| 1999 | 2431       | 95   | 2613    | 234     |  | 3536                                      | 44   | 1099         | 2424  | 404     |  | 0                 |
| 2000 | 2035       | 85   | 2110    | 73      |  | 2832                                      | 41   | 1099         | 1850  | 245     |  | 0                 |
| 2001 | 2016       | 65   | 1512    | 512     |  | 2207                                      | 17   | 879          | 1161  | 395     |  | 220               |



**uture Level of Demand with City of Willits Inflow**

**Table 4-D Future Annual Operations Summary - Calendar Year**

|      |            |      |         |                    |  |   |      |        |       |         |  |                   |
|------|------------|------|---------|--------------------|--|---|------|--------|-------|---------|--|-------------------|
| max  | 3960       | 98   | 3864    | 512                |  | 5731  | 44   | 1649   | 3955  | 628     |  | 1157              |
| ave  | 2332       | 76   | 2243    | 252                |  | 3146  | 29   | 1359   | 1751  | 233     |  | 379               |
|      | Centennial |      |         |                    |  | Morris  |      |        |       |         |  |                   |
|      |            |      |         |                    |  | Net Delivery into Water Release to End of Distribution Davis Dec System Creek Storage |      |        |       |         |  |                   |
| Year | Inflow     | Evap | Release | End of Dec Storage |  | Inflow  | Evap | System | Creek | Storage |  | Delivery Shortage |
| 1968 | 2384       | 76   | 1881    | 481                |  | 2768  | 24   | 1301   | 1307  | 239     |  | 348               |
| 1969 | 2790       | 91   | 2825    | 356                |  | 4028  | 37   | 1584   | 2415  | 231     |  | 65                |
| 1970 | 3315       | 80   | 3079    | 512                |  | 4571  | 30   | 1475   | 2669  | 628     |  | 174               |
| 1971 | 2417       | 94   | 2691    | 144                |  | 3582  | 39   | 1649   | 2384  | 138     |  |                   |
| 1972 | 2288       | 89   | 2043    | 300                |  | 2899  | 35   | 1649   | 1181  | 171     |  |                   |
| 1973 | 3407       | 90   | 3106    | 512                |  | 4630  | 36   | 1649   | 2489  | 628     |  |                   |
| 1974 | 2977       | 93   | 3341    | 56                 |  | 4624  | 38   | 1607   | 3504  | 104     |  | 42                |
| 1975 | 2581       | 93   | 2429    | 115                |  | 3492  | 38   | 1638   | 1751  | 168     |  | 11                |
| 1976 | 1336       | 63   | 1334    | 53                 |  | 1634  | 17   | 1225   | 461   | 100     |  | 424               |
| 1977 | 1264       | 21   | 825     | 471                |  | 1114  | 11   | 492    | 492   | 218     |  | 1157              |
| 1978 | 2398       | 93   | 2725    | 51                 |  | 3709  | 39   | 1602   | 2186  | 100     |  | 47                |
| 1979 | 2189       | 78   | 1978    | 184                |  | 2770  | 22   | 1491   | 1230  | 128     |  | 158               |
| 1980 | 1939       | 89   | 1978    | 55                 |  | 2680  | 35   | 1532   | 1141  | 100     |  | 117               |
| 1981 | 2488       | 65   | 1966    | 512                |  | 2970  | 17   | 1358   | 1067  | 628     |  | 291               |
| 1982 | 2854       | 95   | 2760    | 512                |  | 3992  | 39   | 1649   | 2390  | 542     |  |                   |
| 1983 | 3960       | 96   | 3864    | 512                |  | 5731  | 41   | 1649   | 3955  | 628     |  |                   |
| 1984 | 2100       | 96   | 2004    | 512                |  | 2788  | 40   | 1649   | 1586  | 142     |  |                   |
| 1985 | 1345       | 63   | 1736    | 57                 |  | 2038  | 16   | 1059   | 1004  | 100     |  | 590               |
| 1986 | 2435       | 85   | 2346    | 62                 |  | 3293  | 34   | 1410   | 1849  | 100     |  | 239               |
| 1987 | 2061       | 56   | 1580    | 487                |  | 2335  | 16   | 1063   | 1160  | 196     |  | 586               |
| 1988 | 1426       | 56   | 1723    | 133                |  | 2105  | 16   | 1026   | 1129  | 129     |  | 623               |
| 1989 | 1703       | 81   | 1699    | 57                 |  | 2221  | 26   | 1351   | 873   | 100     |  | 298               |
| 1990 | 1479       | 44   | 1439    | 53                 |  | 1838  | 21   | 1275   | 541   | 100     |  | 374               |
| 1991 | 1248       | 42   | 1206    | 52                 |  | 1465  | 15   | 687    | 763   | 100     |  | 963               |
| 1992 | 1549       | 35   | 1369    | 197                |  | 1794  | 14   | 697    | 1039  | 143     |  | 952               |
| 1993 | 2449       | 98   | 2428    | 120                |  | 3434  | 44   | 1649   | 1604  | 281     |  |                   |
| 1994 | 1242       | 39   | 1268    | 55                 |  | 1522  | 14   | 752    | 937   | 100     |  | 897               |
| 1995 | 3519       | 95   | 3117    | 363                |  | 4750  | 41   | 1636   | 2972  | 202     |  | 13                |
| 1996 | 3911       | 97   | 3665    | 512                |  | 5529  | 41   | 1649   | 3413  | 628     |  |                   |
| 1997 | 2265       | 84   | 2637    | 56                 |  | 3514  | 31   | 1428   | 2582  | 100     |  | 221               |
| 1998 | 3497       | 96   | 3042    | 414                |  | 4644  | 42   | 1643   | 2852  | 207     |  | 6                 |
| 1999 | 2431       | 93   | 2695    | 58                 |  | 3617  | 37   | 1638   | 2049  | 100     |  | 11                |
| 2000 | 2035       | 80   | 1958    | 54                 |  | 2679  | 31   | 1321   | 1327  | 100     |  | 328               |
| 2001 | 2016       | 38   | 1520    | 512                |  | 2216  | 14   | 727    | 1236  | 338     |  | 922               |

## References

Mast, M.A., and Clow, David W., 2000, Environmental characteristics and water-quality of Hydrologic Benchmark Network stations in the Western United States, U.S. Geological Survey Circular 1173-D, 115 p. <http://ny.cf.er.usgs.gov/hbn/report.cfm>

State of California Department of Water Resources. Dams Within Jurisdiction of the State of California, Bulletin 17-93, 12 p. and 49 p.

State of California Department of Water Resources. Evaporation from Water Surfaces in California, Bulletin 73-9-79, 13 p., 78 p. and 79 p.

## **APPENDIX E**

---

### **Cost Estimates**

The intention of estimating costs in the Water Supply Planning Study is to provide reasonably accurate cost estimates for comparison of alternatives, not to anticipate every possible contingency. The capital cost estimates herein, particularly for the dams, are not sufficient to budget the design and construction phases because the scope definition is preliminary, and the necessary equipment, construction materials and labor are subject to price volatility and influenced by economic conditions and competition. If the City chooses to expand Morris Reservoir or develop a supplemental surface water supply, a more detailed study of sub-alternatives and costs is recommended to develop a basis for decision making and design.

While the groundwater supply alternative is less complex, updating the cost estimate is advisable during design of each phase of the groundwater supply project.

**Table E-1. Estimated Cost of Expanding Morris Reservoir**

| Component   | Estimated Cost, dollars <sup>(a)</sup> |
|---|--|
| Concrete dam (assumed dimensions: 100-foot height and 500-foot length at crest) | 6,400,000                              |
| Spillway and fish ladder  | 1,800,000                              |
| Fish screen, pump station, and pipeline   | 600,000                                |
| Water treatment plant expansion   | 4,400,000                              |
| Subtotal  | 13,200,000                             |
| Construction contingency (25 percent)   | 3,300,000                              |
| Subtotal  | 16,500,000                             |
| Engineering and project administration (15 percent)                             | 2,500,000                              |
| Environmental documentation and permits   | 800,000                                |
| Land purchase <sup>(b)</sup>  | 0                                      |
| Total   | 19,800,000                             |
| <b>Round-off</b>  | <b>\$20 million</b>                    |

<sup>(a)</sup> Based on ENR Construction Cost Index of 7518 (September 2005)

<sup>(b)</sup> Assuming current land owned by City is adequate



**Table E-2. Estimated Cost of Supplemental Surface Water Supply<sup>(a)</sup>**

| Component  | Estimated Cost, dollars <sup>(b)</sup> |
|--|--|
| Concrete dam (assumed dimensions: 60 feet high by 200 feet long) | 2,600,000                              |
| Spillway and fish ladder   | 800,000                                |
| Fish screen, pump station, and pipeline                          | 600,000                                |
| Water treatment plant  | 4,400,000                              |
| Pipeline (assumed 4 miles @ \$100/lineal foot)                   | 2,100,000                              |
| Subtotal   | 10,500,000                             |
| Construction contingency (25 percent)                            | 2,625,000                              |
| Subtotal   | 13,125,000                             |
| Engineering and project administration (15 percent)              | 1,970,000                              |
| Environmental documentation and permits                          | 800,000                                |
| Land (60 acres including buffer @ \$30,000/acre)                 | 1,800,000                              |
| Total  | 17,695,000                             |
| <b>Round-off</b>   | <b>\$18 million</b>                    |

<sup>(a)</sup> Assuming another dam in separate watershed of Little Lake Valley

<sup>(b)</sup> Based on ENR Construction Cost Index of 7518 (September 2005)

**Table E-3. Estimated Cost of Groundwater Supply – Phase 1**

| Component  | Estimated Cost, dollars <sup>(a)</sup> |
|--|--|
| Wells No. 1 and No. 2 (develop and equip)                                      | 780,000                                |
| Groundwater treatment plant  | 1,250,000                              |
| Pipelines from Wells No. 1 and No. 2 to centralized plant (2,500 LF @ \$75/LF) | 188,000                                |
| Pipeline from plant to distribution system (500 LF @ \$120/LF)                 | 60,000                                 |
| Subtotal   | 2,278,000                              |
| Construction contingency (25 percent)  | 570,000                                |
| Subtotal   | 2,848,000                              |
| Engineering and project administration (15 percent)                            | 427,000                                |
| Environmental documentation and permits  | 120,000                                |
| Land purchase <sup>(b)</sup>   | 0                                      |
| Total  | 3,395,000                              |
| <b>Round-off</b>   | <b>\$3.4 million</b>                   |

<sup>(a)</sup> Based on ENR Construction Cost Index of 7518 (September 2005)

<sup>(b)</sup> Assuming use of City property (Figure 5-2)

**Table E-4. Estimated Cost of Groundwater Supply – Phase 2**

| Component   | Estimated Cost, dollars <sup>(a)</sup> |
|---|--|
| Well No. 3 (develop and equip)  | 390,000                                |
| Groundwater treatment plant expansion                                 | 750,000                                |
| Pipeline from Well No. 3 to centralized plant<br>(1,000 LF @ \$75/LF) | 75,000                                 |
| Subtotal  | 1,215,000                              |
| Construction contingency (25 percent)                                 | 304,000                                |
| Subtotal  | 1,519,000                              |
| Engineering and project administration<br>(15 percent)                | 228,000                                |
| Land (0.5 acres including buffer @<br>\$30,000/acre)                  | 15,000                                 |
| Total   | 1,762,000                              |
| <b>Round-off</b>  | <b>\$1.8 million</b>                   |

<sup>(a)</sup> Based on ENR Construction Cost Index of 7518 (September 2005)

**Table E-5. Estimated Cost of Groundwater Supply – Phase 3**

| Component   | Estimated Cost, dollars <sup>(a)</sup> |
|---|--|
| Well No. 4 (develop and equip)  | 390,000                                |
| Groundwater treatment plant expansion                                 | 750,000                                |
| Pipeline from Well No. 4 to centralized plant<br>(1,000 LF @ \$75/LF) | 75,000                                 |
| Subtotal  | 1,215,000                              |
| Construction contingency (25 percent)                                 | 304,000                                |
| Subtotal  | 1,519,000                              |
| Engineering and project administration<br>(15 percent)                | 228,000                                |
| Land (0.5 acres including buffer @<br>\$30,000/acre)                  | 15,000                                 |
| Total   | 1,762,000                              |
| <b>Round-off</b>  | <b>\$1.8 million</b>                   |

<sup>(a)</sup> Based on ENR Construction Cost Index of 7518 (September 2005)